2023 Water System Assessment Report Bridgetown

Final Report



230822.00 • September 2023

0	FINAL		BB	2023-09-13	M.L
А	DRAFT		BB	2023-07-30	ML
	Issue or	Revision	Reviewed By:	Date	Issued By:
This document was prepared for herein. The material and inform reflects CBCL Limited's opinion based on the information availup preparation. Any use of this do its content by third parties is the third party. CBCL Limited accept any damages suffered as a result this document.		or the party indicated mation in the document and best judgment able at the time of ocument or reliance on ne responsibility of the ots no responsibility for ult of third party use of	PR DAT B. B. B. B. B.	OFESSION E:Sept. 13, 2023 J. BICKERTON 11131 S OF NOVA SCOTT	

Project No. 230822.00





Platinum member

September 13th, 2023

Mr. Jim Young, P.Eng. Director of Municipal Operations Municipality of the County of Annapolis 752 St. George Street Annapolis Royal, NS B0S 1A0

Dear Mr. Young:

RE: Bridgetown Water Utility 2023 Water System Assessment Report

Please find enclosed the 2023 System Assessment Report (SAR) for the Bridgetown Water Utility (the Utility) completed by CBCL Limited (CBCL) on behalf of the Municipality of the County of Annapolis (MOCA). This report includes the specific requirements of a SAR as outlined in the Nova Scotia Environment and Climate Change (NSECC) *Approval to Operate* for a Water Distribution System.

Yours very truly,

CBCL Limited

Ben Bickerton, M.A.Sc., P.Eng. Process Engineer Direct: (902) 492-7979, Ext. 2271 E-Mail: <u>bbickerton@cbcl.ca</u>

Project No: 230822.00

This document was prepared for the party indicated herein. The material and information in the document reflects CBCL Limited's opinion and best judgment based on the information available at the time of preparation. Any use of this document or reliance on its content by third parties is the responsibility of the third party. CBCL Limited accepts no responsibility for any damages suffered as a result of third party use of this document.

Contents

1 Pro	ject	1	
1.1	Introduction1		
1.2	Purpose1		
2 Cha	aracter	ization of the Water Source	
2.1 Source Description & Schematic			
	2.1.1	Back-up Water Supplies5	
2.2	Microbi	al Risks	
	2.2.1	Surface Water Sources6	
	2.2.2	Groundwater Sources6	
2.3	Chemic	al & Physical Risks	
	2.3.1	Disinfection By-Products7	
	2.3.2	Lead & Corrosion Control8	
	2.3.3	Guidelines for Canadian Drinking Water Quality10	
	2.3.4	Guidelines for Monitoring Public Drinking Water Supplies11	
	2.3.5	Source Water Protection Plan for Monitoring12	
	2.3.6	Cyanobacteria13	
2.4	Filter Ba	ackwash Water	
2.5	Source	Quantity	
	2.5.1	Demand Growth14	
2.6	Source	Water Protection Plan 14	
2.7	Conclus	sion & Recommendations	
	2.7.1	Treatment Requirements to Protect Against Pathogenic Organisms16	
	2.7.2	GUDI Classification16	
	2.7.3	Disinfection By-Products16	
	2.7.4	Lead & Corrosion Control16	
	2.7.5	Guidelines for Canadian Drinking Water Quality17	
	2.7.6	Guidelines for Monitoring Public Drinking Water Supplies17	
	2.7.7	Source Water Protection Plan Monitoring18	
	2.7.8	Filter Backwash Water Discharge18	

	2.7.9	Source Quantity	18
	2.7.10	Source Water Protection Plan	19
3 Tre	reatment Processes, Facilities, & Equipment		
3.1	Treatm	ent Process	20
	3.1.1	Treatment Process Schematic	20
	3.1.2	Turbidity Levels & Associated Criteria	21
	3.1.3	Membrane Filtration	25
	3.1.4	Primary Disinfection	25
	3.1.5	Secondary Disinfection	27
	3.1.6	Other Critical Processes	27
	3.1.7	Waste Streams	27
3.2	Distribu	ution Water Quality	
	3.2.1	Chlorine Residual Levels	28
	3.2.2	Microbial Water Quality	28
	3.2.3	Turbidity	28
	3.2.4	Cross Connection Control Program	29
	3.2.5	Other Distribution System Monitoring Programs	29
3.3	On-Site Inspection		29
3.4	Conclusion & Recommendations		29
	3.4.1	Turbidity Levels	29
	3.4.2	Primary Disinfection	30
	3.4.3	Secondary Disinfection	30
	3.4.4	Other Critical Processes	30
	3.4.5	Waste Streams	30
	3.4.6	Distribution Water Quality	30
	3.4.7	On-site Inspection	31
4 Op	eratio	ns, Monitoring, & Management	32
4.1	Operat	ions & Maintenance	32
4.2	Monito	ring & Reporting	33
	4.2.1	Review of Recent Submitted Annual Report	35
4.3	Manag	ement	35
4.4	Conclu	sion & Recommendations	
	4.4.1	Operation & Maintenance	35

	4.4.2	Monitoring & Reporting	.35
	4.4.3	Management	.36
5 Abi	lity to	Comply	37
5.1	Summa	ary	37
	5.1.1	Treatment Processes, Facilities, & Equipment	.37
	5.1.2	Distribution System Water Quality	.38
	5.1.3	Operations, Monitoring, & Management	.39
	5.1.4	Recommendations	.39
5.2	Report	Preparation	42

Appendices

- A Tables Required by the Terms of References
- B Watershed Boundary Plan
- C Distribution Map
- D Corrosion Control Program Results
- E Last Round of Sampling Data for *GCDWQ*
- F Last Round of Sampling Data for *GMPDWS*
- G Approval to Operate
- H Approval to Withdrawal
- I Schematic of the Treatment & Disinfection Process
- J Water Protection Zone Mapping in GIS Format for NSECC
- K Terms of Reference Checklist

1 Project

1.1 Introduction

The objective of this System Assessment Report (SAR) is to verify that the operation, supply, and distribution provided by this system complies with the environmental standards for safe drinking water as outlined in the *Nova Scotia Treatment Standards for Municipal Drinking Water Systems* (June 2022). This report follows the Terms of Reference provided by Nova Scotia Environment and Climate Change (NSECC). In addition to verifying the required performance, this report will identify any sources of concern and provide appropriate recommendations.

The overall study area includes all Bridgetown Water Utility (the Utility) infrastructure and wellfields within the municipal boundaries of the Community of Bridgetown. The infrastructure is owned by the Municipality of the County of Annapolis (MCA) and includes:

- Source water wellfields.
- Non- GUDI* source wells.
- Monitoring wells.
- Chlorination buildings.
- Transmission and distribution mains.
- Water distribution storage underground concrete storage reservoir.
- * GUDI= Groundwater under the direct influence of surface water.

1.2 Purpose

CBCL Limited (CBCL) has been retained by MCA to complete the 2023 SAR for the Bridgetown Water Utility to verify that the system meets the requirements to comply with the current standards outlined by NSECC. Previous SARs were completed in February 2004 and March 2013.

This report, prepared by CBCL, verifies that the system can:

- Meet current environmental standards, which are frequently updated and enhanced for public health protection.
- Meet the minimum requirements set out in the Nova Scotia Treatment Standards for Municipal Drinking Water Systems.
- Demonstrate performance with disinfection criteria.
- Demonstrate performance with turbidity criteria.



- Demonstrate that online equipment is in place and appropriately alarmed to continuously monitor chlorine residual, turbidity, and all parameters related to other primary disinfectants.
- Confirm that waste streams generated by the treatment facilities are adequately managed.

This report is organised into the following four sections:

- 1 Characterization of the Water Source.
- 2 Treatment Processes, Facilities and Equipment.
- 3 Operations, Monitoring and Management.
- 4 Ability to Comply with the terms of the SAR.



2 Characterization of the Water Source

This section of the SAR characterizes the source water for the system by reporting on the following:

- 1 Microbial risks.
- 2 Chemical and Physical risks.
 - a. Lead and corrosion control.
 - b. Guidelines for Canadian Drinking Water Quality (GCDWQ).
 - c. Guideline for Monitoring Public Drinking Water Supplies (GMPDWS).
 - d. Source Water Protection Plan (SWPP) monitoring.
- 3 Source Quantity.
- 4 SWPP.

2.1 Source Description & Schematic

Source water for the system is supplied by two wellfields, both located along Hampton Mountain Road. The new wellfield contains one non-GUDI production well (PW4) and is located approximately 1.3 km away from the existing wellfield. The original wellfield contains three non-GUDI production wells (PW1, PW2, PW3). The production wells are drilled to depths ranging from 103.6 - 122 m into an underlying layer of coarse sandstone. PW1 is currently not in use as per the updated Approval to Withdraw (2020). This was taken out of production as it exhibited the highest concentrations of uranium of all wells. Well construction information is provided below in Table 2.1.

Well	Parameter	Value
	UTM (Easting)	318864
	UTM (Northing)	4969098
	UTM (Zone)	20
	Well Total Depth (m)	103.6
PW1	Casing Depth (m)	97.5
	Diameter (mm)	254
	Screen Description	Bedrock: 10.7 m. Screen (4X5 ft) 54.86-56.39 m, 73.15-74.68 m,

Table 2.1: Summary of Bridgetown Wells



Well	Parameter	Value
		91.44-92.96 m,
		103.63-105.16 m
	UTM (Easting)	318783
	UTM (Northing)	4969291
	UTM (Zone)	20
	Well Total Depth (m)	106.7
	Casing Depth (m)	100.6
PW2	Diameter (mm)	254
	Screen Description	Bedrock:10.7 m. Screen (4X5 ft) 51.82-53.34 m 76.2-77.72 m 88.39- 89.92 m
	UTM (Easting)	318843
	UTM (Northing)	4969033
	UTM (Zone)	20
D\\/2	Well Total Depth (m)	121.9
FVVJ	Casing Depth (m)	21.3
	Diameter (mm)	203
	Screen Description	Bedrock: 9.1 m Screen: 21.34-121.9 m
	UTM (Easting)	318104
	UTM (Northing)	4970229
	UTM (Zone)	20
	Well Total Depth (m)	57.6
FVV4	Casing Depth (m)	12.2
	Diameter (mm)	203
	Screen Description	Bedrock: 6 m Screen: 12.2-57.6 m
	UTM (Easting)	318612
	UTM (Northing)	4969326
	UTM (Zone)	20
MW09 - 01	Well Total Depth (m)	60.9
	Casing Depth (m)	12.2
	Diameter (mm)	152
	Screen Description	Open borehole
	UTM (Easting)	318065
	UTM (Northing)	4970378
	UTM (Zone)	20
	Well Total Depth (m)	6.1
	Casing Depth (m)	3.05
	Diameter (mm)	51



Well	Parameter	Value
	Screen Description	Unavailable
	UTM (Easting)	318063
	UTM (Northing)	4970377
	UTM (Zone)	20
MW17-01S	Well Total Depth (m)	12.2
	Casing Depth (m)	9.15
	Diameter (mm)	51
	Screen Description	Unavailable
	UTM (Easting)	318829
	UTM (Northing)	4968955
	UTM (Zone)	20
Τ\Λ/Λ	Well Total Depth (m)	122
1 1 1 4	Casing Depth (m)	12.2
	Diameter (mm)	152
	Screen Description	Bedrock: 8 m
		Open hole
	UTM (Easting)	318130
	UTM (Northing)	4970238
	UTM (Zone)	20
TW5	Well Total Depth (m)	91.5
	Casing Depth (m)	12.2
	Diameter (mm)	152
	Screen Description	Open borehole

The three production wells (PW1, PW2, PW3) located in the existing wellfield all flow into a combined common pipe to the well control building 1. The production well (PW4) in the new wellfield flows directly to well control building 2 located in the new wellfield. There is infrastructure within the well control building 2 for an additional well source to be added, but none currently exist. Both well control buildings use sodium hypochlorite for primary disinfection. Flows from both well control buildings then feed into a common transmission water main that fills a reservoir located north of the community, which then flows by gravity to the distribution system. The source water schematic is identified on the Watershed Boundary Plan, provided in Appendix B.

2.1.1 Back-up Water Supplies

PW1 has been identified in the Water Withdrawal Approval as a potential back-up supply but is not currently in regular use due to elevated uranium concentrations.

2.2 Microbial Risks

Treatment requirements for all Nova Scotia municipal water system include the following:
3.0-log reduction in protozoa (e.g., *Cryptosporidium* oocysts and *Giardia* cysts).

• 4.0-log reduction in viruses.

Log reductions of microbial agents must be achieved by a combination of filtration and disinfection. Non-GUDI groundwater supplies are credited with 3.0-log reduction of protozoa by natural in-situ attenuation/filtration. As such, only a 4.0-log reduction of viruses by disinfection is required.

2.2.1 Surface Water Sources

There are no surface water sources utilized by the Bridgetown System.

2.2.2 Groundwater Sources

The system uses non-GUDI groundwater sources and is required to achieve a minimum of 4.0-log reduction of viruses according to the requirements outlined in the *Nova Scotia Treatment Standards for Municipal Drinking Water Systems* (2022). Chlorine disinfection is used to achieve the required virus log reductions.

The current NSECC *Approval to Operate* designates wells PW1, PW2, PW3, and PW4 as non-GUDI. This Approval was issued following the completion of GUDI assessments on PW1, PW2, and PW3 in 2009 and on PW4 in 2016. The wells were determined to be non-GUDI at Step 1 of the assessment. Nova Scotia Environment issued an Approval to Operate in 2019 reflecting the status of the production wells as non-GUDI. A summary of the production well GUDI classification is presented below in Table 2.2.

	0		
Well Name	Classification	GUDI Protocol	
PW1	Non-GUDI	Step 1	
PW2	Non-GUDI	Step 1	
PW3	Non-GUDI	Step 1	
PW4	Non-GUDI	Step 1	

Table 2.2: Bridgetown Drinking Water Production Well GUDI Classification

During the site visit conducted on June 7, 2022, there were no obvious changes in the surrounding area that would warrant re-classification of the wells.

2.3 Chemical & Physical Risks

Routine monitoring for general chemical and physical water quality parameters is conducted as per the requirement outlined in the *Approval to Operate*.

2.3.1 Disinfection By-Products

Trihalomethanes (THMs) and Haloacetic Acids (HAAs) levels are currently monitored on a quarterly basis at three different locations within the distribution system. The sample locations are as follows:

- Site A: 684 Hampton Mountain Road (Storage tank).
- Site B: 27 Granville Street West (Ward's Farm).
- Site C: 612 Granville Street, east (Nobs Farm Market).

The extremities of the distribution system are most likely to have the longest residence times and will consequently have the highest concentrations of Disinfection By-Products (DBPs). Sites B and C were selected due to the long retention times at the distal ends of the system. Site A represents the entry into the distribution system from the storage tank.

The DBP sample locations appear to be appropriate to represent the areas with the highest potential for THMs and HAAs. The locations of the DBP sampling points are presented in on the Water Distribution Map in Appendix C.

2.3.1.1 Trihalomethanes

THM sampling results for 2022 are provided in Table A.2 (Appendix A). Monitoring occurs quarterly as per the *Approval to Operate*. THM levels observed in the distribution system have always been less than the Locational Running Annual Average (LRAA) maximum of 100 μ g/L.

THM results in 2022 were very low, or below the detection limit, in all samples. MCA could request a reduction in sampling locations and frequency from quarterly to annually since the LRAA is less than 0.01 mg/L, based on 2022 quarterly samples.

2.3.1.2 Haloacetic Acids

HAA5 concentration results for 2022 is provided in Table A.3 (Appendix A). Monitoring occurs quarterly as per the *Approval to Operate*. HAA5 levels observed in the distribution system have always been less than the LRAA maximum of 80 μ g/L.

HAA results in 2022 sampling were all below the detection limit. MCA could request a reduction in sampling locations and frequency from quarterly to annually since the LRAA is less than 0.01 mg/L, based on 2022 quarterly samples.

2.3.1.3 Other Disinfectant By-Products

Other DBPs listed in the NSECC Approval to Operate include Bromate and Chlorate, if sodium hypochlorite is stored for more than three months. The water treatment system utilizes sodium hypochlorite for primary and secondary disinfection. Operators confirmed that sodium hypochlorite is not stored for more than one month and, therefore, testing for Bromate and Chlorate has not been required.



2.3.2 Lead & Corrosion Control

The *Approval to Operate* requires MCA to minimize corrosion to the distribution system and residential plumbing. Minimizing the corrosion of the drinking water helps to protect distribution infrastructure and to minimize the release of lead and copper into the drinking water through contact with plumbing materials.

2.3.2.1 Lead & Copper

MCA has established a Lead Sampling Program for use in the distribution system. The purpose of this program is to implement consistent sampling of lead in residential buildings to assess public exposure, as well as to evaluate the Municipality's Corrosion Control Program.

The Lead Sampling Program outlines the sample locations and provides the following sections:

- Collecting Samples for Lead and Copper.
 - Sample Protocol and Number of Samples.
 - o Sample Information.
- Notification and Investigation Procedures.
- Public Information and Communication Plan.
- Taking Action.

The *Guidelines for Canadian Drinking Water Quality (GCDWQ)* sets a Maximum Acceptable Concentration (MAC) of 0.005 mg/L for total lead. According to the *Approval to Operate*, the minimum number of sample locations is determined by the current serviced population. Table 2.3 displays the ranges for the minimum number of sample locations required based on the number of customers serviced.

Number of People Served	Number of Sample Locations (Annual)
≤500	5
501-3,300	10
3,301-10,000	20
10,001-100,000	30
>100,000	50

Table 2.3: Minimum Number of Sample Locations for Lead and Copper Sampling

As of 2022, the Bridgetown system serves approximately 1,000 people; therefore, ten locations are required to comply with Approval. MCA sampled seven residential locations for lead, which is not in compliance with the minimum number of sample locations required.

Sampling occurred twice in 2022, once in July and once in November (this is outside the required sampling window of May – October). Sample sites were selected based on the



following rationale to identify residences that were more likely to exceed the MAC for lead in drinking water:

- Residences with known lead service lines.
- Residences constructed prior to 1975.
- Residences that have shown elevated residential lead in prior testing.

1L Random Daytime Samples (RDT) were collected from the kitchen of residences and sent to a third-party lab for analysis. Sample locations, dates, and results for 2022 are provided in Table 2.4 and Table 2.5.

Sample Date	Address	Lead Results (µg/L)
05-July-22	18 Church St.	6.0
05-July-22	12 Church St.	<0.5
05-July-22	10 Rectory St.	<0.5
05-July-22	54 Rectory St.	<0.5
05-July-22	211 Granville St.	<0.5
05-July-22	4037 Highway 201	<0.5
05-July-22	124 South St	<0.5

Table 2.4: Lead Sampling Locations & Results (July 2022)

Table 2.5: Lead and Copper Sampling Locations & Results (November 2022)

Sample Date	Address	Lead Results (µg/L)	Copper Results (µg/L)
07-Nov-22	18 Church St.	6.5	116
07-Nov-22	12 Church St.	<0.5	72
07-Nov-22	10 Rectory St.	<0.5	71
07-Nov-22	54 Rectory St.	<0.5	25
07-Nov-22	211 Granville St.	<0.5	70

Lead concentrations were exceeded above the MAC limit of 5 μ g/L at one location during both sampling events. MCA followed the response procedures as outlined in the 2022 monitoring plan. The homeowners and NSECC were notified of the exceedance. Based on the current Approval to Operate requirements, Tier 1 and 2 six-hour stagnation tests should be conducted at all sites where exceedances were observed to follow the *Approval to Operate*.

MCA should begin sampling ten residential locations to be in compliance with the current Approval to Operate and the NSECC *Requirements for Lead and Copper Management*. Clarification from NSECC on lead and copper sampling requirements should be requested and an updated Approval to Operate with current sampling requirements should be provided.

2.3.2.2 Corrosion Control

The current *Approval to Operate* (Schedule A) includes requirements to monitor and minimize corrosion within the distribution system. Regular sampling for various corrosion control parameters is required to be conducted on a quarterly basis in the distribution system. Sampling parameters include the following:

- ▶ pH.
- Alkalinity.
- Conductivity.
- Temperature.
- Dissolved oxygen.
- Chlorine residual.

The *Approval to Operate* indicates that these parameters will assist MCA to determine the corrosivity of the water, and the type of corrosion control system that may be needed. MCA has identified in the Annual Sampling Plan the three locations within the distribution system to be sampled on a quarterly basis for two consecutive years.

The Annual Report did not include results for these parameters at any sampling locations in the distribution system, which is not in compliance with the *Approval to Operate*. **MCA should begin sampling in accordance with its Annual Sampling Plan and Approval to Operate for corrosion control parameters.**

Currently no comprehensive document outlining the Corrosion Control Plan has been developed. No sampling results for the parameters identified in the Approval to Operate and the Annual Sampling Plan were available for review. A Corrosion Control Plan should be developed and should include a sampling plan, action limits for corrosion monitoring parameters, and description of follow-up actions. If water is deemed non-corrosive from sampling results, a request to NSECC for a reduction in sampling frequency can be made.

2.3.3 Guidelines for Canadian Drinking Water Quality

All parameters with associated MACs listed in the *GCDWQ* are required to be analyzed from a raw and treated water sample every five years. The most recent round of *GCDWQ* compliance sampling was completed on the following date:

- Sample Date #1: March 2012.
- Sample Date #2: June 18, 2018.
- Sample Date #3: Summer 2023 (scheduled).



Results from the last round of sampling, as required by NSECC, are provided in Appendix E. The next round of sampling will be completed in summer 2023 to meet the minimum requirements of one sampling event every five years.

Raw water samples were collected at PW2, and treated water samples were collected from the Town Hall. PW2 and treated samples were in compliance with NSECC requirements for the health-related parameters of the *GCDWQ* as shown in the 2018 sampling results, though the locations were not in compliance. MCA is required to take samples from each individual wellhead as well as treated water. Results for PW3 and PW4 were not provided and were therefore unable to be analyzed to determine if all parameters were within acceptable limits.

The next round of sampling is set to take place in the summer of 2023. Once these results have been received, the results should be compared to the previous testing to determine if any noticeable trends are identified between the past round of sampling.

MCA must begin *GCDWQ* compliance sampling for raw water from each individual well head in the next round of sampling (2023). Raw and treated water sampling is required as per the *Approval to Operate*.

2.3.4 Guidelines for Monitoring Public Drinking Water Supplies

The Nova Scotia Treatment Standards for Municipal Drinking Water Systems requires that municipal water utilities monitor water quality for the parameters listed in the *Guidelines for Monitoring Public Drinking Water Supplies (GMPDWS)*. As per the *Approval to Operate,* the *GMPDWS* samples are collected and tested every two years at an accredited water quality laboratory. The last round of sampling results for raw and treated water from August 2021 are provided in Appendix F. There were no distinguishable water quality trends; however, not all individual wells were sampled in 2021 to compare directly to the 2019 sample results. Operations staff have reported anecdotally that uranium concentrations have generally been increasing at each of PW1 (before being taken offline), PW2, and PW3.

As per the last round of sampling completed in August 2021, Bridgetown is not in compliance with the NSECC sampling requirements of the *GMPDWS* based on the number of samples taken. Raw water quality from each individual wellhead, as well as treated water samples, should be collected during the next round of compliance testing, which is scheduled to occur in summer 2023.

In 2019, Health Canada added a health-based maximum for total manganese of 120 µg/L. NSECC updated the *GMPDWS* to reflect this change and requires monitoring of total manganese in raw, treated, and distribution system samples. As per the Municipality's *Approval to Operate*, manganese is to be sampled twice per year, during the spring and fall. Samples were taken in July 2022 and were below the health-based maximum.



Manganese testing for raw water samples should be taken twice per year in the spring and fall to comply, and distribution system samples should be taken quarterly with the Approval to Operate.

Uranium is tested multiple times per month at each source well to ensure limits are not being exceeded using a field-testing kit. All wells were below the limit for uranium in 2022.

2.3.5 Source Water Protection Plan for Monitoring

The SWPP for the wellfield outlines the recommended monitoring plan and possible sources of contaminants as point sources and non-point sources. A list of the sample locations and associated sampling schedule is provided below in Table 2.4.

Darameter	Locations			
Parameter	PW2	PW3	PW4	
Total Coliform and E. coli	Weekly	Weekly	Weekly	
Turbidity	Weekly	Weekly	Weekly	
рН	Daily grab or continuous	Daily grab or continuous	Daily grab or continuous	
Uranium, Pesticides, Herbicides	Yearly	Yearly	Yearly	
Total Trihalomethanes	Quarterly	Quarterly	Quarterly	
Haloacetic acids	Quarterly	Quarterly	Quarterly	
Chlorine residual	Weekly or continuous	Weekly or continuous	Weekly or continuous	
Fluoride	Every two years	Every two years	Every two years	
Arsenic, Antimony, Lead	Every two years	Every two years	Every two years	
Volatile Organic Compounds	Every five years	Every five years	Every five years	

Table 2.4: Bridgetown SWPP Monitoring Plan

The sampling protocols for the wellfields protected water area provides sufficient data and information needed to constantly evaluate the effectiveness of the SWPP. The extensive sampling network in tandem with the comprehensive measurement of analytical parameters provides MCA with the strong early warning system for potential contamination or changes in source water quality.

Currently this monitoring program is not fully implemented; the Annual Sampling Plan and SWPP monitoring requirements should be reconciled, and MCA should conduct sampling accordingly.

2.3.6 Cyanobacteria

A monitoring and protection program against the risk of cyanobacteria is not required as the entire water supply consists of non-GUDI sources.

2.4 Filter Backwash Water

The Bridgetown system does not operate any filtration units; therefore, no filter backwash water is produced at any point.

2.5 Source Quantity

Water withdrawal permits are issued by NSECC in order to document the allowable withdrawals from a water source. The Water Withdrawal Approval Number is 2009-068808-05 with an expiry date of March 15, 2030. The document is attached in Appendix H. The Approval authorizes the following withdrawal rates:

- Average rate of withdrawal: 1,000,000 litres per day (L/day) (averaged over 30 days).
- Maximum rate of withdrawal: 1,300,000 L/day (averaged over 3 days).
- > 30-day withdrawal volume: 30,000,000 litres.
- Annual withdrawal volume: 365,000,000 litres.

	PW2	PW3	PW4
Average Pumping Rate (Averaged over 30 days) (L/day)	573,235	583,708	654,637
Maximum Pumping Rate (Averaged over 3 days) (L/day)	716,531	728,760	981,956
30-day withdrawal volume (L)	17,197,050	17,511,240	19,639,110
Annual withdrawal volume (L)	209,520,775	213,343,420	238,942,505

Table 2.5: Approved Withdrawal Rates for Bridgetown's Production Wells

The average daily rate of withdrawal of the system in 2022 was 623,000 L/day, with a maximum rate of withdrawal of 1,147,000 L/day occurring in September. In 2022, the system used 62% of it's allotted average yearly withdrawal rate, and 88% of the maximum rate of withdrawal. The 2022 raw water flow data is summarised in Table 2.6 below. It should be noted that the maximum withdrawal values for December were deemed inaccurate and were omitted. Flow meters for well 2 were inactive due to maintenance in December of 2022.

Month	Monthly Maximum Daily Rate (m³/day)	Monthly Average Daily Rate (m³/day)	Monthly Withdrawal Volume (m³)	Annual Withdrawal Volume (m³)
January	590	590	18,304	
February	575	575	16,103	
March	561	544	16,859	
April	1027	601	18,023	
May	839	585	18,124	
June	841	705	21,138	
July	730	647	20,059	
August	750	550	17,053	
September	1147	609	18,271	
October	799	566	17,544	
November	845	757	22,696	
December		754	23,371	
				168,616

Table 2.6: Bridgetown Water Supply Combined Monthly Withdrawal 2022

Individual well flow data can be found in Tables A.6 a. and A.6 b (Appendix A). Individual well and combined flows never exceeded the authorized withdrawal limits as per their Water Withdrawal Approval . As a result, all three wells were in compliance in 2022.

2.5.1 Demand Growth

In 2021, the Canadian Census listed the population of Bridgetown as 1,000, a 2.2% decrease from the population in 2016. Given the current population trends and production rate of the system, demand growth is expected to be met by the current drinking water system for the foreseeable future.

2.6 Source Water Protection Plan

Bridgetown is supplied from non-GUDI wells located within the municipal boundaries of Bridgetown. The SWPP was developed in 2018. A hydrogeological study was conducted to determine the three wellhead protection zones, based on the time-of-travel to the wellheads, which could be used to place restrictions on land-use and various activities that could negatively impact the safety of the source water. Moving away from the wellheads to the wellfield, restriction in the zones become more stringent as contamination events are more likely to pose a potential threat to the security of the water supply.

Groundwater flow patterns served as a tool to delineate the Source Water Protection Area (SWPA). When travel times of 2 years, 5 years, and 25 years were entered into the model, a roughly circular zone (or capture zone) corresponding to each travel time was produced:

- 2-year capture zone (Zone 1).
- 5-year capture zone (Zone 2).



25-year capture zone (Zone 3).

Based on the SWPP, the outer boundary of the SWPA for Wells 2 and 3 is the 25-year zone which intersects with the farmlands to the north, an orchard and several residential properties to the west, residential lots and a senior citizens' home to the south. Well 4 is situated on the floor of Annapolis Valley, extending north from the Annapolis River to the foot of the North Mountain. Adjacent land uses are primarily agricultural or wooded and include several rural residential lots. The northwest corner of the property is bordered by a former Nova Scotia Transportation and Infrastructure Renewal (NSTIR) depot, used to store and service maintenance vehicles. Groundwater flow in the Valley is dominated by the regional topography, directing drainage down the Valley slopes and into the Valley plain where groundwater discharges to the Annapolis River or flows to the southwest as regional flow. Appendix B identifies the boundaries of the source water protection area and delineates the three travel time zones around the production wells. The Water Protection Zone Mapping in GIS format is referenced in Appendix J and is to be provided separately as a deliverable along with the SAR.

The main objective of the SWPP is to help ensure the continued safety of the drinking water supply for Bridgetown. Following the delineation of the protected water area, the Source Water Protection Advisory Committee (SWPAC) identified potential contaminants and completed a risk ranking for the various point and non-point sources for each zone. The main risks that have been established within the protection area boundary are:

- Chemical/ temporary fuel storage.
- Abandoned wells.
- Roadway/potential spills.
- Fuel oil tank storage/heating oil tanks
- Fire suppressants.
- Herbicides/pesticides.
- Illegal dumping.

After the risk ranking was completed, a management plan was established to reduce the risk of a contamination event in the groundwater supply. Management strategies were developed for each potential risk. The management strategies adopted in the SWPP are as follows:

- Acquisition of land.
- Best management practices.
- By-laws.
- Contingency Planning.
- Designation as a SWPA.
- Education and stewardship initiatives.

A monitoring program has been established to regularly monitor for contaminants and identify changes in source water quality. Sampling for parameters identified in the SWPP is to be carried out on raw water at monitoring wells as part of MCAs overall monitoring plan.



An active SWPAC has not been held for an extended period. As such, the meeting minutes from the previous two SWPAC meetings are not attached as an appendix. The date of the next SWPAC meeting has not been scheduled.

As part of the *Approval to Operate*, MCA must review and update the SWPP on an annual basis.

2.7 Conclusion & Recommendations

The objective of this section was to provide a detailed characterization of the source water through a review of available information. Specifically, the focus was on assessing the approach and ability to protect against pathogenic organisms, effectiveness of DBP monitoring, lead and corrosion control/monitoring, assessment of *GCDWQ* and *GMPDWS* parameters, source quantity, and SWPP.

2.7.1 Treatment Requirements to Protect Against Pathogenic Organisms

Raw water is drawn from non-GUDI wells. As per the *Nova Scotia Treatment Standards for Municipal Drinking Systems*, groundwater sources require 3.0-log reduction for protozoa and 4.0-log reduction for viruses.

Using natural filtration and disinfection with sodium hypochlorite, the system meets the treatment requirements to protect against *Giardia*, *Cryptosporidium*, and viruses.

2.7.2 GUDI Classification

All production wells are classified as non-GUDI wells. The site visit confirmed there were no obvious changes in the area surrounding the wells that would warrant re-classification of the wells.

2.7.3 Disinfection By-Products

MCA monitors THMs and HAAs quarterly at three different locations throughout the distribution system. THM and HAAs levels observed in the distribution system comply with the respective LRAA maximum of 100 μ g/L and 80 μ g/L, respectively.

MCA could request a reduction in sampling frequency from quarterly to annually and the number of sample locations as all 2022 sample results were less than 0.01 mg/L.

2.7.4 Lead & Corrosion Control

MCA does not adequately monitor lead concentrations in the distribution system. As per the *Approval to Operate*, ten sampling locations are required. In 2022 MCA sampled seven locations, where one sampling location was in exceedance for MAC levels of lead.



Clarification from NSECC on lead and copper sampling requirements should be requested and an updated Approval to Operate with current sampling requirements should be provided.

The Annual Report did not include results for corrosion monitoring parameters at any sampling locations in the distribution system, which is not in compliance with the *Approval* to Operate. **MCA should begin sampling in accordance with its Annual Sampling Plan and Approval to Operate for corrosion control parameters.**

Currently no comprehensive document outlining the Corrosion Control Plan has been developed. This should include a sampling plan, action limits for corrosion monitoring parameters, and description of follow-up actions. If water is deemed noncorrosive from sampling results, a request to NSECC for a reduction in sampling frequency can be made.

2.7.5 Guidelines for Canadian Drinking Water Quality

Raw water samples were collected at one wellhead (PW2), and treated water samples were collected from the Town Hall. Samples were in compliance with NSECC requirements for the health-related parameters of the *GCDWQ* as shown in the 2018 sampling results, though the locations were not in compliance. MCA is required to take samples from each individual wellhead as well as treated water. Results for the remaining wellheads (PW3, PW4) were not provided and were therefore unable to be analyzed to determine if all parameters were within acceptable limits.

The next round of sampling is set to take place in the summer of 2023. Once these results have been received, the results should be compared to the previous testing to determine if any noticeable trends are identified between the past round of sampling.

MCA must begin *GCDWQ* compliance sampling for raw water from each individual well head in the next round of sampling (2023). Raw and treated water sampling is required as per the *Approval to Operate*.

2.7.6 Guidelines for Monitoring Public Drinking Water Supplies

As per the *Approval to Operate*, the *GMPDWS* samples are collected and tested every two years at AGAT Laboratories. The last round of sampling for raw and treated water from August 2021 are provided in Appendix F. There were no distinguishable water quality trends; however, not all individual wells were sampled in 2021 to compare directly to the 2019 sample results. Operations staff have reported anecdotally that uranium concentrations have generally been increasing at each of PW1 (before being taken offline), PW2, and PW3.



As per the last round of sampling completed in August 2021, MCA is not in compliance with the NSECC sampling requirements of the *GMPDWS* based on the number of samples taken. Raw water quality from each individual wellhead, as well as treated water samples, should be collected during the next round of compliance testing, which is scheduled to occur in summer 2023.

In 2019, Health Canada added a health-based maximum for total manganese of 120 µg/L. NSECC updated the *GMPDWS* to reflect this change and requires monitoring of total manganese in raw, treated, and distribution system samples. As per the Municipality's *Approval to Operate*, manganese is to be sampled twice per year, during the spring and fall. Samples were taken in July 2022 and were below the health-based maximum.

Manganese testing for raw water samples should be taken twice per year in the spring and fall to comply, and distribution system samples should be taken quarterly with the Approval to Operate.

2.7.7 Source Water Protection Plan Monitoring

The current SWPP includes a monitoring program. The sampling protocols for the wells provides sufficient data and information needed to constantly evaluate the effectiveness of the SWPP. The monitoring plan provides MCA with a strong warning system for potential contamination or changes in source water quality.

Currently this monitoring program is not fully implemented; the Annual Sampling Plan and SWPP monitoring requirements should be reconciled, and MCA should conduct sampling accordingly.

2.7.8 Filter Backwash Water Discharge

The Bridgetown system does not operate any filtration units, therefore, there is no filter backwash water to discharge.

2.7.9 Source Quantity

The average daily rate of withdrawal in the year 2022 was 623,000 L/day, with a maximum rate of withdrawal of 1,147,000 L/day occurring in September. In 2022, the system used 62% of its allotted average yearly withdrawal rate, and 88% of the maximum rate of withdrawal. Raw water flow data from 2022 is provided in Table A.6 (Appendix A). A copy of the Water Withdrawal Approval is provided in Appendix H.

Individual well flow data can be found in Tables A.6 a and A.6 b (Appendix A). Individual well flows never exceeded authorized withdrawal limits as per their Water Withdrawal Approval showing that all three wells were in compliance in 2022.



2.7.10 Source Water Protection Plan

Appendix B identifies the boundaries of the PWA. The Water Protection Zone Mapping in GIS Format is to be attached as a separate file. A SWPAC meeting has not occurred for an extended period of time.

As part of the *Approval to Operate*, the Community must review and update the SWPP on an annual basis.

3 Treatment Processes, Facilities, & Equipment

3.1 Treatment Process

The *Approval to Operate* classifies the system as a Class I Water Distribution Facility. The *Approval to Operate* is attached in Appendix G, and the details are as follows:

- Approval Holder: Municipality of the County of Annapolis.
- Approval No: 2010-073601-04.
- Expiry Date: June 1, 2029.

3.1.1 Treatment Process Schematic

The Bridgetown water system is a groundwater chlorination system consisting of the following units:

- Non-GUDI wells.
- Chlorination.

A schematic of the treatment process is presented in Figure 3.1 and in Appendix I.







Note that PW1 is greyed out to indicate that the well is currently not in use, but it still exists and the process equipment is still there.

3.1.1.1 Chlorination

Raw water is dosed with sodium hypochlorite at each well control building. The disinfection equipment in each well control building consists of duplex (redundant) peristaltic metering pumps and is complete with continuous chlorine residual measurement in water leaving each site.

The pumps operate in duty/standby such that if the duty pump is not able to operate the standby pump would turn on. Each pump is adequately sized to provide the design dose of sodium hypochlorite for each wellfield. An alarm has been set in SCADA that alerts staff when the chlorine residual is lower than the minimum set limit when entering the system. For locations leaving the storage tank, the action limit is set to 0.5 mg/L. Operations personnel maintain a daily log and verify the chlorine residual by grab sample.

Secondary disinfection is considered to be the maintenance of a free chlorine residual throughout the distribution system. Water leaving the reservoir and entering the distribution system is continuously monitored for chlorine residual and trended via SCADA. The chlorine dosage is reported to be relatively constant and the secondary residual leaving the reservoir is consistently above 0.6 mg/L.

3.1.2 Turbidity Levels & Associated Criteria

3.1.2.1 Surface Water

This section is not applicable for this system.

3.1.2.2 GUDI Wells

This section is not applicable for this system.

3.1.2.3 Non-GUDI Wells

Section 2.3 of the *Nova Scotia Treatment Standards for Municipal Drinking Water Systems* outlines the prescribed turbidity levels for non-GUDI systems. The requirements for combined flow turbidity or individual well turbidity limits for non-GUDI systems, such as the Bridgetown water system, are as follows:

- Shall be less than or equal to 1.0 NTU in at least 95% of the measurements taken by grab sample for each calendar month; or
- Shall be less than or equal to 1.0 NTU at least 95% of the time each calendar month if continuous monitoring is the method of turbidity measurement.



Verification of the ability for the Bridgetown water system to continuously achieve the 3.0-log removal credits was evaluated using Option 2 as outlined in the NSECC *Terms of Reference for Municipal Drinking Water Systems*. The system utilizes SCADA to provide combined raw water turbidity data for the four source wells. The turbidity from each individual well in use in 2022 was obtained from SCADA and is presented below in Figures 3.2, 3.3 and 3.4.



Figure 3.2: Well 2 Annual Turbidity Readings



Figure 3.3: Well 3 Annual Turbidity Readings



Figure 3.4: Well 4 Annual Turbidity Readings

Operators confirmed all exceedances observed were due to maintenance of the online turbidity analyzer and controller. The turbidity meter for PW4 was undergoing maintenance during June 2022. These readings were not indicative of turbidity levels of water being discharged to the distribution system. Operators indicated that daily grab samples were taken in lieu of the meters not communicating properly for PW 2 and 3. It should be noted that the turbidity levels from the grab samples did not match the SCADA turbidity levels for each well during the same time period. Daily grab samples for PW 2 and 3 are summarized in Figure 3.5, which confirm the raw water was able to meet the stipulated turbidity requirements. Based on the SCADA graphs and supplemental grab samples, the raw water met stipulated turbidity requirements for all months.



Figure 3.5: Supplemental turbidity grab samples for wells 2 and 3

Raw water is continuously monitored at each individual well using online turbidity monitors. The high alarm set point is established at 1.0 NTU and sends out an alarm to the operator to investigate, therefore, the system meets the requirements to receive the removal credits as per the *Nova Scotia Treatment Standards for Municipal Drinking Water Systems*.

3.1.2.4 Inspection of Turbidity Meters

Continuous monitoring of well turbidity is conducted using HACH 1720E low range process turbidimeters at the PW1/2/3 wellsite and HACH TU5300 series turbidimeter at the PW4 building. These meters meet and exceed the *USEPA Method 180.1* rules for measuring turbidity for drinking water compliance. The analysis method is based upon comparison of the light scattering by the sample under defined conditions with the intensity of light scattered by a standard reference suspension. These units are capable of measuring turbidity levels with an accuracy of $\pm 2\%$ of the reading or ± 0.02 NTU (whichever is greater) from 0 to 40 NTU.

MCAs Operations and Maintenance Manual does not include a detailed quality assurance and calibration program. Turbidimeters are inspected on a weekly basis by operators and calibrated as needed. The system currently does not have continuous turbidity monitoring for water entering the distribution system (leaving the reservoir).

MCA should update the Quality Assurance/Quality Control (QA/QC) Standard Operating Procedure (SOP) to better reflect the operation, maintenance, and



calibration of the online monitoring equipment. The updated SOP should include sections on equipment start-up, calibration, maintenance, and troubleshooting.

3.1.3 Membrane Filtration

This section is not applicable for this system.

3.1.4 Primary Disinfection

Under the *Nova Scotia Treatment Standards for Municipal Drinking Water Systems,* treatment processes using non-GUDI groundwater as their source water are required to have the ability to achieve a:

- ▶ 3.0-log reduction for *Giardia* and *Cryptosporidium*.
- 4.0-log reduction for viruses.

The system is able to receive a 3.0-log removal credit for protozoa removal (*Cryptosporidium* oocysts and *Giardia* cysts), based on natural filtration log removal credits assigned to non-GUDI water supplies as described in the *Nova Scotia Treatment Standards for Municipal Drinking Water Systems*. For that reason, the system is required to provide a 4.0-log inactivation of viruses using disinfection. Sodium hypochlorite is used to achieve primary chemical disinfection from the CT control point at the outlet of the storage reservoir. A schematic of the primary disinfection system is provided in Appendix I.

3.1.4.1 Chemical Disinfection (CT Concept)

CT calculations are based on various operational, treatment, and system design parameters. Operational parameters including maximum flowrate, chlorine residual, and contact volume will affect the time that primary disinfection occurs as well as efficiency of disinfection. Furthermore, environmental conditions such as pH and temperature affect the efficiency of disinfection and are included in CT calculations. Calculations reflect the worst-case scenario to ensure that the system will always have adequate disinfection.

Primary disinfection occurs between the chlorination points (at each well building) and the outlet of the reservoir. The system disinfects water in the chlorination building at both wellfields. To be conservative, the calculation of CT for compliance is based only on the 850 m of 200 mm transmission main from both well control buildings (the combined chlorinated water transmission main) to the storage tank. Further disinfection occurs in the storage tank, which operators reported to be 75% full during peak hours. Plug flow conditions can be assumed in the pipe and so a baffling factor of 1.0 is assigned. All the design parameters are listed in Table 3.1 and Table 3.2.



Table 3.1: CT Design Parameters

CT Design Parameters	Values	
Maximum Flow (m ³ /day)	1,147	
Maximum pH	8.0	
Minimum Temperature (°C)	0.5°C	
Minimum Free Chlorine Residual (mg/L)	0.5 mg/L	

Table 3.2: Distribution Main Design Parameters for CT Calculations

Distribution Main Design Parameters	Values
Length (m)	850 m
Diameter (mm)	200 mm
Baffling Factor	1.0

Water Main Cross Sectional Area
$$(m^2) = \pi r^2 = \pi \left(\frac{0.1m}{2}\right)^2 = 0.0314 m^2$$

Water Main Volume $(m^3) = L * A = (850 m) * (0.0314 m^2) = 26.7 m^3$

Contact time (min) = $\frac{Volume (m^3)}{Max Flow (\frac{m^3}{min})} = \frac{26.7 m^3}{0.8 \frac{m^3}{min}} = 33.3 min$

 $CT_{actual} (mg * min/L) = Chlorine Residual \left(\frac{mg}{L}\right) * Contact Time (min) * Baffling Factor$

$$CT_{actual} (mg * min/L) = 0.5 \frac{mg}{L} * 33.3 min * 1.0 = 16.7 mg * min/L$$

 $CT_{req} = 12 mg * min/L$ (for 4.0-log Virus at Temp = 0.5 °C, pH = 8.0)

$$\frac{CT_{actual}}{CT_{reg}} = \frac{16.7 mg * min/L}{12 mg * min/L} = 1.4$$

The CT calculation above for the log inactivation of viruses confirms that the minimum CT required for the 4.0-log inactivation of viruses in drinking water from both the primary and backup sources is being met. This is the case as the ratios of CT_{actual}/CT_{required} are greater than one and confirms proper disinfection. In 2022, there were no instances where operational conditions for adequate CT were not met.

3.1.4.2 UV Disinfection (IT Concept)

This section is not applicable for this system.

3.1.4.3 Redundancy, Monitoring, & Alerting

Online monitoring of chlorine residual is accomplished using an online HACH CL17 colorimetric chlorine analyser at the outlet of the storage reservoir that continuously takes



primary disinfection residual readings and transmits this data to the SCADA system for monitoring and alarming as required. Control limits within the SCADA system are set to alarm and notify operators when the primary disinfection system is operating incorrectly. The SCADA system is set to alarm if chlorine residual falls below the level of 0.5 mg/L at any of the chlorine residual monitors in the system. There is also online chlorine residual monitoring at each well building, used to ensure the chlorination systems are functioning properly. A portable chlorine residual analyzer (HACH DR2000 Spectrophotometer) is used to confirm chlorine residual. This unit can measure free chlorine residual from a range of 0.1–2.0 mg/L (±0.2 mg/L).

3.1.4.4 Standard Operating Procedures

There is no formal SOP for the disinfection process. A general SOP describes how the CT concept of disinfection may be applied.

MCA should update the current disinfection SOP to formally outline operational setpoints, worst case scenario CT values, response procedures, and operation/maintenance of the disinfection equipment.

3.1.5 Secondary Disinfection

Secondary disinfection is achieved by maintaining a minimum free chlorine residual of 0.2 mg/L at all points within the distribution system. Grab samples are collected weekly at two points in the system. All samples collected in 2022 met the required chlorine residual, therefore, meeting the requirements of the *Approval to Operate*.

The requirement to maintain an adequate secondary disinfectant residual throughout the distribution system drives the dose applied at the primary chlorination point.

3.1.6 Other Critical Processes

There are no critical processes outside those described above.

3.1.7 Waste Streams

3.1.7.1 Filter-to-Waste

This section is not applicable for this system.

3.1.7.2 Filter Backwash Water - Discharging into a Freshwater Watercourse This section is not applicable for this system.

3.1.7.3 Filter Backwash Water - Discharge to Land or Soil

This section is not applicable for this system.



3.1.7.4 Filter Backwash Water – Discharge to a Marine or Brackish Environment

This section is not applicable for this system.

3.1.7.5 Other Waste Streams

This section is not applicable for this system.

3.2 Distribution Water Quality

Distribution system water quality samples are collected from the locations listed below. The Distribution Map is provided in Appendix C.

Site A	Water Storage Tank, Hampton Mountain Road.
Site B	Wards Farm, 8607 Highway #1, Bridgetown, NS.
Site C	Nob's Farm Market, 612 Granville Street East

3.2.1 Chlorine Residual Levels

Samples from the distribution system for residual chlorine levels are collected weekly at sites B and C as per the *Approval to Operate* conditions. In 2022, the chlorine residuals did not fall below 0.2 mg/L.

Residual chlorine monitoring for water entering the distribution system is measured at the outlet of the storage tank by an online free chlorine analyzer. Values are recorded on the SCADA software which initiates alarms if the levels drop below 0.5 mg/L. The existing system is in good condition.

3.2.2 Microbial Water Quality

Schedule A in the existing *Approval to Operate* requires the collection of grab samples on a weekly basis to monitor for total coliforms and *E. coli*. Samples are collected from sites B and C as identified on the Water Distribution Map located in Appendix C. These locations represent the center and the distal end of the system. This results in 8 samples per month, which is above the minimum number of samples required for a population of 1,000 residents. All test results showed absent for *E. coli* and total coliforms in 2022. The number of sampling sites

3.2.3 Turbidity

Schedule A in the *Approval to Operate* requires turbidity samples to be taken on a weekly basis to ensure values are less than 5.0 NTU. Samples were collected at Sites A, B, and C each week, and all turbidity samples collected in 2022 were within compliance.



3.2.4 Cross Connection Control Program

MCA has developed a Cross Connection Control Program. The Cross Connection Control Program requires all multi residential units (greater than four units), industrial, commercial, and institutional buildings to install a Backflow Prevention Device (BFD) on their water service lateral. The devices are installed to provide premises isolation at the entrance to the building for new sprinkler services, and on the customer's side of the water meter for domestic services.

Currently the plan does not meet the minimum requirements outlined in *A Guide to Assist Nova Scotia Municipal Water Works Develop a Cross Connection Control Program.* **MCA should update the cross-connection control program to include a detailed project scope, budget, authority, and timelines.**

3.2.5 Other Distribution System Monitoring Programs

MCA conducts the following distribution system monitoring:

- Annual flushing program with inspection of hydrants and system gate valves.
- Ongoing leak detection program in development, includes both flow monitoring and correlation and acoustic leak detection equipment.

There is currently no formal reservoir inspection program in place at the Bridgetown reservoir. It is recommended that a program be established to conduct interior inspection in the reservoir on a regular basis.

3.3 On-Site Inspection

An on-site inspection was conducted on June 7, 2023, by Ben Bickerton, M.A.Sc., P.Eng., and Meghan Lea, M.A.Sc., EIT. There were no obvious concerns identified at this time other than the items listed elsewhere in this report.

3.4 Conclusion & Recommendations

3.4.1 Turbidity Levels

Water is provided to the distribution system without passing through any filtration unit. Schedule A of the *Approval to Operate* requires that turbidity entering the distribution system shall be less than or equal to 1.0 NTU at least 95% of the time each calendar month for continuous monitoring.

MCA should ensure all online turbidity meters for each individual well are in good working order and calibrated correctly. MCA should also update the Quality Assurance/Quality Control (QA/QC) Standard Operating Procedure (SOP) to better



reflect the operation, maintenance, and calibration of the online monitoring equipment to mitigate events where turbidity meters are not accurate.

3.4.2 Primary Disinfection

The system uses sodium hypochlorite for primary disinfection. The disinfection equipment consists of a duplex sodium hypochlorite peristaltic metering pump system complete with continuous chlorine residual measurement at each well building. Calculations for CT confirm that primary disinfection achieves a 4.0-log reduction of viruses at the CT control point (water storage reservoir outlet) prior to reaching the first customer in the distribution system.

MCA should update the current disinfection SOP to formally outline operational setpoints, worst case scenario CT values, response procedures, and operation/maintenance of the disinfection equipment.

3.4.3 Secondary Disinfection

Secondary disinfection is achieved by maintaining a minimum free chlorine residual of 0.2 mg/L at all points within the distribution system. Grab samples were collected weekly at designated sample locations. Free chlorine residual was also continuously monitored leaving the reservoir.

3.4.4 Other Critical Processes

There are no other critical processes in the system.

3.4.5 Waste Streams

MCA operates a municipal drinking water system lacking any filtration processes. No significant waste streams are present.

3.4.6 Distribution Water Quality

3.4.6.1 Chlorine Residual Levels

To satisfy the *Approval to Operate* requirements, operators utilize a handheld colorimeter to grab free chlorine samples from two sample locations in the distribution system. Data from all sample sites in 2022 showed levels greater than 0.2 mg/L and met regulatory requirements.

3.4.6.2 Microbial Water Quality

All *E. coli* and total coliform test results in 2022 showed absent for total coliforms and *E. coli*. As a result, the distribution system microbial water quality is within compliance.


3.4.6.3 Turbidity

The distribution system was monitored for turbidity on a weekly basis at three sampling locations. Turbidity samples collected in 2022 were within compliance and below 5.0 NTU.

3.4.6.4 Cross Connection Control Program

The Municipality has developed a Cross Connection Control Program to partially comply with NSECC requirements. The Cross Connection Control Program requires all multi residential units (greater than four units), industrial, commercial, and institutional buildings to install a backflow prevention device on their water service.

Currently the plan does not meet the minimum requirements outlined in *A Guide to Assist Nova Scotia Municipal Water Works Develop a Cross Connection Control Program.* **MCA should update the cross-connection control program to include a detailed project scope, budget, authority, and timelines.**

3.4.6.5 Other Distribution System Monitoring Programs

MCA conducts the following distribution system monitoring:

- Annual flushing program with inspection of hydrants and system gate valves.
- Ongoing leak detection program in development, includes both flow monitoring and correlation and acoustic leak detection equipment.

There is currently no formal reservoir inspection program in place at the Bridgetown reservoir. It is recommended that a program be established to conduct interior inspection in the reservoir on a regular basis.

3.4.7 On-site Inspection

An on-site inspection was conducted on June 7, 2023, and there were no obvious concerns identified at this time.

4 Operations, Monitoring, & Management

4.1 Operations & Maintenance

As required by the *Approval to Operate*, MCA has an Operations and Maintenance Manual which outlines the characteristics of the system and includes emergency actions and limited SOPs for normal operations. Copies of the Operations and Maintenance Manual are available digitally, and operations staff have access to these documents and are aware of their contents. This manual was last updated in 2010.

Sections of the Operations and Maintenance Performance Standards Manual includes the following:

- Chapter 1: Introduction.
- Chapter 2: Contact Information.
- Chapter 3: Water System Overview.
- Chapter 4: Standard Operating Procedures.
- Chapter 5: Contingency Plans.
- Appendix A: Approval to Operate.
- Appendix B: Approval to Withdraw.

The Contingency Plan in chapter 5 outlines the plans and steps to follow in case of an emergency and/or failure. The Contingency Plan includes power failure, failure of SCADA, chemical spill/release, high filter turbidity, disinfection, failure of disinfectant equipment, fire, failure of coagulation, and raw water contamination.

All certified operators make process adjustments such as chemical dosing changes, perform equipment and instrument maintenance as required based on experience, and continuous evaluation of the system performance. The Operator in Direct Responsible Charge (ODRC) is ultimately responsible for changes, and significant changes beyond routine adjustments are discussed with the ODRC prior to implementing the change. The Operations and Maintenance Manual lacks detailed SOPs for the operations staff to follow. The maintenance plan was reviewed and is not adequate to ensure the long-term viability of the Municipal Public Drinking Water Supply, including distribution system components.



MCA should update the Operation and Maintenance Manual to include detailed SOPs in accordance with the NSECC document *A Guide to Assist Nova Scotia Municipal Water Works Develop a Comprehensive Operations Manual*.

4.2 Monitoring & Reporting

The approved monitoring program was submitted to NSECC in 2022. The program includes quality assurance programs and training, water quality compliance limits, sampling sites, and monitoring plans. Compliance monitoring is required to ensure that the water adheres to the quality standards outlined in the *GCDWQ* and *GMPDWS*. A summary of the raw, treated, and SWPP sampling programs are provided in Table 4.1, Table 4.2, and Table 4.3, respectively.

Summary of Raw Water Requirements					
	Approval to OperateParameterSampling RequirementsLocationFrequency		Bridgetown Sampling Program		
Parameter					
			Frequency		
Turbidity	Every Individual Well	Continuous	Continuous		
Water Volume	Every Individual Well	Continuous	Continuous		
All GMPDWS	Every Individual Well	Every two years	Every two years		
All GCDWQ	Raw Water	Every 5 years	Every 5 years		
Viruses	Raw Water	As requested	As requested		
Manganese	Raw Water	Semi Annually	Semi Annually		

Table 4.1: Raw Water Sampling Program

Table 4.2: Distribution Water Sampling Program

Summary of Treated Water and Distribution Monitoring Requirements					
Parameter	Approval t Sampling Re	o Operate quirements	Bridgetown System Sampling Program		
	Location	Frequency	Frequency		
Turbidity	Distribution System Sample Points	Weekly Grab	Weekly Grab		
Free Chlorine	Entering Distribution System	Continuous	Continuous		
	Storage Tank Outlet	Continuous	Continuous		
	Distribution System Sample Points	Weekly Grab	Weekly Grab		
All GMPDWS	Treated Water	Every 2 years	Every 2 years		
All GCDWQ	Treated Water	Every 5 years	Every 5 years		
Temperature	CT Control Point	Daily Grab or Continuous	Continuous		
рН	CT Control Point	Continuous	Continuous		
Viruses	Distribution System	As Requested	As Requested		



Summary of Treated Water and Distribution Monitoring Requirements					
Parameter	Approval t Sampling Re	o Operate quirements Program			
	Location	Frequency	Frequency		
Parameters per Corrosion Monitoring Program	Select Distribution Points	Quarterly Grab	No current plan		
Lead (Flushed)	Select Distribution Points	Annual	Annual between May to October, distribution sampling points		
Lead (Stagnant)	Select Distribution Points	Annual grab (between May to October)	Annual in August, distribution sampling points		
THMs	Select Distribution Points	Quarterly	Annual		
HAAs	Select Distribution Points	Quarterly	Annual		
Manganese	Storage tank, distribution sampling points	Quarterly Grab	Quarterly Grab		

Table 4.3: Source Water Protection Plan Sampling Program

Devementer	Locations				
Parameter	PW2	PW3	PW4		
Total Coliform and E. coli	Weekly	Weekly	Weekly		
Turbidity	Weekly	Weekly	Weekly		
рН	Daily grab or continuous	Daily grab or continuous	Daily grab or continuous		
Uranium, Pesticides, Herbicides	Yearly	Yearly	Yearly		
Total THMs	Quarterly	Quarterly	Quarterly		
HAAs	Quarterly	Quarterly	Quarterly		
Chlorine residual	Weekly or continuous	Weekly or continuous	Weekly or continuous		
Fluoride	Every two years	Every two years	Every two years		
Arsenic, Antimony, Lead	Every two years	Every two years	Every two years		
Volatile Organic Compounds	Every five years	Every five years	Every five years		

All samples collected for the various monitoring programs are sent to AGAT Laboratories in Dartmouth, NS for analysis. AGAT Laboratories is an accredited laboratory as per the *Policy on Acceptable Certification of Laboratories*.



4.2.1 Review of Recent Submitted Annual Report

The 2022 Annual Report was reviewed. Not all sections were completed; most notably, distribution system corrosion control parameters, manganese and lead/copper sampling results were not included. **MCA should ensure that each section of the Annual Report** where applicable to the Bridgetown system is completed in its entirety each year. The document can be modified from the basic template provided by NSECC.

4.3 Management

The system has been classified as a Class I Water Distribution Facility. John Webber, Level II Water Distribution (WD) Operator is the ODRC of the Water Distribution Utility. A summary of staffing information is provided below:

- John Webber (ODRC) Level II WD.
- James Jenner Level I WD
- Charles Grant (DRC Operator) Level I WD
- Amy Brown Level I WD.
- Tim Durling Level I WD.

The ODRC protocol information is provided in Appendix A.

4.4 Conclusion & Recommendations

4.4.1 Operation & Maintenance

MCA has a limited Operations and Maintenance Manual. It is recommended that a comprehensive manual be created that elaborates on protocols and procedures.

MCA should seek to update the Operations and Maintenance Manual to include detailed SOPs for daily operations of the plant.

4.4.2 Monitoring & Reporting

Results from all sampling listed in the approved Annual Sampling Plan was not available for review. The 2022 Annual Report did not include reporting on all parameters (e.g. corrosion control parameters).

MCA should ensure that each section of the Annual Report where applicable to the Bridgetown system is completed in its entirety each year. The document can be modified from the basic template provided by NSECC.



4.4.3 Management

The system has been classified as a Class I Water Distribution Facility. The ODRC is John Webber. All operators are adequately certified and there are a sufficient number of operators as well as back-up personnel available. The procedure for when the ODRC is absent is outlined in Appendix A.

5 Ability to Comply

This section will provide a summary of conclusions as referenced from the NSECC Terms of Reference.

5.1 Summary

5.1.1 Treatment Processes, Facilities, & Equipment

5.1.1.1 Treatment Process

Water is supplied from non-GUDI wells and undergoes chlorine disinfection prior to entering the distribution system. The *Approval to Operate* is valid until June 1, 2029.

5.1.1.2 Turbidity Levels & Associated Criteria

Raw water supplied from the non-GUDI wells must be less than 1.0 NTU 95% of the time in each calendar month based on continuous monitoring. SCADA graphs and grab samples indicate that the source wells did meet this turbidity limit for all months in 2022.

5.1.1.3 Primary Disinfection

All municipal drinking water systems in Nova Scotia are required to meet treatment standards to achieve:

- ▶ 3.0-log removal for *Giardia* and *Cryptosporidium*.
- 4.0-log removal credits for viruses.

The Bridgetown system is a groundwater chlorination process consisting of natural filtration and disinfection. Combined raw water turbidity was reviewed and meets the limits of 1.0 NTU 95% of the time. As such, the facility received a natural filtration 3.0-log reduction credit for *Giardia* and *Cryptosporidium*.

The remaining removal credits were achieved with chlorine disinfection. The CT for chlorine disinfection is adequate to achieve a 4.0-log inactivation of viruses, therefore, the combination of natural filtration and inactivation can remove and inactivate protozoa (*Giardia* and *Cryptosporidium*) and viruses to NSECC's treatment standards.



5.1.1.4 Secondary Disinfection

Secondary disinfection is achieved by maintaining a free chlorine residual of 0.2 mg/L. Weekly grab samples within the distribution system are used to ensure that the minimum chlorine residual is met.

5.1.1.5 Other Critical Processes

This section is not applicable for this system.

5.1.1.6 Process Waste Streams

This section is not applicable for this system.

5.1.2 Distribution System Water Quality

5.1.2.1 Chlorine Residuals

Chlorine residuals in the distribution system are acceptable and met a minimum concentration of 0.2 mg/L. Weekly grab samples were taken and analyzed at two locations throughout the distribution system. Chlorine residual levels were also continuously monitored leaving the storage reservoir.

5.1.2.2 Microbial Water Quality

Microbiological samples for *E. coli* and total coliforms were collected at two locations weekly. In 2022, all results for each location tested absent for both *E. coli* and total coliforms. As a result, the distribution system microbial water quality is within compliance.

5.1.2.3 Turbidity

Grab samples were collected on a weekly basis from the three distribution sampling locations. All samples tested were below the maximum turbidity of 5.0 NTU and within regulatory compliance.

5.1.2.4 Cross Connection Control Programs

MCA has implemented an approved Cross Connection Control Program which partially comply with NSECC requirements. **MCA should update the cross-connection control program to include a detailed project scope, budget, authority, and timelines.**

5.1.2.5 Other Distribution System Monitoring Programs

No other distribution system monitoring programs are in place for the system.



5.1.3 Operations, Monitoring, & Management

5.1.3.1 Operations & Maintenance

MCA has an Operations and Maintenance Manual. It is recommended that the manual be updated to better outline the characteristics of the system and include emergency actions and SOPs for normal facility operation.

5.1.3.2 Monitoring & Reporting

The 2022-2023 monitoring program and 2022 Annual Report appear to address all requirements, with minor exceptions including lead/copper, manganese, and corrosion control sampling results.

All chemical analyses are carried out at the AGAT Laboratories in Dartmouth. AGAT Laboratories is an accredited laboratory as per the *Policy on Acceptable Certification of Laboratories*.

5.1.3.3 Management

The system has been classified a Class I Water Distribution Facility. John Webber Level II WD Operator is the ODRC of the Water Distribution Facility.

5.1.4 Recommendations

Table 5.1: Recommendations for Bridgetown Water Utility

Category	Problem/ Challenge Area	Recommended Action	Time Frame to Complete	Opinion of Cost
Water Quality	Corrosion Control Monitoring	Formalize a comprehensive Corrosion Control Plan with action limits/responses that align with the current <i>Approval to Operate</i> , aiming to reduce lead and copper, to correspond to existing sampling plan.	6 months	No cost if done in-house
Water Quality	SWPP Monitoring Parameter testing	Begin sampling for parameters outlined in the SWPP following the appropriate schedule.	Annually	\$1,000/year
Water Quality	DBP Monitoring	Propose reduced monitoring of THMs and HAAs based on low historical readings.	1 year	Sampling cost savings
SWPP	Annual SWPP meeting	Recommence bi-annual SWPAC meeting to review and update the SWPAC.	1 year	\$0
Management	O&M Manual and SOPs limited	Update the Operations and Maintenance manual with SOPs for normal operation and emergency actions in accordance with the NSECC guidance manual.	1 year	No cost if done in-house
Metering	Turbidity Meters	Ensure all turbidity meters are properly cleaned and calibrated to mitigate events where readings may be inaccurate.	3 months	\$1,000
Treatment	Disinfection SOP	Add notification and response procedures for inadequate CT to SOP.	6 months	Complete – In house



Category	Problem/ Challenge Area	Recommended Action	Time Frame to Complete	Opinion of Cost
Sampling	Lead Exceedance	3 additional residential sampling locations should be added for lead/copper sampling. Locations where lead concentrations exceeded the MAC should be retested using a 6-hour stagnation test as per the <i>Approval to Operate</i> .	3 months	\$500
Sampling	GCDWQ/GMPDWS Sampling	Ensure samples are taken at each induvial wellhead as well as treated water.	Next round of compliance testing	\$5,000
Sampling	Manganese Testing	Manganese testing for raw water samples should be taken twice per year in the spring and fall to comply, and distribution system samples should be taken quarterly with the Approval to Operate.	3 months	\$200/year
Management	Limited Cross Connection Control Plan	Update Cross Connection Control Plan to comply with minimum requirements set by NSECC.	3 months	No cost if done in-house



5.2 Report Preparation

I, the undersigned, hereby declare that to the best of my knowledge, the information contained herein and the information in support of this submission, as completed by me, is complete and accurate in accordance with my obligations under the Engineering Profession Act and its regulations. I further declare that this submission has been prepared in accordance with the published standard for this submission.

Ben Bickerton, M.A.Sc., P.Eng. Process Engineer



APPENDIX A

Tables Required by the Terms of References



Table A.1: Groundwater Under the Direct Influence of Surface Water: Microscopic Particulate Analysis (MPA) Test Results *Section not applicable.*

Table A.2: Annual Trihalomethanes Concentrations (THMs) by Sample Location	es Concentrations (THMs) by Sample Location
--	---

Sampling Period/Month		Site A	Site B
		THM total (μg/L)	THM total (µg/L)
	January	-	-
Q1	February	<0.001	0.003
	March	-	-
	April	-	-
Q2	May	<0.001	0.005
	June	-	-
	July	<0.001	0.002
Q3	August	-	-
	September	-	-
	October	<0.001	0.004
Q4	November	-	-
	December	-	-
LRAA (µg/L)		0.001	<0.001
Meets MAC of 0.1 mg/L (100 µg/L)		Yes	Yes

Table A.3: Annual Haloacetic Acid Concentrations (HAA5) by Sample Location

Sampling Period/Month		Site A	Site B	
		HAA (5) μg/L	HAA (5) μg/L	
	January	-	-	
Q1	February	<0.004	<0.004	
	March	-	-	
	April	-	-	
Q2	May	<0.004	<0.004	
	June	-	-	
	July	<0.004	<0.004	
Q3	August	-	-	
	September	HAA (5) µg/L - - - - - - - - - - - - -	-	
	October	<0.004	<0.004	
Q4	November	-	-	
	December	-	-	
LRAA (µg/L)		<0.001	0.004	
Meets MAC of 0.08 mg/L (80) μg/L)	Yes	Yes	

Site C
Site C
THM total (μg/L)
-
0.005
-
-
0.006
-
0.007
-
-
0.008
-
-
0.003
Yes

Site C
HAA (5) μg/L
-
<0.004
-
-
<0.004
-
<0.004
-
-
<0.004
-
-
<0.004
Yes

Table A.4: Health-Related Parameters in the Guidelines for Canadian Drinking Water Quality

		PW2	PW3	PW4	Treated Water
Parameter	MAC	Sampling Date:			Sampling Date:
	(mg/L)	June 18 th , 2018			June 18 th , 2018
		μg/L			
Bacteria					
Total Coliforms	None per 100 mL	-	-	-	-
E. coli	None per 100 mL	-	-	-	-
Aluminum	2.9	<10	-	-	<10
Antimony	0.006	<2	-	-	<2
Arsenic	0.01	4	-	-	4
Atrazine	0.005	-	-	-	-
Barium	2	271	-	-	341
Benzene	0.005	<1	-	-	<1
Benzo[<i>a</i>]pyrene	0.00004	<0.0001	-	-	<0.0001
Boron	5	13	-	-	14
Bromate	0.01	-	-	-	-
Bromoxynil	0.03	<0.5	-	-	<0.5
Cadmium	0.007	<0.3	-	-	<0.3
Carbon tetrachloride	0.002	<1	-	-	<1
Chlorate	1	<0.02	-	-	<0.02
Chlorite	1	<0.02	-	-	<0.02
Chlorpyrifos	0.09	<1	-	-	<1
Chromium	0.05	3	-	_	3
Copper	2	<1	-	-	11
Cvanide	0.2	<0.002	-	-	<0.002
Cyanobacterial toxins	0.0015	-	-	-	-
Dicamba	0.11	-	-	_	-
1.4-Dichlorobenzene	0.005	<1	-	-	<1
1.2-Dichloroethane	0.005	<1	-	-	<1
1.1-Dichloroethylene	0.014	<2	-	_	<2
Dichloromethane	0.05	-	-	_	-
2.4-Dichlorophenoxy acetic acid (2.4-D)	0.1	-	-	<u>-</u>	-
Dimethoate	0.02	<1.5	-	_	<1.5
1.4-Dioxane	0.05	-	-	_	-
Diquat	0.05	<1	-	_	<1
Ethylbenzene	0.14	<2	-	_	<2
Fluoride	1 5	_ <0.12	<u>-</u>	_	<0.12
Glyphosate	0.28	<15	_	_	<15
Haloacetic acids - Total (HAAs)	0.08		_	_	
Lead	0.005	<0.5	<u>.</u>		<0 5
Malathion	0.19	<1	<u>_</u>		<1
Manganese	0.15	<2		_	<7
Mercury	0.12	<0.026		_	<0.026
wereury	0.001	~0.020	-	-	<u>\0.020</u>

		PW2	PW3	PW4	Treated Water
Parameter	MAC (mg/L)	Sampling Date: June 18 th , 2018			Sampling Date: June 18 th , 2018
		μg/L			
2-Methyl-4-chlorophenoxyacetic acid (MCPA)	0.35	-	-	-	-
Metribuzin	0.08	<0.25	-	-	<0.25
Nitrate-Nitrogen	10	-	-	-	-
Nitrilotriacetic acid (NTA)	0.4	-	-	-	-
Nitrite-Nitrogen	1	-	-	-	-
N-Nitroso dimethylamine (NDMA)	0.00004	-	-	-	-
Pentachlorophenol	0.06	-	-	-	-
Perfluorooctane Sulfonate (PFOS)	0.0006	-	-	-	-
Perfluorooactanoic Acid (PFOA)	0.0002	-	-	-	-
Selenium	0.05	<2	-	-	<2
Strontium	7	-	-	-	-
Tetrachloroethylene	0.01	<1	-	-	<1
Toluene	0.06	<2	-	-	<2
Trichloroethylene	0.005	<1	-	-	<1
2,4,6-Trichlorophenol	0.005	<0.5	-	-	<0.5
Trihalomethanes (THM)	0.1		-	-	
Turbidity		0.6	-	-	1.2
Uranium	0.02	19.7	-	-	19.5
Vinyl chloride	0.002	<0.6	-	-	<0.6
Xylenes (total)	0.09	<4	-	-	<4

Table A.5: Guidelines for Monitoring Public Drinking Water Supplies

Devenue de v	Health Based Guideline	Aesthetic Guideline	Treated Water	
Parameter	(mg/L)	(mg/L)	(µg/L)	
Alkalinity	-	-	-	
Aluminium	2.9	0.1	-	
Ammonia	-	-	-	
Antimony	0.006	-	-	
Arsenic	0.01	-	-	
Barium	1	-	205	
Boron	5	-	9	
Cadmium	0.007	-	-	
Calcium	-		-	
Chloride	-	≤250	-	
Chromium	0.05	-	-	
Colour	-	≤ 15 TCU	-	
Conductivity	-	-	-	
Copper	2	≤1.0	-	
Fluoride	1.5	-	-	
Hardness	-	-	-	
Iron	-	≤0.3	-	
Lead	0.005		-	
Magnesium	-	-	-	
Manganese	0.12	≤0.02	-	
Nitrate-nitrogen	10	-	-	
рН	-	6.5-8.5	7.92	
Potassium	-	-	-	
Selenium	0.05	-	-	
Sodium	-	≤200	-	
Sulphate	-	≤500	-	
Total Dissolved Solids	-	≤500	-	
Total Organic Carbon	-	-	-	
Turbidity	-	-	-	
Uranium	0.02	-	6.8	
Zinc		≤5	<5	

Raw Water
Sample Date: August 17, 2021
(µg/L)
-
<5
-
<2
<2
202
9
<0.09
-
-
-
-
-
<1
-
-
<50
<0.5
-
<2
-
7.79
-
<1
-
-
-
-
-
7.0
<5

Table A.6.a: Water Withdrawal Data

	S	ource 1 – Prod	uction Well 1 (P	' 1)	Source 2 - Production Well 2 (P2)				
Month	Monthly Maximum Daily Rate (m ³ /d)	Monthly Average Daily Rate (m³/d)	Monthly Withdrawal Volume (m³)	Annual Withdrawal Volume (m³)	Monthly Maximum Daily Rate (m ³ /d)	Monthly Average Daily Rate (m ³ /d)	Monthly Withdrawal Volume (m³)	Annual Withdrawal Volume (m³)	
January	0	0	0	0	179	64	318		
February	0	0	0	0	163	92	250		
March	0	0	0	0	40	39	77		
April	0	0	0	0	158	76	250		
May	0	0	0	0	49	33	89		
June	0	0	0	0	315	103	561		
July	0	0	0	0	274	110	804		
August	0	0	0	0	102	69	187		
September	0	0	0	0	202	73	642		
October	0	0	0	0	215	83	430		
November	0	0	0	0	77	71	141		
December	0	0	0	0	0	0	0		
Total Annual Withdrawal				0				3749	



	S	ource 3 – Produ	iction Well 3 (P	3)	Source 4 – Production Well 4 (P4)				
Month	Monthly Maximum Daily Rate (m ³ /d)	Monthly Average Daily Rate (m³/d)	Monthly Withdrawal Volume (m³)	Annual Withdrawal Volume (m³)	Monthly Maximum Daily Rate (m ³ /d)	Monthly Average Daily Rate (m³/d)	Monthly Withdrawal Volume (m³)	Annual Withdrawal Volume (m ³)	
January	357	215	6,61		443	336	10,403		
February	387	222	6,204		438	368	10,299		
March	356	220	6,810		438	333	10,327		
April	356	227	6,820		437	323	9688		
May	354	258	7,997		431	370	11,462		
June	353	263	7,894		426	336	10,076		
July	378	259	8,041		418	316	9811		
August	350	247	7,666		411	334	10,348		
September	597	252	7,545		408	328	9,825		
October	350	254	7,859		411	323	10,007		
November	351	213	4,895		417	320	9,611		
December	0	0	0		421	274	8,506		
Total Annual Withdrawal				71,731				120,363	

Table A.6.a: Water Withdrawal Data



So	ource – PW	/1		Source – PW2			Source – PW3	
Specify Approved Exceeds Withdrawal Limits (Yes/No)		Exceeds (Yes/No)	Specify Approved Withdrawal Limits		Exceeds (Yes/No)	Specify Approved Withdrawal Limits		Exceeds (Yes/No)
Maximum Daily Rate Litres/day	0	No	Maximum Daily Rate Litres/day	716,531	No	Maximum Daily Rate Litres/day	728,760	No
Average Daily Rate - Litres/day	0	No	Average Daily Rate - Litres/day	573,235	No	Average Daily Rate - Litres/day	583,708	No
Volume (30 days) - Litres	0	No	Volume (30 days) - Litres	17,197,050	No	Volume (30 days) - Litres	17,511,240	No
Volume (Annual) - Litres	0	No	Volume (Annual) - Litres	209,520,775	No	Volume (Annual) - Litres	213,343,420	No

Table A.6.b: Water Withdrawal Data Comparison to Approved Limits

Table A.6.b: Water Withdrawal Data Comparison to Approved Limits

Specify Approved Withdrawal Limits		Exceeds (Yes/No)
Maximum Daily Rate (litres/day)	981,956	No
Average Daily Rate (litres/day)	654,637	No
Volume (30 days) (litres)	19,639,110	No
Volume (Annual) (litres)	238,942,505	No



Table C.1 - Operator in Overall Direct Responsible Charge

The operator in overall direct responsible charge (ODRC) is: (Specify name - add additional lines if more than one ODRC operator)

Signature of operator:_____hundle Date: May 26/23 Protocols in place during the absence of the operator in ODRC include (specify): When on vacation: James Jenner When ill: James Jenner Other (specify) James Jenner

Terms of Reference for System Assessment Reports for Municipal Drinking Water Systems / Tables

68

APPENDIX B

Watershed Boundary Plan







APPENDIX C

Distribution Map





APPENDIX D

Corrosion Control Program Results





11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B38 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PO Box 100 Annapolis Royal, NS B0S1A0 (902) 532-3141 ATTENTION TO: James Jenner PROJECT: AGAT WORK ORDER: 22X967186 WATER ANALYSIS REVIEWED BY: Jason Coughtrey, Inorganics Supervisor DATE REPORTED: Nov 17, 2022 PAGES (INCLUDING COVER): 6 VERSION*: 1

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

No	tes	
Dise	Jaimer	
	All work conducted herein has been done using acce	pted standard protocols, and generally accepted practices and methods. AGAT test methods ma
	All samples will be disposed of within 30 days followi	e memods to improve periormance. ing analysis, unless expressly agreed otherwise in writing. Please contact your Client Project
	Manager if you require additional sample storage tim	18. 18.
	AGAT's liability in connection with any delay, perform third party. Unless expressly agreed otherwise in writ	nance or non-performance of these services is only to the Client and does not extend to any other ting, AGAT's liability is limited to the actual cost of the specific analysis or analyses included in the
	SERVICES	
	services. This report shall not be reproduced or distributed, in t	whole or in part, without the prior written consent of AGAT Laboratories.
	services. This report shall not be reproduced or distributed, in The test results reported herewith relate only to the s	whole or in part, without the prior written consent of AGAT Laboratories. samples as received by the laboratory.

All reportable information as specified by ISO/IEC 17025 2017 is available from AGAT Laboratories upon request.

AGAT Laboratories (V1)

Member of Association of Professional Engineers and Geoscientists of Alberta (APEGA) Western Enviro-Agricultural Laboratory Association (WEALA) Environmental Services Association of Alberta (ESAA) AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation fnc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation. Measurement Uncertainty is not taken into consideration when stating conformity with a specified requirement.



Page 1 of 5



Certificate of Analysis AGAT WORK ORDER: 22X967186 PROJECT:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner
SAMPLED BY:

	SAMPLED BY:
Health Canada Lead & Conne	r Sampling - Drinking Water

DATE RECEIVED: 2022-11-08								DATE REPORTER): 2022-11-17
0.55		SAMPLE DESC SAMP DATE S	RIPTION: LE TYPE: AMPLED:	18 Church St Water 2022-11-07 10:10	12 Church St Water 2022-11-07 10:15	10 Rectory St Water 2022-11-07 10:20	54 Rectory St Water 2022-11-07 10:25	211 Granville St Water 2022-11-07 11:50	
Parameter	Unit	G/S	RDL	4497805	4497807	4497808	4497809	4497810	
Total Lead - Health Canada	ug/L	5	0.5	6.5	<0.5	<0.5	<0.5	<0.5	
Total Copper	ug/L	2000, 1000	2	116	72	71	25	70	

Comments: RDL - Reported Detection Limit: G / S - Guideline / Standard: Refers to Canadian Drinking Water Quality - updated 2023-01 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation. Analysis performed at AGAT Halifax (unless: marked by *)

Certified By:

Page 2 of 6

Jasan Cocapiting

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested. Results apply to samples as received.

			ries Guideline Violat AGAT WORK ORDER: 22X967 PROJECT:	Guideline Violation AGAT WORK ORDER: 22X967186 PROJECT:			11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com	
CLIENT NAM	E: MUNICIPALITY OF ANN	APOLIS COUNTY		ATTENTION TO: James	Jenner			
SAMPLEID	SAMPLE TITLE	GUIDELINE	ANALYSIS PACKAGE	PARAMETER	UNIT	GUIDEVALUE	RESULT	
4497805	18 Church St	NS-CDWQ incl [AO]	Health Canada Lead & Copper Sampling - Drinking Water	Total Lead - Health Canada	ug/L	5	6.5	

AGAT GUIDELINE VIOLATION (V1)

Results relate only to the items tested. Results apply to samples as received.

Page 3 of 6

Chain of Custo	dy Record			P	: 90:	2.46	8.87	18 •	F: 90	02.46	58.89	24	AG/	o Tin	me: b N	umb	er:	20	2x	96	7	180	20	-
Report Information Company: Mun of the County of Atmapolis Contact: James Jenner			Report	nformation (Please print):					Rep	ort F	Forma	t	No	tes:	ex	tra		10	1.	Stat	51	Ρ".	26	of
			1. Name	James Jenenr	_	_				Single	Sample		Cooler, ile pau				ac	22NOU 8 8					Q:1	
			Email	Email: jenner@annapoliscounty.ca						per page			Turnaround Time Required (TAT)											
Address: PO Box 100 75	52 St George St		2. Name	2. Name: Charles Grant						le Samp ge	les	Pequilar TAT 2 5 to 7 working days												
Annapolis Roy	/al		Email	Email: cgrant@annapoliscounty.ca													r working days							
Phone:	Fax:		Pogulat									Rus	in D	41	-	I Sa	me	Jay		Lday	6			
Client Project #:			Elist Gu	El Let Guidelines on Report									□ 2 days □ 3 days											
AGAT Ouctation:		-			r ciuloi	1111031	oil nep	~~				-	Dat	e Re	quin	ed:	_			_	_	-	_	_
Please Note: if quotation number	is not provided client will be billed fu	Il price for anal	ysis, Tier	1 Res Pot		Co	arse	ł					-	_	-	-	-		_	_	_		_	_
Involce To	Same		2 □ Com □ N/Po , □ Fuel □ Lube	t	- Fit	ne		Drink Reg.	No.:	Vater S	ampl	le: L	Yes		No	S	alt W	/ater :	Samp	le	□ Ye	<u>j</u>	No	
Company			CCME	CDWQ	Г			T	T			1	T	-		1	T	T	1		T	T	3	T
Contact: Amanda Lewis				ustrial SEQS-Cont Sites			able						-							4			2	
Address			- Cor	mercial HRM 101	1		Avai						n levi	w								AF I	Į.	
Address.				cultural Storm Water		10	-			ss			010	puati						Nd	998		3	
Disease 009 599 1445			- DFW	L Waste Water	erved	alysi	Diss			2		1.2	PIRI)	racti	ĕ					N	omo	MPN	later	
PO/Credit Card#:	Fax:		Sec	liment Other	d/Pres	ater Ar	otal C	LODO I		TDS	Norus		BTEX (BTEX F	TPH/B					P/A	Pseud	E	II Cas	INZA
Sample Identification	Date/Time Sampled	Sample	# Containers	Comments - Site/Sample Info.	d Filtere	ndard W	tals: D T	kina	3	SS	I Phosp	nols	1: TPH/	2: TPH/	AE-CWS					EC	2	al Colifo	DE DE	rardous
		Matrix		Sample Containment	Fie	Sta	Me	2 2	Ha	ä	Tota	h	Ties	19L	8	8	Ē	PAH	PC	Ę.	E	E Fe	f	Ta
18 Church St	Nov 7/22 10:10 AM	-	-		1				-		_	-		_		-		-	-			6	1	
12 Church St	Nov 7/22 10:15 AM		1		-		_	-	-		_		-					-				6	2	
Ed Destern St	Nov 7/22 10:20 AM	-	1		-		-	-	-		-	-				_	-	_	-			6	2	_
211 Cramille St	Nov 7/22 10:25 Am		1		+		-	-	-		-	-	-		_	-	-	+	+		-	6	1	-
TTT CHARTER DI	NOV THE TEST AND				+		-	-	-		-	-	-	-	-	+	+	+	-		\vdash	10	1	-
	-		-		+		-	-	+		-	-	-		-	+	+	+	+	-	\vdash	-	-	-
					+			-	-		-	1	-		-	+	+	+	+	+	+	-	+	-
		-			+			-	+		-	-	-			+	-	-	+	++	+	-	-	-
		1			+				+		-	1	-			+	+	+	+	+	-	-	-	+
	1				1				+		-	1	-			-	-	-	-	+	-	-	-	-
									1			-	-			+	+	-	-				-	-
Amples Releaseshed by Print Names		Date	/Time	Samples Recoved By (Print Neme):	-	-	_		-	Da	ta/Time	-	-	T	link	onv-	Clinic	T		F	_	1.5	-	1
any brown		140	W 1122	\square				-	_	-					ellow	Copy	- AGA	TL	Pa	ige [-	10[_	1
VEHICLES FORTH TO CALL AND THE COMPANY				and a second sec			_				and the second se				- /**** f	T								

APPENDIX E

Last Round of Sampling Data for *GCDWQ*





11 Morris Drive, Unit 122 Darlmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PO Box 100 Annapolis Royal, NS B0S1A0 (902) 532-3141

ATTENTION TO: James Jenner

PROJECT:

AGAT WORK ORDER: 18X352285

FOOD CHEMISTRY REVIEWED BY: Philippe Morneau, chimiste

MISCELLANEOUS ANALYSIS REVIEWED BY: Laura Baker, Inorganics Data Reporter

TRACE ORGANICS REVIEWED BY: Amy Hunter, Trace Organics Supervisor, B.Sc.

WATER ANALYSIS REVIEWED BY: Laura Baker, Inorganics Data Reporter

DATE REPORTED: Jul 16, 2018

PAGES (INCLUDING COVER): 23

VERSION*: 1

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

*NOTES	
All samples will be disposed of within 30 days following and	alysis. Please contact the lab if you require additional sample storage time.
AT Laboratories (V1)	Page 1 c
nber of: Association of Professional Engineers and Geoscientists of Alberta	AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laborato
(APEGA) Western Enviro-Agricultural Laboratory Association (WEALA) Environmental Services Association of Alberta (ESAA)	Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed scope of accreditation, AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accredit are location and parameter specific. A complete listing of parameters for each location is avai from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included the scope of accreditation.



CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:					Certificate of AGAT WORK ORDER PROJECT:	11 Morris Drive, Unit 122 Dartmouth, Nova Socia CANADA B38 1M2 TEL (902)468-8714 FAX (902)468-8734 http://www.agaitabs.com		
				Glyp	ohosate (Montreal)	(ug/L)		
DATE RECEIVED: 2018-06-19	ē.					DATE REPOR	TED: 2018-07-16	
Parameter	Unit	SAMPLE DES SAM DATE G/S	CRIPTION: PLE TYPE: SAMPLED: RDL	Town Hall Water 2018-06-18 9342204	PW2 RAW Water 2018-06-18 9342302			
Glyphosate	ug/L		15	<15	<15			

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

Certified By:

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested and to all the items tested

Page 2 of 23

Marine (F)



Certificate of Analysis AGAT WORK ORDER: 18X352285 PROJECT:

ATTENTION TO: James Jenner

SAMPLED BY:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotla CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

Canadian Drinking Water MAC Package (Radiochemistry)									
DATE RECEIVED: 2018-06-19				1		DATE REPORTED: 2018-07-16			
14 7 S C		SAMPLE DES SAM DATE	CRIPTION: PLE TYPE: SAMPLED:	Town Hall Water 2018-06-18	PW2 RAW Water 2018-06-18				
Parameter	Unit	G/S	RDL	9342204	9342302				
Radionuclides - Gross Alpha	Bq/L	0.5	0.1	0.48+/-0.16	0.92+/-0.25				
Radionuclides - Gross Beta	Bq/L	1.0	0.1	0.25+/-0.05	0.26+/-0.04				

 Comments:
 ROL - Reported Detection Limit; G / S - Guideline / Standard: Refers to Canadian Drinking Water Quality - updated 2017-05 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation. 9342204-9342302 "Analysis performed at subcontracted laboratory.

Certified By:

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested and to all the items tested

Page 3 of 23

Laure Bater





Certificate of Analysis AGAT WORK ORDER: 18X352285 PROJECT:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotla CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner

SAMPLED BY:

Canadian Drinking Water MAC Package (Subcontracted)								
					DATE REPORTED: 2018-07-16			
1	SAMPLE DES SAN DATE	SCRIPTION: MPLE TYPE: SAMPLED:	Town Hall Water 2018-06-18	PW2 RAW Water 2018-06-18				
Unit	G/S	RDL	9342204	9342302				
mg/L	0.4	0.03	< 0.03	<0.03				
ug/L	1.5	0.1	<0.1	<0.1				
ug/L	0.04	0.0008	<0.0008	<0.0008				
	Unit mg/L ug/L ug/L	SAMPLE DES SAN DATE Unit G / S mg/L 0.4 ug/L 1.5 ug/L 0.04	Canadia SAMPLE DESCRIPTION: SAMPLE TYPE: DATE SAMPLED: Unit G/S MgL 0.4 ugL 1.5 0.0008 0.0008	Canadian Drinking SAMPLE DESCRIPTION: Town Hall SAMPLE DESCRIPTION: Town Hall SAMPLE TYPE: Water DATE SAMPLED: 2018-06-18 Unit G/S RDL 9342204 mg/L 0.4 0.03 ug/L 0.4 0.03 ug/L 0.4 0.0008 ug/L 0.04 0.0008	Canadian Drinking Water MAC Package (Su SAMPLE DESCRIPTION: Town Hall PWZ RAW SAMPLE TYPE: Water Water DATE SAMPLED: 2018-06-18 2018-06-18 OUR-06-18 Unit G/S RDL 9342204 9342302 mg/L 0.4 0.03 <0.03			

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard: Refers to Canadian Drinking Water Quality - updated 2017-05 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation. 9342204-9342302 "Analysis performed at subcontracted laboratory.

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By:

Results relate only to the items tested and to all the items tested

Laure Bater Page 4 of 23

CBCL


11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner SAMPLED BY:

DATE RECEIVED: 2018-06-19						DATE REPORTED: 2018-07-16
		SAMPLE DES SAM DATE :	CRIPTION: PLE TYPE: SAMPLED:	Town Hall Water 2018-06-18	PW2 RAW Water 2018-06-18	
Parameter	Unit	G/S	RDL	9342204	9342302	
Aldicarb	µg/L		0.15	<0.15	<0.15	
Bendiocarb	µg/L		2	<2	<2	
Carbofuran	µg/L	90	5	<5	<5	
Carbary)	µg/L	90	5	<5	<5	
Diuron	µg/L	150	10	<10	<10	

Comments: RDL - Reported Detection Limit: G / S - Guideline / Standard: Refers to Canadian Dinking Water Quality - updated 2017-05 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation. 9342204-9342302 Analysis performed in AGAT Mississauga laboratory.

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested and to all the items tested

Certified By:

Page 5 of 23

my Und



ATTENTION TO: James Jenner

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

SAMPLING SITE:	MPLING SITE:					SAMPLED BY:
			Canad	ian Drinkir	g Water MAC Pac	ckage (Diq./Paraq.)
DATE RECEIVED: 2018-06-1	9					DATE REPORTED: 2018-07-16
		SAMPLE DESCRIPTION: SAMPLE TYPE: DATE SAMPLE D		Town Hall Water 2018-06-18	PW2 RAW Water 2018-06-18	
Parameter	Unit	G/S	RDL	9342204	9342302	
Diquat.	µg/L	70	1	<1	<1	
Paraquat	µg/L	10	1	<1	<1	

Comments:
 ROL - Reported Detection Limit; G / S - Guideline / Standard; Refers to Canadian Drinking Water Quality - updated 2017-05
 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation.
9342204-9342302
Analysis performed in AGAT Mississauga laboratory.

Certified By:

Page 6 of 23

my Hut

AGAT CERTIFICATE OF ANALYSIS (V1)



11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner SAMPLED BY:

DATE RECEIVED: 2018-06-19						DATE REPORTED: 2018-07-16
Parameter	Unit	SAMPLE DESC SAMP DATE S G/S	RIPTION: LE TYPE: AMPLED: RDL	Town Hall Water 2018-06-18 9342204	PW2 RAW Water 2018-06-18 9342302	
Chloroacetic Acid	ug/L		1.7	<1.7	<1.7	
Bromoacetic Acid	ug/L		0.3	< 0.3	<0.3	
Dichloroacetic Acid	ug/L		0.2	2.0	<0.2	
Trichloroacetic Acid	ug/L		0.2	<0.2	<0.2	
Bromochloroacetic Acid	ug/L		0.2	0.5	<0.2	
Dibromoacetic Acid	ug/L		0.1	<0.1	<0.1	
Haloacetic Acids	ug/L	80	4.0	<4.0	<4.0	
Bromoxynil	µg/L	5	0.5	<0.5	<0.5	
Dicamba	µg/L	120	0.05	<0.05	<0.05	
2,4-Dichlorophenol	µg/L	900, 0.3	0.3	<0.3	<0.3	
2.4-Dichlorophenoxyacetic acid (2, 4-D)	µg/L	100	0.05	<0.05	<0.05	
Diclofop Methyl	µg/L	9	0.05	< 0.05	<0.05	
Dinoseb	µg/L		1	<1	<1	
2-Methyl-4-chlorophenoxyacetic acid MCPA)	µg/L	100	5	<5	<5	
Pentachlorophenol	µg/L	60, 30 AO	0.5	<0.5	<0.5	
Picloram	µg/L	190	0.05	<0.05	<0.05	
3.4,6-Tetrachlorophenol	µg/L	100, 1 AO	0.5	<0.5	<0.5	
4,6-Trichlorophenol	µg/L	5, 2 AO	0.5	<0.5	<0,5	
Ndrin	ug/L		0.05	<0.05	<0.05	
Dieldrin	ug/L		0.05	<0.05	<0.05	
Aldrin + Dieldrin	ug/L		0.05	<0.05	<0.05	
Nethoxychlor	µg/L		0.1	<0.1	<0.1	
Phorate	µg/L	2	0.5	<0.5	<0.5	
Dimethoate	µg/L	20	1.5	<1.5	<1,5	
Terbufos	µg/L	1	0.7	<0.7	<0.7	
Chlorpyrifos	µg/L	90	1	<1	<1	
Diazinon	µg/L	20	1	<1	<1	
Alathion	µg/L	190	1	<1	<1	
Parathion	µg/L		1	<1	<1	

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By:

Results relate only to the items tested and to all the items tested

Page 7 of 23



Certificate of Analysis AGAT WORK ORDER: 18X352285

PROJECT:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner SAMPLED BY:

Canadian Drinking Water MAC Package (HAAs, Herbicides, PAH, OC Pest, Triaz. Pest, OP Pest., VOCs) DATE RECEIVED: 2018-06-19 DATE REPORTED: 2018-07-16 SAMPLE DESCRIPTION: Town Hall PW2 RAW SAMPLE TYPE: Water Water 2018-06-18 DATE SAMPLED: 2018-06-18 Unit G/S RDL 9342204 9342302 Parameter Azinophos Benzo(a)pyrene Trifluralin µg/L mg/L µg/L 20 2 <2 <2 <2 <0.00001 <1 <1 0.00004 0.00001 <0.00001 45 10 <1 <1 1 Triffuralin Simazine Afrazine Afrazine + N-dealkylated metabolites Metabuzin Cyanazine Metolachlor Vinyi Chloride Chlorothane µg/L µg/L µg/L <0.5 <1 <0.25 <0.5 <1 <0.25 0.5 5 μg/L μg/L μg/L 80 0.25 1 <1 <1 <1 <1 50 ug/L ug/L ug/L 2 0.6 <0.6 <0.6 Vinyl Chloride Chloroethare 1.1-Dichloroethylene Methylene Chloride (Dichloronethane) Methyl-Eltur (MTBE) Chloroform 1.2-Dichloroethane Carbon Tetrachloride Berzene Trichloroethylene Bromolchloroethylene 5 <5 <2 <5 <2 14 ug/L 50 <2 <2 2 <2 15 AO <2 <1 <2 <1 2 2 1 1 1 2 2 5 Bromodichloromethane Toluene Dibromochloromethane Tetrachloroethylene 60, 24 AO <2 2 <1 Chlorobenzene Ethylbenzene 80. 30 AO <1 1 2 1 4 1 1 140.1.6 AO <2 <1 <4 <1 Bromoform Xylenes (Total) 1,4-Dichlorobenzene 300 AO 5, 1 AO 1.2-Dichlorobenzene ug/L 200, 3 AO <1 my Huy

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested and to all the items tested

Certified By:

Page 8 of 23



11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner SAMPLED BY:

DATE RECEIVED: 2018-06-19						DATE REPORTED: 2018-07-16
Parameter	Unit	SAMPLE DES SAM DATE S G/S	CRIPTION: PLE TYPE: SAMPLED: RDL	Town Hall Water 2018-06-18 9342204	PW2 RAW Water 2018-06-18 9342302	
Total Trihalomethanes	ug/L	100	1	6	<1	
Surrogate	Unit	Acceptab	le Limits			
2-Bromobutanoic acid	%	50-1	30	102	114	
Toluene-d8	%	60-1	30	95	96	
4-Bromofluorobenzene	%	60-1	30	89	88	

RDL - Reported Detection Limit: G / S - Guideline / Standard: Refers to Canadian Drinking Water Quality - updated 2017-05 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation.

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By: Results relate only to the items tested and to all the items tested

Page 9 of 23

my Huf



11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902/468-8718 FAX (902/468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE: ATTENTION TO: James Jenner SAMPLED BY:

	Canadian Drinking Water MAC Package (Metals, Hg & Inorganics)										
DATE RECEIVED: 2018-06-19						DATE REPORTED: 2018-07-16					
1000		SAMPLE DESC SAMP DATE S	RIPTION: LE TYPE: AMPLED:	Town Hall Water 2018-06-18	PW2 RAW Water 2018-06-18						
Parameter	Unit	G/S	RDL	9342204	9342302						
Total Aluminum	ug/L	100 OG AO	10	<10	<10						
Total Antimony	ug/L	6	2	<2	<2						
Total Arsenic	ug/L	10	2	4	4						
Total Barium	ug/L	1000	5	341	271						
Total Boron	ug/L	5000	5	14	13						
Total Cadmium	ug/L	5	0.3	<0.3	<0.3						
Total Chromium	ug/L	50	2	3	3						
Total Copper	ug/L	1000 AO	2	14	<2						
Total Iron	ug/L	300 AO	50	52	<50						
Total Lead	ug/L	10	0.5	<0.5	<0.5						
Total Manganese	ug/L	50 AO	2	<2	<2						
Total Selenium	ug/L	50	2	<2	<2						
Total Uranium	ug/L	20	0.1	19.5	19.7						
Total Zinc	ug/L	5000 AO	5	6	<5						
Total Sodium	mg/L	200 AO	0.1	14.8	9.8						
Mercury	ug/L	1	0.05	<0.05	<0.05						
pH		7.0-10.5		8.27	8.26						
Turbidity	NTU	0.1-1	0.1	0.1	0.2						
True Color	TCU	15 AO	5	13	10						
Chloride	mg/L	250 AO	1	11	6						
Fluoride	mg/L	1.5	0.12	0.43	0.64						
Nitrate as N	mg/L	10	0.05	0.25	0.23						
Sulphate	mg/L	500 AO	2	5	4						
Total Dissolved Solids	mg/L	500 AO	5	170	156						
Bromate	mg/L	0.01	0.01	< 0.01	< 0.01						
Chlorate	mg/L	1	0.02	0.14	<0.02						
Chlorite	mg/L	1	0.02	<0.02	<0.02						
Sulphide	mg/L	0.05 AO	0.05	<0.05	<0.05						
Cyanide, Free	mg/L		0.002	<0.002	<0.002						

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By:

Laure Bater

Results relate only to the items tested and to all the items tested

Page 10 of 23



11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

DATE RECEIVED: 2018-06-19

LIS COUNTY ATTENTION TO: James Jenner SAMPLED BY: Canadian Drinking Water MAC Package (Metals, Hg & Inorganics)

DATE REPORTED: 2018-07-16

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard; Refers to Canadian Dinking Water Quality - updated 2017-05 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation. 9342204-9342302 Sulphide and Cyanide were analysed at AGAT Mississauga.

Certified By:

Laure Bale Page 11 of 23

AGAT CERTIFICATE OF ANALYSIS (V1)

B (30	i a 1	Labo	ratorie	25	Certificate of AGAT WORK ORDER PROJECT:	11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)488-8718 FAX (902)488-8974 http://www.agatlabs.com	
CLIENT NAME: MUNICIPA	LITY OF ANN	APOLIS CO	UNTY			ATTENTION TO: James Jenne	er
SAMPLING SITE:						SAMPLED BY:	
					Chloramines		
DATE RECEIVED: 2018-06-1	9					DATE R	EPORTED: 2018-07-16
		SAMPLE DES	CRIPTION:	Town Hall	PW2 RAW		
		SAM	PLE TYPE:	Water	Water		
	DATE SAMPLED: 2018-0						
Parameter	Unit	G/S	RDL	9342204	9342302		
Chloramines - Total	mg/L		0.50	<0.50	<0.50		
				_			

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

Certified By:

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested and to all the items tested

Page 12 of 23

Laure Bater



5

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatiabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

ATTENTION TO: James Jenner SAMPLED BY:

	Total Metals - Uranium										
DATE RECEIVED: 2018-06-19							DATE REPORTED: 2018-07-16				
		SAMPLE DES	CRIPTION:	PW2	PW3	Storage Tank					
		SAMPLE TYPE:		Water	Water	Water					
		DATE	SAMPLED:	2018-06-18	2018-06-18	2018-06-18					
Parameter	Unit	G/S	RDL	9342305	9342308	9342309					
Total Uranium	ug/L		0.1	19.5	19.7	19.7					

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

Certified By:

AGAT CERTIFICATE OF ANALYSIS (V1)

Results relate only to the items tested and to all the items tested

Page 13 of 23

Laure Bale





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PROJECT: SAMPLING SITE: AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:

			Food	d Che	mist	try A	nalys	is							
RPT Date: Jul 16, 2018 DUPLICATE						1	REFERENCE MATERIAL			METHOD	BLAN	K SPIKE	MATRIX SPIKE		
PARAMETER	Batch	Sample Id	Dup #1	Dup #2	RPD	Method Blank	Measured	Acceptable Limits		Recovery	Acceptable Limits		Recovery	Acceptable	
							Value	Lower	Upper		Lower	Upper	Necovery	Lower	Upper
Glyphosate (Montreal) (ug/L) Glyphosate	628	9342202	< 15	< 15	0.0%	< 15	98%	70%	130%	98%	70%	130%	99%	70%	130%

Certified By:	pu-C
AGAT QUALITY ASSURANCE REPORT (V1)	Page 14 of 23
AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CAL4 listed on the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association fo tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available I not necessarily be included in the scope of accreditation.	 and/or Standards Council of Canada (SCC) for specific tests r Laboratory Accreditation (nc, (CALA) for specific drinking water from www.cala.ca and/or www.scc.ca. The tests in this report may
Results relate only to the items tested and to all the item	is lested





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PROJECT: SAMPLING SITE: AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:

<table-container> PARAMETER Barb Barb<th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th></table-container>														
PARAMETER Batch Sample Id Dup #1 Dup #2 RPD. Method Relative Plant Method Value Conceptuble Lower Recoverul Limits Acceptuble Limits Canadian Drinking Water MAC Package (HAAs, Herbicides, PAH, OC Pest, Triaz, Pest, OP Pest, UP2st, Clocoacetic Acid 1 9340096 <.17 <.17 NA <0.17 84% 70% 130% 87% 60% 13 Dichoracetic Acid 1 9340096 0.2 <.0.3 NA <0.2 86% 70% 130% 10% 60% 13 Dichoracetic Acid 1 9340096 1.4 1.3 7.4% <0.2 91% 70% 130% 10% 60% 13 Bromochioraacetic Acid 1 9340096 1.6 1.4 13.3% <0.1 84% 70% 130% 60% 13 Bromochioraacetic Acid 1 9330262 <0.5 NA <0.05 104% 70% 130% 60% 13 2.4-Dichlorophenol 1 9330262 <0.05 </th <th>RPT Date: Jul 16, 2018</th> <th>1</th> <th>DUPLICATE</th> <th></th> <th>1.0</th> <th>REFEREN</th> <th>ICE MA</th> <th>TERIAL</th> <th>METHOD</th> <th>BLANK</th> <th>SPIKE</th> <th>MAT</th> <th>RIX SPI</th> <th>KE</th>	RPT Date: Jul 16, 2018	1	DUPLICATE		1.0	REFEREN	ICE MA	TERIAL	METHOD	BLANK	SPIKE	MAT	RIX SPI	KE
Image: Constraint of the second sec	PARAMETER Batch Sam	ple Dup #1	Dup #2	RPD	Method Blank	Measured	Acce Lit	eptable nits	Recovery	Acce	ptable nits	Recovery	Acce	ptable nits
Canadian Drinking Water MAC Package (HAAs, Herbicites, PAH, OC Pest, Triaz, Pest, OP Pest, VOP VOP 130% 87% 60% 13 Chioraacelic Acid 1 9340096 0.3 0.0.3 NA < 0.2 86% 70% 130% 83% 60% 13 Dichloraacelic Acid 1 9340096 0.2 NA < 0.2 97% 70% 130% 105% 60% 13 Tichloraacelic Acid 1 9340096 1.4 1.3 7.4% < 0.2 97% 70% 130% 85% 60% 13 Bromochloraacelic Acid 1 9340096 1.6 1.4 13.3% < 0.1 84% 70% 130% 85% 60% 13 Dichomaacelic Acid 1 9330262 < 0.05 NA < 0.05 104% 70% 130% 80% 60% 13 Q4-Dichlorophenol 1 9330262 < 0.05 NA < 0.05 108% 70% 130% 00% 60% 13			1.1.1		1.1	VINGS	Lower	Upper	1. I	Lower	Upper	1	Lower	Uppe
Chloracetic Acid 1 9340096 < 1.7 < 1.7 NA < 1.7 84% 70% 130% 87% 60% 13 Bromaacetic Acid 1 9340096 < 0.3 < 0.3 NA < 0.3 102% 70% 130% 87% 60% 13 Dichloracetic Acid 1 9340096 < 0.3 < 0.2 NA < 0.2 86% 70% 130% 108% 60% 13 Dichloracetic Acid 1 9340096 < 1.4 1.3 7.4% < 0.2 97% 70% 130% 102% 60% 13 Bromochloracetic Acid 1 9340096 < 1.4 1.3 7.4% < 0.2 97% 70% 130% 102% 60% 13 Dichoracetic Acid 1 9330262 < 0.5 0.5 NA < 0.2 86% 70% 130% 85% 60% 13 Dichoracetic Acid 1 9330262 < 0.5 0.5 NA < 0.5 86% 70% 130% 96% 60% 13 Dichoracetic Acid 1 9330262 < 0.5 0.5 NA < 0.5 86% 70% 130% 96% 60% 13 Dicamba 1 9330262 < 0.05 0.05 NA < 0.05 104% 70% 130% 96% 60% 13 2.4-Dichorachenoxyacetic acid 2 9330262 < 0.05 < 0.05 NA < 0.05 113% 60% 130% 85% 70% 13 2.4-Dichorachenoxyacetic acid 2 9330262 < 0.05 < 0.05 NA < 0.05 113% 60% 130% 85% 70% 13 2.4-Dichorachenoxyacetic acid 2 9330262 < 0.05 < 0.05 NA < 0.05 113% 60% 130% 60% 13 Dicamba 1 9330262 < 0.05 < 0.05 NA < 0.05 113% 60% 130% 60% 13 2.4-Dichorachenoxyacetic acid 2 9330262 < 0.5 0.05 NA < 0.05 113% 60% 130% 10% 60% 13 Dicate 1 9330262 < 0.5 0.5 NA < 0.5 81% 70% 130% 10% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 81% 70% 130% 10% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 81% 70% 130% 10% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 81% 70% 130% 10% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 81% 70% 130% 10% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 81% 70% 130% 10% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330262 < 0.5 0.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330269 < 1.5 1.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330209 < 1.5 1.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330209 < 1.5 1.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330209 < 1.5 1.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330209 < 1.5 1.5 NA < 0.5 85% 70% 130% 95% 60% 13 Dichorace 1 9330209 < 1.5 1.5 NA < 0.5 75	Canadian Drinking Water MAC Package (HAAs, H	erbicides, P/	AH, OC Pes	t, Triaz.	Pest, OP	Pest., VO	Cs)							
Bromozelic Acid 1 9340096 <0.3 NA <0.3 10.2% 70% 130% 437% 60% 13 Dichlorozestic Acid 1 9340096 0.3 0.2 NA <0.2	Chloroacetic Acid 1 934009	96 < 1.7	< 1.7	NA	< 1.7	84%	70%	130%	87%	60%	130%	121%	70%	1309
Dichloroacetic Acid 1 9340096 2.6 2.5 3.9% < 0.2 86% 70% 130% 110% 60% f3 Bromochloroacetic Acid 1 9340096 1.4 1.3 7.4% < 0.2	Bromoacetic Acid 1 934009	6 < 0.3	< 0.3	NA	< 0.3	102%	70%	130%	83%	60%	130%	118%	70%	1309
Tichloroacetic Acid 1 9340096 0.3 <0.2 NA <0.2 97% 70% 130% 102% 60% 13 Bromochloroacetic Acid 1 9340096 1.6 1.4 1.3 7.4% <0.2	Dichloroacetic Acid 1 93400	6 2.6	2.5	3.9%	< 0.2	86%	70%	130%	116%	60%	130%	94%	70%	130%
Bromochloroacetic Acid 1 9340096 1.4 1.3 7.4% < 0.2 91% 70% 130% 102% 60% 13 Dibromoacetic Acid 1 9340096 1.6 1.4 13.3% < 0.1	Trichloroacetic Acid 1 934009	6 0.3	<0,2	NA	< 0.2	97%	70%	130%	108%	60%	130%	99%	70%	130%
Dibromaeæitc Acid 1 9340096 1.6 1.4 13.3% < 0.1 84% 70% 130% 85% 60% 13 Bromoxynii 1 9330262 < 0.5	Bromochloroacetic Acid 1 934009	96 1.4	1.3	7.4%	< 0.2	91%	70%	130%	102%	60%	130%	117%	70%	130%
Bromoxynil 1 9330262 < 0.5	Dibromoacetic Acid 1 93400	6 1.6	1.4	13.3%	< 0.1	84%	70%	130%	85%	60%	130%	99%	70%	1309
Dicamba 1 9330262 < 0.05 < 0.05 NA < 0.05 104% 70% 130% 96% 60% 13 2,4-Dichlorophenol 1 9330262 < 0.3	Bromoxynil 1 933026	32 < 0.5	< 0.5	NA	< 0.5	86%	70%	130%	95%	60%	130%	104%	60%	1309
2,4-Dichlorophenol 1 9330262 < 0.3	Dicamba 1 93302/	52 < 0.05	< 0.05	NA	< 0.05	104%	70%	130%	96%	60%	130%	85%	60%	130%
2.4-Dichlorophenoxyacetic acid 1 9330262 < 0.05	2.4-Dichlorophenol 1 933020	52 < 0.3	< 0.3	NA	< 0.3	82%	70%	130%	91%	60%	130%	119%	60%	130%
Diclotop Methyl 1 9330262 <0.05 NA <0.05 108% 70% 130% 100% 60% 13 Dinoseb 1 9330262 <1	2,4-Dichlorophenoxyacetic acid 1 933020 (2,4-D)	52 < 0.05	< 0.05	NA	< 0.05	113%	60%	130%	85%	70%	130%	88%	70%	130%
Dinoseb 1 9330262 < 1 < 1 NA < 1 111% 70% 130% 101% 60% 13 2-Methyl-4-chlorophenoxyacetic acid (MCPA) 1 9330262 <5	Diclofop Methyl 1 933020	32 < 0.05	< 0.05	NA	< 0.05	108%	70%	130%	100%	60%	130%	99%	60%	130%
2-Methyl-4-chlorophenoxyacetic 1 9330262 <5 <5 NA <5 82% 70% 130% 105% 60% 13 Pentachlorophenol 1 9330262 <0.5	Dinoseb 1 93302	52 <1	<1	NA	<1	111%	70%	130%	101%	60%	130%	109%	60%	130%
Pentachlorophenol 1 9330262 < 0.5 NA < 0.5 <td>2-Methyl-4-chlorophenoxyacetic 1 933026 acid (MCPA)</td> <td>52 < 5</td> <td>< 5</td> <td>NA</td> <td><5</td> <td>82%</td> <td>70%</td> <td>130%</td> <td>105%</td> <td>60%</td> <td>130%</td> <td>107%</td> <td>60%</td> <td>130%</td>	2-Methyl-4-chlorophenoxyacetic 1 933026 acid (MCPA)	52 < 5	< 5	NA	<5	82%	70%	130%	105%	60%	130%	107%	60%	130%
Picloram 1 9330262 < 0.05 <0.05 NA < 0.05 105% 70% 130% 82% 60% 13 2,3,4,6-Trichlorophenol 1 9330262 < 0.5	Pentachlorophenol 1 933026	32 < 0.5	< 0.5	NA	< 0.5	81%	70%	130%	106%	60%	130%	119%	60%	130%
2.3.4.6-Tetrachlorophenol 1 9330262 < 0.5	Picloram 1 933026	32 < 0.05	< 0.05	NA	< 0.05	105%	70%	130%	82%	60%	130%	114%	60%	130%
2.4.8-Trichlorophenol 1 9330262 < 0.5	2.3.4.6-Tetrachlorophenol 1 933020	52. < 0.5	< 0.5	NA	< 0.5	85%	70%	130%	97%	60%	130%	89%	60%	130%
Aldrin 1 9342204 < 0.05 < 0.05 NA < 0.05 102% 70% 130% 120% 60% 13 Dieldrin 1 9342204 < 0.05	2.4.6-Trichlorophenol 1 933026	52 < 0.5	< 0.5	NA	< 0.5	83%	70%	130%	95%	60%	130%	102%	60%	130%
Dieldrin 1 9342204 < 0.05 NA < 0.05 109% 70% 130% 116% 60% 13 Methoxychlor 1 9342204 < 0.1	Aldrin 1 934220	4 < 0.05	< 0.05	NA	< 0.05	102%	70%	130%	120%	60%	130%	120%	60%	130%
Methoxychlor 1 9342204 < 0.1 < 0.1 NA < 0.1 111% 60% 130% 123% 70% 13 Phorate 1 9330209 < 0.5	Dieldrin 1 934220	4 < 0.05	< 0.05	NA	< 0.05	109%	70%	130%	116%	60%	130%	87%	60%	130%
Phorate 1 9330209 < 0.5 < 0.5 NA < 0.5 75% 70% 130% 87% 40% 13 Dimethoale 1 9330209 < 1.5	Methoxychlor 1 934220	04 < 0.1	< 0.1	NA	< 0.1	111%	60%	130%	123%	70%	130%	109%	60%	130%
Dimethoate 1 9330209 <1.5 <1.5 NA <1.5 99% 70% 130% 107% 40% 13 Terbufos 1 9330209 <0.7	Phorate 1 93302/	9 < 0.5	< 0.5	NA	< 0.5	75%	70%	130%	87%	40%	130%	79%	40%	130%
Terbufos 1 9330209 <0.7 <0.7 NA <0.7 78% 70% 130% 93% 40% 13 Chlorpyrifos 1 9330209 <1	Dimethoale 1 93302	9 < 1.5	< 1.5	NA	< 1.5	99%	70%	130%	107%	40%	130%	100%	40%	130%
Chlorpyrifos 1 9330209 < 1 < 1 NA < 1 87% 70% 130% 94% 40% 13 Diazinon 1 9330209 < 1	Ferbufos 1 933020	9 < 0.7	< 0.7	NA	< 0.7	78%	70%	130%	93%	40%	130%	90%	40%	130%
Diazinon 1 9330209 < 1 < 1 NA < 1 86% 70% 130% 88% 40% 13 Malathion 1 9330209 < 1	Chlorpyrifos 1 93302/	9 <1	<1	NA	<1	87%	70%	130%	94%	40%	130%	92%	40%	130%
Malathion 1 9330209 <1 <1 NA <1 70% 70% 130% 91% 40% 13 Parathion 1 9330209 <1	Diazinon 1 933020	9 <1	< 1	NA	<1	86%	70%	130%	88%	40%	130%	82%	40%	130%
Paratition 1 9330209 < 1 < 1 NA < 1 93% 70% 130% 96% 40% 13 Azinophos 1 9330209 <2	Malathion 1 93302i	9 <1	< 1	NA	<1	70%	70%	130%	91%	40%	130%	87%	40%	130%
Azinophos 1 9330209 <2 <2 NA <2 91% 70% 130% 122% 40% 13 Benzo(a)pyrene 1 9355714 < 0.00001	Parathion 1 93302)9 <1	<1	NA	<1	93%	70%	130%	96%	40%	130%	84%	40%	130%
Benzo(a)pyrene 1 9355714 < 0.00001 < 0.00001 NA < 0.00001 75% 50% 140% 115% 50% 14 Cyanazine 1 9332565 <1	Azinophos 1 933020	19 <2	< 2	NA	<2	91%	70%	130%	122%	40%	130%	107%	40%	130%
Cyanazine 1 9332565 < 1 < 1 NA < 1 81% 50% 140% 110% 50% 14 Vinyl Chloride 1 9340643 < 0.6	Benzo(a)ovrene 1 93557	4 < 0.00001	< 0.00001	NA	< 0.0000*	75%	50%	140%	115%	50%	140%	113%	50%	140%
Vinyl Chlonde 1 9340643 < 0.6 < 0.6 NA < 0.6 71% 70% 130% 76% 60% 14 Chloroethane 1 9340643 < 5 < 5 NA < 5 88% 70% 130% NA 60% 14	Cyanazine 1 933256	35 <1	< 1	NA	< 1	81%	50%	140%	110%	50%	140%	83%	50%	140%
Chloroethane 1 9340643 < 5 < 5 NA < 5 88% 70% 130% NA 60% 14	Vinyl Chloride 1 93406	3 <06	< 0.6	NA	< 0.6	71%	70%	130%	76%	60%	140%	NA	60%	140%
	Chloroethane 1 93406	3 <5	< 5	NA	< 5	88%	70%	130%	NA	60%	140%	NA	60%	140%
1.1-Dichloroethylene 1 9340643 <2 <2 NA <2 94% 70% 130% 71% 60% 14	1.1-Dichloroethylene 1 93406	3 <2	< 2	NA	<2	94%	70%	130%	71%	60%	140%	NA	60%	140%
Methylene Chloride 1 9340543 <2 <2 NA <2 94% 70% 130% 107% 60% 14/ (Jichloromethane)	Methylene Chloride 1 934064 (Dichloromethane)	13 < 2	< 2	NA	<2	94%	70%	130%	107%	60%	140%	NA	60%	140%
Methyl-t-Butyl-Ether (MTBE) 1 9340643 < 2 < 2 NA < 2 100% 60% 140% 121% 60% 14	Methyl-t-Butyl-Ether (MTBE) 1 934064	13 < 2	< 2	NA	<2	100%	60%	140%	121%	60%	140%	NA	60%	140%
Chloroform 1 9340643 <1 <1 NA <1 91% 70% 130% 99% 60% 14	Chloroform 1 93406	3 <1	< 1	NA	<1	91%	70%	130%	99%	60%	140%	NA	60%	140%
1.2-Dichloroethane 1 9340643 <2 <2 NA <2 100% 70% 130% 102% 60% 14	1.2-Dichloroethane 1 93406/	43 <2	< 2	NA	<2	100%	70%	130%	102%	60%	140%	NA	60%	140%

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PROJECT:

SAMPLING SITE:

AGAT WORK ORDER: 18X352285 **ATTENTION TO: James Jenner** SAMPLED BY:

RPT Date: Jul 16, 2018			C	UPLICAT	E	1	REFEREN	NCE MA	TERIAL	METHOD	BLANK	SPIKE	MAT	RIX SPI	KE
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured	Acceptable Limits		Recovery	Acce Lin	ptable nits	Recovery	Acce	ptable nits
and a star of the		Ia			176		value	Lower	Upper		Lower	Upper		Lower	Uppe
Carbon Tetrachloride	1	9340643	<1	< 1	NA	<1	92%	70%	130%	102%	60%	140%	NA	60%	140%
Benzene	1	9340643	<1	< 1	NA.	<1	85%	70%	130%	95%	70%	130%	NA	70%	130%
Trichloroethylene	1	9340643	< 1	< 1	NA	<1	95%	60%	130%	100%	60%	140%	NA	60%	140%
Bromodichloromethane	1	9340643	<1	< 1	NA	<1	90%	70%	130%	97%	60%	140%	NA	60%	140%
Toluene	1	9340643	< 2	< 2	NA	<2	84%	70%	130%	101%	60%	140%	NA	60%	140%
Dibromochloromethane	1	9340643	< 1	< 1	NA	<1	97%	70%	130%	110%	60%	140%	NA	60%	140%
Tetrachloroethylene	1	9340643	<1	<1	NA	< 1	98%	70%	130%	111%	60%	140%	NA	60%	140%
Chlorobenzene	1	9340643	< 1	< 1	NA	<1	88%	70%	130%	103%	60%	140%	NA	60%	140%
Ethylbenzene	1	9340643	< 2	<2	NA	<2	85%	70%	130%	102%	60%	140%	NA	60%	140%
Bromoform	1	9340643	< 1	<1	NA	<1	100%	70%	130%	111%	60%	140%	NA	60%	140%
1.4-Dichlorobenzene	1	9340643	< 1	<1	NA	< 1	95%	70%	130%	109%	60%	140%	NA	60%	140%
1,2-Dichlorobenzene	1	9340643	< 1	< 1	NA	<1	102%	70%	130%	113%	60%	140%	NA	60%	140%

If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

Canadian Drinking Water	MAC Package (Diq./Paraq	.)												
Diquat	9356021	< 5	< 5	NA	<1	95%	60%	140%	86%	60%	140%	87%	60%	140%
Paraqual	9356021	< 1	< 1	NA	< 1	94%	60%	140%	81%	60%	140%	84%	60%	140%
Canadian Drinking Water	MAC Package (Carb./Urea	Pest)												
Aldicarb	TW	< 0.15	< 0.15	NA	< 0.15	104%	60%	140%	105%	60%	140%	NA	60%	140%
Bendiocarb	TVV	< 2	< 2	NA	<2	108%	60%	140%	81%	60%	140%	NA	60%	140%
Carbofuran	TW	< 5	< 5	NA	< 5	108%	60%	140%	81%	40%	130%	NA	30%	150%
Carbaryl	TW	< 5	< 5	NA	< 5	131%	60%	140%	106%	40%	130%	NA	30%	150%
Diuron	TW	< 10	< 10	NA	< 10	100%	60%	140%	98%	60%	140%	NA	30%	150%

Comments: Tap water analysis has been performed as QC sample testing for duplicate and matrix spike due to insufficient sample volume. When the average of the sample and duplicate results is less than 5x the RDL, the Relative Percent Difference (RPD) will be indicated as Not Applicable (NA).

Certified By:

Cmy 1

AGAT QUALITY ASSURANCE REPORT (V1)

Page 16 of 23 AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation for Laboratory Accreditation Inc. (CALA) for specific tests is the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific timking water issts. Accreditation and parameter specific and the scope of accreditation and parameter specific and the scope of accreditation.





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PROJECT:

SAMPLING SITE:

AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:

				Wate	er Ar	nalys	s									
RPT Date: Jul 16, 2018				UPLICATE			REFEREN	ICE MA	TERIAL	METHOD	BLANK	SPIKE	MATRIX SPIKE			
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured	Acceptable Limits		Recovery	Acce	ptable nits	Recovery	Acceptat Limits		
1917 - 00-0-0		Id			20	1	Value	Lower	Upper		Lower Upper			Lower	Uppe	
Canadian Drinking Water MA	C Package (M	etals, Hg 8	Inorgani	cs)	1	100		-					1.00			
Total Aluminum	9341819		12	<10	NA	< 10	106%	80%	120%	111%	80%	120%	111%	70%	130%	
Total Antimony	9341819		<2	<2	NA	< 2	90%	80%	120%	105%	80%	120%	89%	70%	130%	
Total Arsenic	9341819		40	39	2.1%	<2	98%	80%	120%	103%	80%	120%	NA	70%	130%	
Total Barium	9341819		17	15	NA	< 5	100%	80%	120%	104%	80%	120%	90%	70%	130%	
Total Boron	9341819		11	10	NA	< 5	109%	80%	120%	112%	80%	120%	84%	70%	130%	
Total Cadmium	9341819		< 0.3	<0.3	NA	< 0.3	97%	80%	120%	99%	80%	120%	83%	70%	1309	
Total Chromium	9341819		5	4	NA	<2	91%	80%	120%	97%	80%	120%	96%	70%	130%	
Total Copper	9341819		341	339	0.8%	<2	94%	80%	120%	101%	80%	120%	NA	70%	130%	
Total Iron	9341819		663	671	1.2%	< 50	101%	80%	120%	97%	80%	120%	NA	70%	130%	
Total Lead	9341819		25.1	23.4	7.1%	< 0.5	105%	80%	120%	109%	80%	120%	NA	70%	130%	
Total Manganese	9341819		157	155	1.5%	< 2	102%	80%	120%	109%	80%	120%	NA	70%	130%	
Total Selenium	9341819		7	7	NA	<2	105%	80%	120%	111%	80%	120%	NA	70%	130%	
Total Uranium	9341819		<0.1	<0.1	NA	< 0.1	98%	80%	120%	103%	80%	120%	98%	70%	130%	
Total Zinc	9341819		263	258	1.9%	< 5	88%	80%	120%	93%	80%	120%	NA	70%	130%	
Total Sodium	9341819		360	369	2.5%	< 0.1	103%	80%	120%	107%	80%	120%	NA	70%	130%	
Mercury	1	9340672	<0.026	<0.026	NA	< 0.05	100%	80%	120%		80%	120%	100%	70%	130%	
pH	9340935		7.74	7.70	0.5%	<	102%	80%	120%	NA	80%	120%	NA	80%	120%	
Turbidity	9340641		49.1	50.6	3.0%	< 0.1	96%	80%	120%	NA			NA			
True Color	9340641		6	<5	NA	< 5	105%	80%	120%	NA			NA			
Chloride	1	9340084	9	9	0.0%	< 1	91%	80%	120%	NA	80%	120%	86%	80%	120%	
Fluoride	Ť.	9340084	<0.12	<0.12	NA	< 0.12	96%	80%	120%	NA	80%	120%	94%	80%	120%	
Nitrate as N	1	9340084	2.80	2.78	0.7%	< 0.05	96%	80%	120%	NA	80%	120%	NA	80%	120%	
Sulphate	1	9340084	4	4	NA	<2	96%	80%	120%	NA	80%	120%	89%	80%	120%	
Total Dissolved Solids	9342204	9342204	170	176	3.5%	< 5	90%	80%	120%							
Bromate	1	9340084	<0.01	<0.01	NA	< 0.01	106%	70%	130%	NA	70%	130%	97%	70%	130%	
Chlorate	1	9340084	<0.02	<0.02	NA	< 0.02	103%	70%	130%	NA	70%	130%	101%	70%	130%	
Chlorite	1	9340084	<0.02	<0.02	NA	< 0.02	100%	70%	130%	NA	70%	130%	96%	70%	130%	
Sulphide	9349906		<0.05	<0.05	NA	< 0.05	99%	80%	120%	100%	85%	115%	100%	70%	130%	
Cyanide, Free	9351696		<0.002	<0.002	NA	< 0.002	99%	90%	110%	95%	90%	110%	98%	70%	130%	

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

 Total Metals - Uranium
 9341819
 <0.1</th>
 <0.1</th>
 NA
 < 0.1</th>
 98%
 80%
 120%
 103%
 98%
 70%
 130%

 Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

 </

Chloramines

Chloramines - Total 1 9342302 <0.50 <0.50 NA < 0.50 NA 100% 100% NA 100% 100% NA 100% 100% NA 100% 100%

AGAT QUALITY ASSURANCE REPORT (V1) Page 17 of 23 AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests
listed on the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) of specific drinking water
lests. Accreditation and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The lests in this report may
not necessarily be included in the scope of accreditation.





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY	
PROJECT:	
SAMPLING SITE:	

AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:

		V	Vater	Ana	lysis	(Co	ntinu	ed)								
RPT Date: Jul 16, 2018				DUPLICATE			REFERENCE MATERIAL			METHOD	BLANK	SPIKE	MATRIX SPIKE			
PARAMETER Batch Sample Dup #1 Dup #2 RPD M	Method Blank	Measured	Acceptable Limits		Recovery	Acceptable Limits		Recovery	Acce	eptable mits						
		Id		2.6.2		1000	Value	Lower	Upper		Lower	Upper		Lower	Upper	

Laure Bater Certified By: AGAT QUALITY ASSURANCE REPORT (V1) Page 18 of 23 AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation for Laboratory Accreditation Inc. (CALA) for specific tests is the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific timking water issts. Accreditation and parameter specific accredited listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation. Results relate only to the items tested and to all the items tested



Method Summary

CLIENT NAME: MUNICIPALITY OF A PROJECT: SAMPLING SITE:	ANNAPOLIS COUNTY	AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:							
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE						
Food Chemistry Analysis									
Glyphosate	ORG-100-5115F	MA.403-GLYAMP 1.0 Modifée	HPLC						
Miscellaneous Analysis									
Radionuclides - Gross Alpha									
Radionuclides - Gross Bela									
Nitriloacetic Acid (NTA)									
Microcystin - LR									
N-Nitrosodimethylamine (NDMA)		EPA SW846-8270	GC/MS						

AGAT METHOD SUMMARY (V1)

Results relate only to the items tested and to all the items lested

Page 19 of 23





Method Summary

CLIENT NAME: MUNICIPALITY OF AN	NAPOLIS COUNTY	
PROJECT:		
SAMPLING SITE:		
PARAMETER	AGAT S.O.P	L
Trace Organics Analysis		-

AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:

PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE			
Trace Organics Analysis		Sector and the sector sector is				
Aldicarb	ORG-91-5101	EPA SW-632 531.1 & MOE E3389	HPLC			
Bendiocarb	diocarb ORG-91- 5101 EPA SW-632 531.1 & MO					
Carbofuran	ORG-91-5101	EPA SW-632 531.1 & MOE E3389	HPLC			
Carbaryl	ORG-91-5101	EPA SW-632 531.1 & MOE E3389	HPLC			
Diuron	ORG-91-5101	EPA SW-632 531.1 & MOE E3389	HPLC			
Diquat	ORG-91-5102	EPA 549.1	HPLC			
Paraquat	ORG-91-5102	EPA 549.1	HPLC			
Chloroacetic Acid	ORG-120-5110	EPA 552.3	GC/ECD			
Bromoacetic Acid	ORG-120-5110	EPA 552.3	GC/ECD			
Dichloroacetic Acid	ORG-120-5110	EPA 552.3	GC/ECD			
Trichloroacetic Acid	ORG-120-5110	EPA 552.3	GC/ECD			
Bromochloroacetic Acid	ORG-120-5110	EPA 552.3	GC/ECD			
Dibromoacetic Acid	ORG-120-5110	EPA 552.3	GC/ECD			
Haloacetic Acids	ORG-120-5110	EPA 552.3	GC/ECD			
2-Bromobutanoic acid	ORG-120-5110	EPA 552.3	GC/ECD			
Bromoxynil	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
Dicamba	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
2,4-Dichlorophenol	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
2,4-Dichlorophenoxyacetic acid (2,4-D)	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
Diclofop Methyl	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
Dinoseb	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
2-Methyl-4-chlorophenoxyacetic acid (MCPA)	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
Pentachlorophenol	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
Picloram	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
2,3,4,6-Tetrachlorophenol	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
2,4,6-Trichlorophenol	ORG-120-5111	modified from EPA SW846 8151A & EPA 515.1	GC/ECD			
Aldrin	ORG-120-5108	Based on EPA SW-846/6510 C-8080-8081 A	GC/ECD			
Dieldrin	ORG-120-5108	Based on EPA SW-846/6510 C-8080-8081 A	GC/ECD			
Aldrin + Dieldrin	ORG-120-5108	Based on EPA SW-846/6510 C-8080-8081 A	GC/ECD			
Methoxychlor	ORG-120-5108	Based on EPA SW-846/6510 C-8080-8081 A	GC/ECD			
Phorate	rate ORG-120-6112 modified from EPA SW-846 3510C/8141A/8270C					
Dimethoate	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS			
Terbufos	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS			
Chlorpyrifos	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS			

AGAT METHOD SUMMARY (V1)

Results relate only to the items lested and to all the items lested

Page 20 of 23

CBCL



Method Summary

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PROJECT: SAMPLING SITE: AGAT WORK ORDER: 18X352285 ATTENTION TO: James Jenner SAMPLED BY:

Origin Linto Offe.							
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE				
Diazinon	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS				
Malathion	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS				
Parathion	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS				
Azinophos	ORG-120-6112	modified from EPA SW-846 3510C/8141A/8270C	GC/MS				
Benzo(a)pyrene	ORG-120-5104	EPA SW846/3510/8270C	GC/MS				
Trifluralin	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Simazine	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Atrazine	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Atrazine + N-dealkylated metabolites	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Metribuzin	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Cyanazine	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Metolachior	ORG-120-6113	EPA SW-846 3510C/8270C and MOE E3121	GC/MS				
Vinyl Chloride	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Chloroethane	VOL-120-5001	EPA SW-846 5030B/8260B	GC/MS				
1,1-Dichloroethylene	VOL-120-5001	EPA SW-846 5030B/8260B	GC/MS				
Methylene Chloride (Dichloromethane)	VOL-120-5001	EPA SW-846 5030B/8260B	GC/MS				
Methyl-t-Butyl-Ether (MTBE)	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Chloroform	VOL-120-5001	EPA SW-846 5030B/8260B	GC/MS				
1,2-Dichloroethane	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Carbon Tetrachloride	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Benzene	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Trichloroethylene	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Bromodichloromethane	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Toluene	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Dibromochloromethane	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Tetrachloroethylene	VOL-120-5001	EPA SW-846 5230B & 8260	(P&T)GC/MS				
Chlorobenzene	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Ethylbenzene	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Bromoform	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
Xylenes (Total)	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
1.4-Dichlorobenzene	VOL-120-5001	EPA SW846 5230B/8260	GC/MS				
1,2-Dichlorobenzene	VOL-120-5001	EPA SW-846 5030B/8260B	GC/MS				
Total Trihalomethanes	VOL-120-5001	EPA SW846 5230/8260	GC/MS				
Toluene-d8	VOL-120-5001	EPA SW846 5030B/8260B	GC/MS				
4-Bromofluorobenzene	VOL-120-5001	EPA SW846 5030B/8260B	GC/MS				

AGAT METHOD SUMMARY (V1)

Results relate only to the items tested and to all the items lested

Page 21 of 23



Appendices



Method Summary

CLIENT NAME: MUNICIPALITY OF PROJECT:	ANNAPOLIS COUNTY	AGAT WORK OF ATTENTION TO:	RDER: 18X352285 James Jenner
SAMPLING SITE:		SAMPLED BY:	
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE
Water Analysis			
Total Aluminum	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Antimony	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Total Arsenic	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Barium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Boron	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Cadmium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Chromium	MET121-6104 & MET-121-6105	modilied from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Copper	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Iron	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Lead	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Manganese	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Selenium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Uranium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Zinc	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Sodium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Mercury	INOR-121-6100 & INOR-121-6107	SM 3112 B	CV/AA
pH	INOR-121-6001	SM 4500 H+B	PC TITRATE
Turbidity	INOR-121-6022	SM 2130 B	NEPHELOMETER
True Color	INOR-121-6014	SM 2120 C	NEPHELOMETER
Chloride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Fluoride	INOR-121-6005	SM 4110 B	ION CHROMATOGRAPH
Nitrate as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Sulphate	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Total Dissolved Solids	INOR-121-6024, 6025	SM 2540C, D	GRAVIMETRIC
Bromate	INOR-121-6005	SM 4110 B	ION CHROMATOGRAPH
Chlorate	INOR-121-6005	SM 4110 B	ION CHROMATOGRAPH
Chlorite	INOR-121-6005	SM 4110 B	ION CHROMATOGRAPH
Sulphide	INOR-93-6054	SM 4500 S2- D	SPECTROPHOTOMETER
Cyanide, Free Chloramines - Total	INOR-93-6052	MOE CN-3015 & SM 4500 CN-1	TECHNICON AUTO ANALYZER

AGAT METHOD SUMMARY (V1)

Results relate only to the items lested and to all the items lested

Page 22 of 23



	auorai	Ories webearth.ag	atlab	s.com	• w	ww.a	B3 gatia	B 1	M2	Arriv Hold	al Te Tim T Job	mpe e:	nber	re: /	2.5	5 /	3.1	. 1	3.2	5
ain of Custody Record	10	P13	02.40	0.07.	10.	P. 30		0.0		No	es:	-			-	-		-		
port Information umpany: Soundly of Annapolis untact: Soundly of Annapolis idress:	Report in I. Name: Email: Email: Email: Regulato Clast Gu	1. Name: JAMPS bomer Email: Some Composition of the second secon						Single Sample per page Multiple Samples per page Excel Fromat Included				Turnaround Time Required (TAT) Regular TAT Do to 7 working days Rush TAT Same day 1 day 2 days 3 days Date Required:								
SAT Quotation: asse Note: If quotation number is not provided client will be billed full price for analysis	Tier	1 Res Pot 2 Com N/Pot		Coarse Fine		Drini Reg.	king V	Vate	San	nple: Ares INO										
ompany:	CCME	CDWQ CDWQ CANACTER CONT. Sites	sted/Preserved Water Analysis	1.Total 🗆 Diss 🗆 Available		E CBOD	SSV D SOLD		sphorus	PH/BTEX (PIRI) [] Iow level	PH/BTEX Fractionation	WS TPH/BTEX					CP/A CMPN CMF	C Pseudomonas	IMAC	hanlen
Sample Identification Date/Time Sampled Sample	# Containers	Comments - Site/Sample Info. Sample Containment	Field Filt	Metals: [Mercury	008 0	D TSS	TKN	Total Phi	Phenols Ther 1: T	Tier 2: T	CCME-C	200	HAA	PAH	PCB	TC + EC	Encal C	Other:	Other:
Iswn Hall Treated Jun 18/18 locan W2 Raw Jun 15/18 2:10pm DW2 June 18/18 11:20pm PW3 7'' 11:00pm PSterrige Tark ''' //:35pm	30 30 1 1																	1		151
																				,
nstes Relinquished By (Mint Name):	nime NISUS	Sanging Received by (Print Harnest:	1		-			Dete/T	1 7- j	Eur	1.	Pink (ору - Сору	Cilen	t J	Pa	nge		of	

APPENDIX F

Last Round of Sampling Data for *GMPDWS*





CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PO Box 100 Annapolis Royal, NS B0S1A0 (902) 532-3141 **ATTENTION TO: James Jenner** PROJECT: Health Canada Lead AGAT WORK ORDER: 21X789410 WATER ANALYSIS REVIEWED BY: Ashley Dussault, Report Writer DATE REPORTED: Aug 30, 2021 PAGES (INCLUDING COVER): 10 VERSION*: 1

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

"Not	otes	
Disc	claimer:	the first a complete back to the first second
	All work conducted herein has been done using accepted standard protoc	ols, and generally accepted practices and methods. AGAT test methods may
	All samples will be disposed of within 30 days after receipt unless a Long	Term Storage Agreement is signed and returned. Some specialty analysis may
	be exempt, please contact your Client Project Manager for details. AGAT's liability in connection with any delay, performance or non-perform	ance of these services is only to the Client and does not extend to any other
	third party. Unless expressly agreed otherwise in writing, AGAT's liability i	is limited to the actual cost of the specific analysis or analyses included in the
	This Certificate shall not be reproduced except in full, without the written a	approval of the laboratory
	The test results reported herewith relate only to the samples as received I	by the laboratory.
	merchantability, fitness for a particular purpose, or non-infringement. AGA contained in this document.	T assumes no responsibility for any errors or omissions in the guidelines

All reportable information as specified by ISO/IEC 17025:2017 is available from AGAT Laboratories upon request. .

AGAT Laboratories (V1)

E.

lation of Professional Engineers and Geoscientists of Alberta

Page 1 of 10

Member of: Association of Professional Engineers and Geoscientists of All (APECA) Western Enviro-Agricultural Laboratory Association (WEALA) Environmental Services Association of Alberta (ESAA)

Page 1 of 10 AGAT Laboratories is accreditient to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation fnc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation. Measurement Uncertainty is not taken into consideration when stating conformity with a specified requirement.





Certificate of Analysis

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

AGAT WORK ORDER: 21X789410 PROJECT: Health Canada Lead ATTENTION TO: James Jenner SAMPLED BY:

			Hea	alth Canada	Lead Sam	oling - Drin	king Water				
DATE RECEIVED: 2021-08-18								0	DATE REPORT	ED: 2021-08-30	
Barameter	Unit	SAMPLE DES SAM DATE	CRIPTION: PLE TYPE: SAMPLED:	61 Church St Water 2021-08-17 08:14 2864087	154 Church St Water 2021-08-17 06:45 2865051	63 Church St Water 2021-08-17 06:20 2865053	419 Granville St Water 2021-08-17 07:02 2865053	4187 Charlton Corner Water 2021-08-17 06:10 2865054	165 Jeffery St Water 2021-08-17 07:40 285055	54 Rectory St Water 2021-08-17 06:30 2865056	183 CentennialDr Water 2021-08-17 06:00 2865057
Total Lead - Health Canada	ug/L	5	0.5	1.1	<0.5	<0.5	<0.5	<0.5	0.9	<0.5	<0.5
		SAMPLE DES SAN DATE	CRIPTION: PLE TYPE: SAMPLED:	25 Cromwell Ct Water 2021-08-17 07:10	16 Bay Rd Water 2021-08-17 07:15						
Parameter	Unit	G/S	RDL	2865058	2865059						
Total Lead - Health Canada	ug/L	5	0.5	<0.5	<0.5						

Comments:

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard: Refors to Canadian Drinking Water Quality - updated 2021-03 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation. Analysis performed at AGAT Halifax (unless marked by *)

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By:

Results relate only to the items tested. Results apply to samples as received.

Page 2 of 10

de

Schley Diss

CBCL



Certificate of Analysis AGAT WORK ORDER: 21X789410 PROJECT: Health Canada Lead ATTENTION TO: James Jenner

SAMPLED BY:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

Standard Water Analysis + Total Metals												
DATE RECEIVED: 2021-08-18	-					DATE REPORTED: 2021-08-30						
		SAMPLE DESC SAMP DATE S	RIPTION: LE TYPE: AMPLED:	Bridgetown Treated Water 2021-08-17 06:45	Bridgetown Raw Water 2021-08-17 06:40							
Parameter	Unit	G/S	RDL	2865063	2865069							
pH		7.0-10.5		7.92	7.79							
Reactive Silica as SiO2	mg/L		0.5	18.7	19.0							
Chloride	mg/L	250 AQ	1	12	10							
Fluoride	mg/L	1.5	0.12	0.17	0.13							
Sulphate	mg/L	500 AO	2	23	24							
Alkalinity	mg/L		5	112	111							
True Color	TCU	15 AO	5.00	<5.00	<5.00							
Turbidity	NTU	1.0	0.5	1.2	0.6							
Electrical Conductivity	umno/cm		1	336	326							
Nitrate + Nitrite as N	mg/L		0.05	0.69	0.85							
Nitrate as N	mg/L	10	0.05	0.69	0.85							
Nitrite as N	mg/L	1.0	0.05	<0.05	<0.05							
Ammonia as N	mg/L		0.03	<0.03	<0.03							
Total Organic Carbon	mg/L		0.5	<0.5	<0.5							
Ortho-Phosphate as P	mg/L		0.01	0.05	0.04							
Total Sodium	mg/L	200 AO	0.1	8.9	8.1							
Total Potassium	mg/L		0.1	0.8	0.8							
Total Calcium	mg/L		0.1	57.3	46.2							
Total Magnesium	mg/L		0.1	2.2	2.2							
Bicarb, Alkalinity (as CaCO3)	mg/L		5	112	111							
Carb. Alkalinity (as CaCO3)	mg/L		10	<10	<10							
Hydroxide	mg/L		5	<5	<5							
Calculated TDS	mg/L	500 AO	1	174	162							
Hardness	mg/L			152	124							
Langelier Index (@20C)	NA			0.12	-0.11							
Langelier Index (@ 4C)	NA			-0.20	-0.43							
Saturation pH (@ 20C)	NA			7.80	7.90							
Saturation pH (@ 4C)	NA			8.12	8.22							

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By:

Results relate only to the items tested. Results apply to samples as received.

Page 3 of 10

de

Jenley Diss



Certificate of Analysis AGAT WORK ORDER: 21X789410 PROJECT: Health Canada Lead ATTENTION TO: James Jenner

SAMPLED BY:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

				Standard V	water Analysis + 1	otal Metals
DATE RECEIVED: 2021-08-18	3					DATE REPORTED: 2021-08-30
10.545		SAMPLE DESC SAMP DATE S	RIPTION: LE TYPE: AMPLED:	Bridgetown Treated Water 2021-08-17 06:45	Bridgetown Raw Water 2021-08-17 06:40	
Parameter	Unit	G/S	RDL	2865063	2865069	
Anion Sum	me/L			3.11	3.06	
Cation sum	me/L			3.45	2.86	
% Difference/ Ion Balance	%			5.3	3.4	
Total Aluminum	ug/L	2900, 100	5	<5	<5	
Total Antimony	ug/L	6	2	<2	<2	
Total Arsenic	ug/L	10	2	2	2	
Total Barium	ug/L	2000	5	205	202	
Total Beryllium	ug/L		2	<2	<2	
Total Bismuth	ug/L		2	<2	<2	
Total Boron	ug/L	5000	5	9	9	
Total Cadmium	ug/L	7	0.09	<0.09	<0.09	
Total Chromium	ug/L	50	1	<1	<1	
Total Cobalt	ug/L		1	<1	<1	
Total Copper	ug/L	2000, 1000	1	11	<1	
Total Iron	ug/L	300 AQ	50	<50	<50	
Total Lead	ug/L	5	0.5	<0.5	<0.5	
Total Manganese	ug/L	120, 20 AO	2	<2	<2	
Total Molybdenum	ug/L		2	<2	<2	
Total Nickel	ug/L		2	3	<2	
Total Phosphorous	mg/L		0.02	0.05	0.05	
Total Selenium	ug/L	50	1	<1	<1	
Total Silver	ug/L		0.1	<0.1	<0.1	
Total Strontium	ug/L	7000	5	236	230	
Total Thallium	ug/L		0.1	<0.1	<0.1	
Total Tin	ug/L		2	<2	<2	
Total Titanium	ug/L		2	<2	<2	
Total Uranium	ug/L	20	0.2	6.8	7.0	
Total Vanadium	ug/L		2	4	4	

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By:

Results relate only to the items tested. Results apply to samples as received.

Page 4 of 10

de

Schley Duss

	agat	Laboratories	
1.1	TR)OR)	Laboratories	

Certificate of Analysis AGAT WORK ORDER: 21X789410

ATTENTION TO: James Jenner

SAMPLED BY:

PROJECT: Health Canada Lead

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

CLIENT NAME: MU PALITY OF ANNAPOLIS COUNTY SAMPLING SITE:

				Standard \	Water Analysis + Total Meta	als
DATE RECEIVED: 2021-08-1	8					DATE REPORTED: 2021-08-30
				Bridgetown	Bridgetown	
		SAMPLE DESC	RIPTION:	Treated	Raw	
		SAMP	LE TYPE:	Water	Water	
- 15 M		DATE S	AMPLED:	2021-08-17 06:45	2021-08-17 06:40	
Parameter	Unit	G/S	RDL	2865063	2865069	
Total Zinc	ug/L	5000 AO	5	<5	<5	

RDL - Reported Detection Limit: G / S - Guideline / Standard: Refers to Canadian Dmking Water Quality - updated 2021-03
 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation.
2865063-2865069 % Difference / Ion Balance, Hardness, Langeler Index, Nitrate + Nitrite, Hydroxide and Saturation pH are calculated parameters. The calculated parameters are non-accredited. The component
parameters of the calculations are accredited.
Analysis performed at AGAT Halifax (unless marked by *)

AGAT CERTIFICATE OF ANALYSIS (V1)

Certified By: Results relate only to the items tested. Results apply to samples as received. de Page 5 of 10

Schley Diss





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY

PROJECT: Health Canada Lead SAMPLING SITE:

AGAT WORK ORDER: 21X789410 **ATTENTION TO: James Jenner** SAMPLED BY:

				Wate	er Ai	nalys	is								
RPT Date: Aug 30, 2021			1	UPLICAT	E	1	REFEREN	CE MA	TERIAL	METHOD	BLANK	SPIKE	MAT	RIX SPI	KE
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured	Acceptable Limits		Recovery	Acce	ptable nits	Recovery	Acce	ptable nits
a standard and a standard a standa	-	Id	1.16.01	1.00		11.000	Value	Lower	Upper		Lower	Upper		Lower	Upper

Total Lead - Health Canada 2882864 <0.5 <0.5 NA <0.5 101% 80% 120% 106% 80% 120% 96% 70% 130%

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

Standard Water Analysis + Total Metals

Reactive Silicg as SiO2 2860511 15.7 15.0 18.8% < 0.5	pH	2865063 2865063	7.92	7.83	1.1%	~	NA	B0%	120%	NA			NA		
Chlonda 2865817 326 326 1.3% <1 8% 80% 120% NA 70% 130% Alkalinity 2865063 361 11 111 1.1% <5	Reactive Silica as SiO2	2860511	15.7	13.0	18.8%	< 0.5	100%	80%	120%	100%	80%	120%	109%	80%	120%
Fluendie 2866817 0.43 0.55 NA <0.12 91% 80% 120% NA 60% 120% NA 60% 120% NA 60% 120% NA 60% 120% NA 70% 130% Alkalinity 2865081 112 111 1.1% <5	Chloride	2865817	326	365	11.3%	< 1	86%	80%	120%	NA	80%	120%	NA	70%	130%
Sulphate 2865817 28 33 15.9% < 2 99% 80% 120% NA 90% 120% NA 70% 130% Alkalinity 2865063 112 111 1.1% <<5	Fluoride	2865817	0.43	0.55	NA	< 0.12	91%	80%	120%	NA	80%	120%	95%	70%	130%
Alkalinity 2865063 112 111 1.1% < 5 87% 80% 120% NA NA True Color 2869711 8.24 8.66 NA <<5	Sulphate	2865817	28	33	15.9%	< 2	99%	B0%	120%	NA	80%	120%	NA	70%	130%
True Color 2859711 8.24 9.66 NA < 55 107% 80% 120% NA NA Turbidity 2866465 1.7 1.9 NA <0.5	Alkalinity	2865063 2865063	112	111	1.1%	< 5	87%	80%	120%	NA			NA		
Turbidiy 2866465 1.7 1.9 NA < 0.5 93% 80% 120% NA NA Electrical Conductivity 2865063 2865063 336 332 1.2% <1	True Color	2859711	8.24	9.66	NA	< 5	107%	80%	120%	92%	80%	120%	NA		
Electrical Conductivity 2865063 2865017 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05 <0.05	Turbidity	2866465	1.7	1.9	NA	< 0.5	93%	80%	120%	NA			NA		
Nitrate as N 2865817 <0.05 <0.05 NA <0.05 80% 80% 120% NA 80% 120% 89% 70% 130% Nitrate as N 2865817 <0.05	Electrical Conductivity	2865063 2865063	336	332	1.2%	< 1	104%	90%	110%	NA			NA		
Ninte as N 2865817 0.05 0.11 NA < 0.05 86% 80% 120% NA 80% 120% 87% 70% 130% Ammonia as N 2871162 <0.03	Nitrate as N	2865817	<0.05	<0.05	NA	< 0.05	80%	80%	120%	NA	80%	120%	89%	70%	130%
Ammonia as N 2871162 <0.03 <0.03 NA <0.03 98% 80% 120% 91% 80% 120% 122% 70% 130% Total Organic Carbon 2865063 2855063 <0.5	Nitrite as N	2865817	<0.05	0.11	NA	< 0.05	86%	80%	120%	NA	80%	120%	87%	70%	130%
Total Organic Carbon 2865063 2865063 <0.5 NA <0.5 96% 80% 120% NA 80% 120% MA 70% 130% Total Sodium 2869402 2.4 2.6 6.2% <0.1	Ammonia as N	2871162	<0.03	<0.03	NA	< 0.03	98%	80%	120%	91%	80%	120%	122%	70%	130%
Ortho-Phosphate as P 2859711 0.02 0.02 NA < 0.01 101% 80% 120% 110% 80% 120% NA 70% 130% Total Sodium 2869402 32.6 33.1 1.5% < 0.1	Total Organic Carbon	2865063 2865063	<0.5	<0,5	NA	<0.5	96%	80%	120%	NA	80%	120%	80%	80%	120%
Total Sodium 2869402 32.6 33.1 1.5% < 0.1 100% 80% 120% 88 80% 120% NA 70% 130% Total Potassium 2869402 2.4 2.6 6.2% <0.1	Ortho-Phosphate as P	2859711	0.02	0.02	NA	< 0.01	101%	80%	120%	101%	80%	120%	110%	80%	120%
Total Potassium 2869402 2.4 2.6 6.2% < 0.1 111% 80% 120% NA 70% 130% Total Calcium 2869402 29.0 27.8 4.3% <0.1	Total Sodium	2869402	32.6	33.1	1.5%	< 0.1	100%	80%	120%	98%	80%	120%	NA	70%	130%
Total Calcium 2869402 29.0 27.8 4.3% < 0.1 108% 80% 120% 106% 80% 120% NA 70% 130% Total Magnesium 2869402 4.1 4.3 4.0% <0.1	Total Potassium	2869402	2.4	2.6	6.2%	< 0.1	111%	80%	120%	109%	80%	120%	NA	70%	130%
Total Magnesium 2869402 4.1 4.3 4.0% < 0.1 100% 80% 120% 95% 80% 120% NA 70% 130% Bicarb. Alkalinity (as CaCO3) 2865063 2865063 <112 111 1.1% <5 NA 80% 120% NA NA Carb. Alkalinity (as CaCO3) 2865063 <10 <10 NA <10 NA 80% 120% NA NA Hydroxide 2865063 2865063 <5 <5 NA <5 NA 80% 120% NA NA Total Aluminum 2869402 16 16 NA <5 NA 80% 120% NA NA Total Aluminum 2869402 <2 <2 NA <2 91% 80% 120% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03% 03%	Total Calcium	2869402	29.0	27.8	4.3%	< 0.1	108%	80%	120%	106%	80%	120%	NA	70%	130%
Bicarb. Alkalinity (as CaCO3) 2865063 2865063 112 111 1.1% <5 NA 80% 120% NA NA Carb. Alkalinity (as CaCO3) 2865063 2865063 <10	Total Magnesium	2869402	4.1	4.3	4.0%	< 0.1	100%	80%	120%	95%	80%	120%	NA	70%	130%
Carb. Alkalinity (as CaCO3) 2865063 2865063 <10 <10 NA <10 NA 80% 120% NA NA Hydroxide 2865063 2865063 <5	Bicarb. Alkalinity (as CaCO3)	2865063 2865063	112	111	1.1%	< 5	NA	80%	120%	NA			NA		
Hydroxide 2865063 2865063 NA < NA 80% 120% NA NA Total Aluminum 2869402 16 16 NA <	Carb. Alkalinity (as CaCO3)	2865063 2865063	<10	<10	NA	< 10	NA	80%	120%	NA			NA		
Total Aluminum 2869402 16 16 NA < 5 113% 80% 120% 103% 70% 130% Total Antimony 2869402 <2	Hydroxide	2865063 2865063	<5	<5	NA	< 5	NA	80%	120%	NA			NA		
Total Antimony 2869402 <2 <2 <2 NA <2 91% 80% 120% 103% 80% 120% 94% 70% 130% Total Arsenic 2869402 <2	Total Aluminum	2869402	16	16	NA	< 5	113%	80%	120%	108%	80%	120%	103%	70%	130%
Total Arsenic 2869402 <2 <2 <2 NA <2 99% 80% 120% 105% 80% 120% 96% 70% 130% Total Banum 2869402 88 94 6.9% <5	Total Antimony	2869402	<2	<2	NA	<2	91%	80%	120%	103%	80%	120%	94%	70%	130%
Total Barium 2869402 88 94 6.9% <5 99% 80% 120% 103% 80% 120% NA 70% 130% Total Baryllum 2869402 <2	Total Arsenic	2869402	<2	<2	NA	< 2	99%	80%	120%	105%	80%	120%	96%	70%	130%
Total Beryllium 2869402 <2 <2 <2 NA <2 114% 80% 120% 94% 70% 130% Total Bismuth 2869402 <2	Total Barium	2869402	88	.94	6.9%	< 5	99%	80%	120%	103%	80%	120%	NA	70%	130%
Total Bismuth 2869402 <2 <2 <2 NA <2 103% 80% 120% 109% 80% 120% 92% 70% 130% Total Boron 2869402 9 10 NA <5	Total Beryllium	2869402	<2	<2	NA	< 2	114%	80%	120%	111%	80%	120%	94%	70%	130%
Total Boron 2869402 9 10 NA <5 96% 80% 120% 93% 80% 120% 83% 70% 130% Total Cadmium 2869402 <0.09	Total Bismuth	2869402	<2	<2	NA	<2	103%	80%	120%	109%	80%	120%	92%	70%	130%
Total Cadmium 2869402 <0.09 <0.09 <0.09 97% 80% 120% 90% 70% 130% Total Chromium 2869402 <1	Total Boron	2869402	9	10	NA	< 5	96%	80%	120%	93%	80%	120%	83%	70%	130%
Total Chromium 2869402 <1 <1 NA <1 96% 80% 120% 99% 80% 120% 103% 70% 130% Total Cobalt 2869402 <1	Total Cadmium	2869402	<0.09	<0.09	NA	< 0.09	97%	80%	120%	100%	80%	120%	90%	70%	130%
Total Cobalt 2669402 <1 <1 NA <1 98% 80% 120% 100% 80% 120% 105% 70% 130% Total Copper 2869402 4 4 NA <1	Total Chromium	2869402	<1	<1	NA	<1	96%	80%	120%	99%	80%	120%	103%	70%	130%
Total Copper 2869402 4 NA <1 99% 80% 120% 102% <	Total Cobalt	2869402	<1	<1	NA	<1	98%	80%	120%	100%	80%	120%	105%	70%	130%
Total Iron 2869402 66 54 NA < 50 97% 80% 120% 97% 80% 120% 104% 70% 130%	Total Copper	2869402	4	4	NA	< 1	99%	80%	120%	102%	80%	120%	102%	70%	130%
	Total Iron	2869402	66	54	NA	< 50	97%	80%	120%	97%	80%	120%	104%	70%	130%
Totai Lead 2869402 <0.5 <0.5 NA < 0.5 101% 80% 120% 105% 80% 120% 93% 70% 130%	Total Lead	2869402	<0.5	<0.5	NA	< 0.5	101%	80%	120%	105%	80%	120%	93%	70%	130%
Total Manganese 2869402 6 NA <2 97% 80% 120% 99% 80% 120% 104% 70% 130%	Total Manganese	2869402	6	6	NA	< 2	97%	80%	120%	99%	80%	120%	104%	70%	130%

AGAT QUALITY ASSURANCE REPORT (V1) Page 6 of 10 Results relate only to the items tested. Results apply to samples as received.





Quality Assurance

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY PROJECT: Health Canada Lead

SAMPLING SITE:

AGAT WORK ORDER: 21X789410 **ATTENTION TO: James Jenner** SAMPLED BY:

ATERIAL eptable	METHOD	BLAN	1 Canada	1			
eptable			K SPIKE	MATRIX SPIKE			
mits	Recovery	Acceptable Limits F		Recovery	Acce	ptable mits	
r Upper		Lower	Upper		Lower	Upper	
120%	97%	80%	120%	101%	70%	130%	
120%	99%	80%	120%	103%	70%	130%	
120%	87%	80%	120%	84%	70%	130%	
120%	104%	80%	120%	90%	70%	130%	
120%	97%	80%	120%	87%	70%	130%	
120%	87%	80%	120%	NA	70%	130%	
120%	104%	80%	120%	93%	70%	130%	
120%	99%	80%	120%	97%	70%	130%	
120%	92%	80%	120%	96%	70%	130%	
120%	102%	80%	120%	97%	70%	130%	
120%	94%	80%	120%	105%	70%	130%	
120%	100%	80%	120%	96%	70%	130%	
	ptable nits Upper 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120%	ptable Recover, Upper 97% 120% 97% 120% 97% 120% 87% 120% 104% 120% 97% 120% 97% 120% 97% 120% 97% 120% 97% 120% 97% 120% 99% 120% 102% 120% 102% 120% 102% 120% 100%	Patable Acc. Upper Acc. 120% 97% 80% 120% 99% 80% 120% 87% 80% 120% 97% 80% 120% 97% 80% 120% 97% 80% 120% 97% 80% 120% 97% 80% 120% 99% 80% 120% 99% 80% 120% 92% 80% 120% 92% 80% 120% 92% 80% 120% 92% 80% 120% 94% 80% 120% 94% 80%	ptable Recovery Lower Limits Upper 120% 97% 80% 120% 120% 99% 80% 120% 120% 99% 80% 120% 120% 87% 80% 120% 120% 104% 80% 120% 120% 97% 80% 120% 120% 97% 80% 120% 120% 97% 80% 120% 120% 99% 80% 120% 120% 104% 80% 120% 120% 104% 80% 120% 120% 99% 80% 120% 120% 99% 80% 120% 120% 99% 80% 120% 120% 99% 80% 120% 120% 92% 80% 120% 120% 94% 80% 120% 120% 100% 80% 120%	Patabis Acceptabis Upper Acceptabis 120% 97% 80% 120% 101% 120% 99% 80% 120% 103% 120% 99% 80% 120% 103% 120% 87% 80% 120% 84% 120% 104% 80% 120% 87% 120% 97% 80% 120% 97% 120% 97% 80% 120% 97% 120% 95% 80% 120% 93% 120% 92% 80% 120% 97% 120% 92% 80% 120% 97% 120% 92% 80% 120% 97% 120% 92% 80% 120% 97% 120% 92% 80% 120% 97% 120% 92% 80% 120% 97% 120% 94% 80% 120% 95%	ptable (upper) Acceptable Limits Recovery Acceptable Limits Recovery Acceptable Limits Recovery Acceptable Limits Recovery Acceptable Limits Recovery Acceptable Limits Recovery Acceptable Limits Acceptable Limits Recovery Acceptable Limits Acceptable Limits	

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

Certified By:

Page 7 of 10

They

Filey

AGAT QUALITY ASSURANCE REPORT (V1) AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation for Laboratory Accreditation Inc. (CALA) for specific tests its accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific tests its accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific tests in the report may not necessarily be included in the scope of accreditation. RPDs calculated using raw data. The RPD may not be reflective of duplicate values shown, due to rounding of final results. Results relate only to the items tested. Results apply to samples as received.



Method Summary

CLIENT NAME: MUNICIPALITY OF PROJECT: Health Canada Lead	ANNAPOLIS COUNTY	AGAT WORK ORDER: 21X789410 ATTENTION TO: James Jenner SAMPLED BY:						
SAMPLING SITE:	10170.00	SAMPLED BY:						
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE					
Water Analysis								
Total Lead - Health Canada	MET-121-6104 &	B/SM 3030 D	ICP-MS					
рН	INOR-121-6001	SM 4500 H+B	PCTITRATE					
Reactive Silica as SiO2	INOR-121-6027	SM 4500-SIO2 F	COLORIMETER					
Chloride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH					
Fluoride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH					
Sulphate	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH					
Alkalinity	INOR-121-6001	SM 2320 B						
True Color	INOR-121-6008	SM 2120 B	LACHAT FIA					
Turbidity	INOR-121-6022	SM 2130 B	NEPHELOMETER					
Electrical Conductivity	INOR-121-6001	SM 2510 B	PC TITRATE					
Nitrate + Nitrite as N	INORG-121-6005	SM 4110 B	CALCULATION					
Nitrate as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH					
Nitrite as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH					
Ammonia as N	INOR-121-6047	SM 4500-NH3 H	COLORIMETER					
Total Organic Carbon	INOR-121-6026	SM 5310 B	TOC ANALYZER					
Odho-Phosphate as P	INOR-121-6012	SM 4500-P G	COLORIMETER					
Total Sodium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Potassium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Calcium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Magnesium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Bicarb, Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE					
Carb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE					
Hydroxide	INORG-121-6001	SM 2320 B	PC-TITRATE					
Calculated TDS	CALCULATION	SM 1030E	CALCULATION					
Hardness	CALCULATION	SM 2340B	CALCULATION					
Langelier Index (@20C)	CALCULATION	CALCULATION	CALCULATION					
Langelier Index (@ 4C)	CALCULATION	CALCULATION	CALCULATION					
Saturation pH (@ 20C)	CALCULATION	CALCULATION	CALCULATION					
Saturation pH (@ 4C)	CALCULATION	CALCULATION	CALCULATION					
Anion Sum	CALCULATION	SM 1030E	CALCULATION					
Cation sum	CALCULATION	SM 1030E	CALCULATION					
% Difference/ Ion Balance	CALCULATION	SM 1030E	CALCULATION					
Total Aluminum	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Fotal Antimony	MET121-6104 & MET-121-6105	SM 3125	ICP-MS					
Total Arsenic	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Barium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Beryllium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Bismuth	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					
Total Boron	MET-121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS					

AGAT METHOD SUMMARY (V1)

Results relate only to the items tested. Results apply to samples as received.

Page 8 of 10

CBCL



Method Summary

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUL	NTY
PROJECT: Health Canada Lead	
SAMPLING SITE:	

AGAT WORK ORDER: 21X789410 ATTENTION TO: James Jenner SAMPLED BY:

PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE				
Total Cadmium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Total Chromium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Fotal Cobalt	MET121-6104 & modified from SM 3125/SM 3030 Dbalt MET-121-6105 B/SM 3030 D		ICP-MS				
fotal Copper	MET121-6104 & modified from SM 3125/SM 3030 MET-121-6105 B/SM 3030 D		ICP-MS				
fotal Iron	on MET121-6104 & modified from SM 3125/SM 3030 MET-121-6105 B/SM 3030 D		ICP-MS				
fotal Lead	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Fotal Manganese	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Fotal Molybdenum	ybdenum MET121-6104 & modified from SM 3125/SM 3030 MET-121-6105 B/SM 3030 D		ICP-MS				
fotal Nickel	al Nickel MET121-6104 & MET-121-6105 B		ICP-MS				
Total Phosphorous	MET-121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Total Selenium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
fotal Silver	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
fotal Strontium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
fotal Thallium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Fotal Tin	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
Fotal Titanium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				
fotal Uranium	m MET121-6104 & modified from SM 3125/SM 3030 MET-121-6105 B/SM 3030 D		ICP-MS				
fotal Vanadium	dium MET121-6104 & modified from SM 3125/SM 3030 MET-121-6105 B/SM 3030 D		ICP-MS				
Fotal Zinc	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS				

AGAT METHOD SUMMARY (V1)

Results relate only to the items tested. Results apply to samples as received.

Page 9 of 10



Chain of Custo	dy Record			webearth.a	902.	.468.	om •	8 = F	v.ag : 90	atla)	8.892	n 4	Hold Time: AGAT Job Number: 21X 789410											
Report Information			Report	nformation (Please print):		-		R	tep	ort F	orma	t	No	tes:										
Commenter Mun of the Co	unty of Annapolis		1 Name	James Jenner						inde (Comple													_
Company:	and the market of		- Email	jjenner@annapoliscounty.ca			_	- E		iet bag	ie ie		Tur			d Ti	me	Dan	line	d (T)	T)	_	_	
Contact: PO BOX 100 S	Caorea St		-	Charles Grant		-	-	16	71 1	ultiple	e Samp	les	-	hai	oun		me	noq	mou	a (17	,			
Address: PO BOX 100 3	-1 BOS LAG		2. Name	cgrant@annapoliscounty.ca		-	-	-	p p	er pag	36 ormat		Reg	ula	TA	T B	15	to 7 v	orki	ng da	ays			
Annapons Roy	al BUS IAU		Email		-	-	_	-11	1	nciude	d		Rus	h T/	AT	E	I Sa	me d	lay	01	L day	0		
Phone: 902-526-0566	Fax: 902-532-	2096	Regulat	ory Requirements (Check):				E] ε	xport						t	12	days		13	3 day	S		
Client Project #: Health	Canada Lead		Z List Gu	List Guidelines on Report Do not list Guidelines on Report									Dat	Re	nuin	-ho								
AGAT Quotation:						700			-	-	-		Dat	ne	quit	·u.		_	_	_		_	_	_
Please Note: If quotation number is	a not provided client will be billed ful	I price for analy	sis.	2 Com N/Pot	Ì		e	D	rinki	ing W	ater Si	amp	le: 🔽	Yes		No	-	alt W	ater :	Sam	ole	T Ye	5 🕅	No
Invoice To	Same	Yes / No	Gas	Fuel Lube				R	eg. N	No.:		-											. trait	
2.0.1.1.1.			CCME	CDWO		T	T	T	1			1	1				T	T	T		T	T	T	T
Company:				ustrial INSEQS-Cont Sites			and						_							4				L
Contact: Amanda Lewis			- Con	mercial HRM 101			9//Sills						leve	c						2		MF		
Address:			- Res	/Park Storm Water			<u>î</u>			12			NOID	natio						N	as		1Cal	L
				AL Waste Water	Devr	hysis	DISS	1.		SV II			(181)	actio	ă					W	ULLION	NUM	due	1
Phone:	Fax:		Sed	liment Other	roso	r Ana		BOD		0	3		EX (P	EX B	1/BTI					A L	endo	0		
PO/Credit Card#:			_		rad/F	Wate		ä		Ê	phor		-VBT	-VBT	S TPI					d D	Ps	form	Sauce	2
Sample Identification	Date/Time Sampled	Sample Matrix	# Containers	Comments - Site/Sample Info. Sample Containment	Field Filte	Standard	Mercury	0 800	PH	D TSS	TKN Total Phos	Phenois	Tier 1: TP	Tier 2: TP.	COME-CM	VOC	WHL	PAH	PCB	TC+ EC	DHPC	Fecal Col	Other:	uniteren u
61 Church St	Aug 17/21 51 Cus		1					1	-		-		1	-					1			Ŀ	0	+
154 Church St	Aug 17/21 5150m		1				1	1			-	t	1	-					1			G	n	t
63 Church St	Aug 17/21 6 214 11		1				1	1				T							T			G	1	T
419 Granville St	Aug 17/21 7 3200		1																			6	7	T
4187 Charlton Corner	Aug 17/21 6 1000		1																T			E.	7	T
165 Jeffery St	Aug 17/21 1:4/000		1																-			6	7	
54 Rectory St	Aug 17/21 200		1															1	T			Ģ	7	
183 Centennial Dr	Aug 17/21 (000)		1																			Ģ	٥	
25 Cromwell Ct	Aug 17/21 7 10001		1	1									1.1									G	2	T
16 Bay Rd	Aug 17/21 -1 -1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1		1	1																		G	21	
Bridgetown Trans	a Aug 17/21 6:43	gm	3			VI	1				1													
Bridgetown Rau	Aug 17/21 6:4	DOM	3			4	1					1	1				-							
Amples Rainquished By (Print Name): Amy Brown		Au	g 17/21	Sarrahau Received By (Print Namin).						Dat	e/Trme			1	Pink	Сору	Clier	1	Pa	age	2	lof		1
Semples Relinquished By (Dign).	~	Date	firms	Samples Placewed By (Sign)	1_	-	1	-	_	Dat	le/Time	_		Y	ellow	Copy	- AG	NT -		971	_	10.9	_	-
1.00		10	Yana	17	5.00	1	1			1123				1.1	100.00	-		1 100	Sec. 1.					

Page 10 of 10

APPENDIX G

Approval to Operate





55 Starrs Rd. Unit 9 Yarmouth NS Canada B5A 2T2 902-742-8985 Р 902-742-7796 F www.novascotia.ca

APPROVAL

Province of Nova Scotia Environment Act, S.N.S. 1994-95, c.1 s.1

APPROVAL HOLDER: MUNICIPALITY OF THE COUNTY OF ANNAPOLISSITE PID:05141973, 05142039

APPROVAL NO: 2010-073601-04

EXPIRY DATE: June 1, 2029

Pursuant to Part V of the *Environment Act*, S.N.S. 1994-95, c.1 s.1 as amended from time to time, approval is granted to the Approval Holder subject to the Terms and Conditions attached to and forming part of this Approval, for the following activity:

Municipal - Water Works - Water Treatment Facility

Paddy joe Mac Millan

Administrator: Paddy-joe MacMillan

Effective Date: June 1, 2019

The Minister's powers and responsibilities under the Act with respect to this Approval have been delegated to the Administrator named above. Therefore, any information or notifications required to be provided to the Minister under this Approval can be provided to the Administrator unless otherwise advised in writing.

Page 1 of 22



TERMS AND CONDITIONS OF APPROVAL

Nova Scotia Environment

Approval Holder: MUNICIPALITY OF THE COUNTY OF ANNAPOLIS

Project: Town of Bridgetown Well field

Site:	s	ite	:
-------	---	-----	---

PID	Civic #	Street Name	Street Type	Community	County
051/1072	507	CHURCH	et.	BRIDGETOWN	ANNAPOLIS
05141975	507	CHURCH	51.	NORTH	COUNTY
051/2030	308	CHURCH	ST	BRIDGETOWN	ANNAPOLIS
00142000	500	CHORON	01.	NORTH	COUNTY

Approval No:	2010-073601-04
File No:	94600-30-YAR-2010-073601

Grid Reference: Easting - 318036, Northing - 4970407

Reference Documents

- Application submitted March 28, 2018 and attachments.
- Previous Approval and Files 2010-073610
- Drawings C01, C02, A01, A02, S01, S02, S03 issued for Review October 20, 2017
- Design Brief Memo dated November 2, 2017
- Level 1 GUDI Screening Bridgetown Production Well #4 dated 28 November 2017 by
- C Walker P.Geo , CBCL
- Bore Hole Log for PW4
- Sketch SK01 dated Nov 2017

1. Definitions

- a. Act means Environment Act. 1994-95, c.1, s.1, and includes, unless the context otherwise requires, the regulations made pursuant to the Act, as amended from time to time.
- b. Administrator means a person appointed by the Minister for the purpose of the

Page 2 of 22



Act, and includes an acting administrator.

- c. CT means disinfectant residual in mg/L multiplied by the contact time in minutes.
- d. Contact Time, denoted as T10, is an effective contact time for disinfection in minutes and represents the time when 10% of the water passes the contact unit; that is 90% of the water remains in the unit and will be exposed to longer disinfection within the unit. T10 can be established by tracer studies or calculated using theoretical hydraulic detention times multiplied by an appropriate baffling factor listed in the "Nova Scotia Treatment Standards for Municipal Drinking Water Systems", as amended from time to time.
- e. Continuous monitoring is sampling of flow through analysis equipment that creates an output signal a minimum of once every five minutes.
- f. Department means the Department of Environment, and the contact for the Department for this approval is:

Nova Scotia Environment Western Region, Yarmouth Office 55 Starrs Road, Unit 9 Yarmouth , NS , B5A 2T2

Phone: (902) 742-8985 Fax: (902) 742-7796

- g. Grab sample means an individual sample collected in less than 30 minutes and which is representative of the substance sampled.
- h. Inadequate Primary Disinfection means water that does not meet the required CT/IT.
- i. Inadequate Secondary Disinfection means water that does not meet the required disinfectant residual in the distribution system.
- j. Log reduction means a negative of the base 10 logarithm of the fraction of pathogens remaining after the treatment process.

log reduction = log removal by physical treatment + log inactivation by disinfection

where log removal by physical treatment is equal to the credit assigned to the filtration technology indicated in the Department's "Nova Scotia Treatment Standards for Municipal Drinking Water Systems", as amended from time to time; and

log inactivation by disinfection is equal to the inactivation which shall be

Page 3 of 22

calculated as defined by the Department's "Nova Scotia Treatment Standards for Municipal Drinking Water Systems", as amended from time to time.

- k. Minister means the Minister of Environment and includes any person delegated the authority of the Minister.
- I. QA/QC means quality assurance and quality control.
- m. Quarterly sampling means samples taken once per quarter with no less than a 45 day interval between sampling events.
- n. Site means a place where a designated activity and/or undertaking is occurring or may occur.

2. Scope

- a. This Approval (the "Approval") relates to the Approval Holder(s) and their application and all documentation submitted to the Department prior to the issuance of this approval for the Water Treatment Facility situated at or near Bridgetown, NS (the "Site").
- b. This Approval supersedes previous Approval number 2010-073601-04 which is now null and void.

3. General

- a. The Approval Holder(s) shall conduct the Designated Activity in accordance with the following provisions:
 - i. The Act, as amended from time to time;
 - ii. Any standard adopted by the Department, as amended from time to time, which includes, but is not limited to the following:
 - The Atlantic Canada Guidelines for the Supply, Treatment, Storage, Distribution and Operation of Drinking Water Supply Systems (2004), as amended from time to time;
 - (b) By January 1, 2020, the Nova Scotia Treatment Standards for Municipal Drinking Water Systems (2012), as amended from time to time;
 - The Guidelines for Monitoring Public Drinking Water Supplies, as amended from time to time;
 - (d) Health Canada's Guidelines for Canadian Drinking Water Quality, as amended from time to time; and
 - (e) Facility Classification Standards (2009), as amended from time to

Page 4 of 22



time.

- b. Nothing in this Approval relieves the Approval Holder(s) of the responsibility for obtaining and paying for all licenses, permits, approvals or authorizations necessary for carrying out the work authorized to be performed by this Approval which may be required by municipal by-laws or provincial or federal legislation. The Minister does not warrant that such licenses, permits, approvals or other authorizations will be issued.
- c. If there is a discrepancy between the reference documents and the terms and conditions of this Approval, the terms and conditions of this Approval shall apply.
- d. Any request for renewal or extension of this Approval is to be made in writing, to the Department, at least ninety (90) days prior to the Approval expiry.
- e. If the Minister cancels or suspends this Approval, the Approval Holder(s) remains subject to the penalty provisions of the Act.
- f. The Approval Holder(s) shall immediately notify the Department of any incidents of non-compliance with this Approval.
- g. The Approval Holder(s) shall advise the Department, in writing, prior to any proposed extensions or modifications to the Site. An amendment to this Approval may be required before implementing any extension or modification.
- h. The Approval Holder(s) shall bear all expenses incurred in carrying out the environmental monitoring required under the terms and conditions of this Approval.
- i. All sampling and analysis must be performed in accordance with the following as amended from time to time: Standard Methods for the Examination of Water and Wastewater, or the analytical methods section of Health Canada's guideline technical document for the parameter of concern. All samples shall be collected by persons trained in appropriate sample collection procedures.
- j. Unless written authorization is received otherwise from the Minister, all samples required by this Approval shall be analyzed by a laboratory that meets the requirements of the Department's "Policy on Acceptable Certification of Laboratories", as amended from time to time.
- k. Notwithstanding the above item, the following parameters may be analyzed at the Site or a laboratory that is not certified:

Alkalinity*, Aluminum Residual*, Chloramines, Chloride Dioxide Residual, Chlorine Residual, Colour, Conductivity*, Fluoride Residual*, Hardness*, Iron*, Manganese*, Methane*, Free Ammonia (as N)*, Ozone Residual, pH, Temperature, Total Organic Carbon, Turbidity and UV Absorbance.

Page 5 of 22
*These parameters must have a Quality Assurance/Quality Control component that includes quarterly confirmation by an accredited laboratory.

- I. The Approval Holder(s) shall ensure that this Approval, or a copy, is kept on Site at all times and that personnel directly involved in the designated activity are made fully aware of the terms and conditions which pertain to this Approval.
- m. Upon any changes to the Registry of Joint Stock Companies information, the Approval Holder(s) shall provide a copy to the Department within five business days.

4. Releases

- a. Releases shall be reported in accordance with the Act.
- b. Releases shall be cleaned up in accordance with the Act.

5. Operation

- a. The Municipal Public Drinking Water Supply has been classified as a Class I water distribution facility.
- b. When it is necessary to use a by-pass to divert water around one or more unit processes, the Approval Holder(s) shall immediately notify the Department and identify the anticipated period of time that the by-pass will be in service.
- c. When it is necessary to use a by-pass to divert water around one or more unit processes, the Approval Holder(s) shall immediately initiate a Boil Water Advisory. The Approval Holder(s) shall maintain the boil advisory until otherwise advised by the Department.
- d. The Approval Holder(s) shall ensure the development and implementation of a cross-connection control program to protect the Municipal Public Drinking Water Supply from contamination due to cross-connections from commercial, institutional, industrial, multi-unit residential, and agricultural facilities, at a minimum, and avoid any cross-connections within the drinking water treatment facility. The program shall be submitted to the Department for review on or before June 1, 2020. Upon review, the Department may require changes to the cross-connection control program.
- e. The Approval Holder(s) shall demonstrate that any Municipal Public Drinking Water Supply component in contact with treated water has been disinfected after construction, repair or maintenance in accordance with ANSI (American National Standards Institute)/AWWA (American Water Works Association) C651 -Disinfection of Water Mains, ANSI/AWWA C653 - Disinfection of Water Treatment Plant, and ANSI/AWWA C652 - Disinfection of Water Storage Facilities, or the latest revisions.

Page 6 of 22

- f. The Approval Holder(s) shall ensure that all chemicals used in the treatment process and all materials contacting the water are of "food grade" quality and meet both the AWWA quality criteria as set out in AWWA standards and the ANSI safety criteria as set out in ANSI standard NSF/60 (for chemical additives) or NSF/61 (for materials). A copy of the appropriate NSF certification is to be kept on Site and is to be available for review immediately upon request by the Department.
- g. The Approval Holder(s) shall discontinue use of any chemical found to have adverse effects on finished water quality limits as prescribed in the Act and/or this Approval.
- h. Emergency Notification Procedures:
 - i. The Approval Holder(s) shall ensure that the emergency notification procedures are reviewed and updated on a yearly basis. The Approval Holder(s) shall document in the annual report what modifications were made to the emergency notification procedures and how the procedures were communicated to staff.
 - ii. A copy of the emergency notification procedures are to be maintained on Site at all times and are to be available for review immediately upon request by the Department.
 - iii. The Approval Holder(s) shall ensure that all employees are trained in accordance with the emergency notification procedures and shall keep a record of training at the facility for a minimum period of five (5) years.
- i. Operations Manual:
 - i. A copy of the operations manual is to be kept on Site at all times and is to be available for review immediately upon request by the Department.
 - ii. The Approval Holder(s) shall ensure that all employees are trained in accordance with the operations manual and shall keep a record of training at the facility for a minimum period of five (5) years.
- j. A set of drawings, incorporating any amendments made from time to time, shall be retained on Site by the Approval Holder(s) for as long as the Municipal Public Drinking Water Supply is kept in operation and are to be available for inspection or review by departmental staff immediately upon request.
- k. The Approval Holder(s) shall establish procedures for receiving and responding to complaints including a reporting system that records and documents what steps were taken to determine the cause of complaint and the corrective measures taken to alleviate the cause and prevent its recurrence.
- I. The Approval Holder(s) shall establish security measures to assure the safety of

Page 7 of 22

the Municipal Public Drinking Water Supply.

m. The Approval Holder(s) shall maintain a written list of the name of each laboratory utilized, and the parameters analyzed by each laboratory, and shall submit this list to the Department immediately upon request.

6. System Assessment Report

- a. The Approval Holder(s) shall submit a System Assessment Report to the Department by April 1, 2023, to verify that the Municipal Public Drinking Water Supply complies with the Act and standards.
- The System Assessment Report shall be in accordance with the Department's "Terms of Reference for System Assessment Reports for Water Works", as amended from time to time.
- c. The Approval Holder(s) shall provide the Department with their corrective action plan to address deficiencies identified by the System Assessment Report by October 1, 2023. Any changes to the corrective action plan shall be submitted to and deemed acceptable by the Department.

7. Source Water Protection

- a. The Approval Holder(s) shall implement the accepted Source Water Protection Plan in accordance with the accepted schedule.
- b. The Approval Holder(s) shall ensure that the Source Water Protection Plan is reviewed and updated on a yearly basis. The Approval Holder(s) shall ensure that any changes are documented in the annual report.
- c. The Approval Holder(s) shall modify the Source Water Protection Plan, including updates, if so directed by the Department.

8. Water Quality Requirements - Performance and Limits

General Requirements

- Treatment shall be sufficient to ensure 99.99% reduction of viruses (4-Log Reduction) for each well or, if water from individual wells is combined, for the combined flow.
- b. The treated water shall minimize corrosion of the water distribution and/or plumbing systems.

Primary Disinfection Requirements

c. Primary disinfection through the use of chlorine, ultraviolet light (UV) and/or a Department approved alternate disinfection method, shall contribute a minimum of 4-log inactivation for viruses for each well or, if water from individual wells is

Page 8 of 22



combined, for the combined flow. The disinfection log inactivation shall be based on CT/IT values which shall be calculated as defined by the Nova Scotia Treatment Standards for Municipal Drinking Water Systems, as amended from time to time.

- d. Flow from each well or the combined flow, if water from individual wells is combined, shall have a minimum of two primary disinfection units configured to apply disinfection treatment at all times to ensure that inadequately disinfected water does not enter the water distribution system unless the Approval Holder(s) makes an application for system wide redundancy and the application is deemed acceptable by the Department.
- e. Each disinfection unit shall be capable of meeting the maximum day demand flow. Where more than two disinfection units are provided, the maximum day demand flow shall be met when the largest unit is out of service.
- f. Continuous on-line monitoring of the primary disinfection process is required at each treatment facility with measurements taken at a minimum of once every five minutes to ensure that inadequately disinfected water does not enter the distribution system. Water systems shall be equipped with alarm capabilities to notify operations staff if the disinfection process fails to operate properly to prevent inadequately disinfected water from being distributed.
- g. In the event of an emergency situation where water enters the water distribution system that does not meet the water quality limits as prescribed in the Act and/or this Approval, the Approval Holder(s) shall issue a boil water advisory, do-notconsume, or do-not-use advisory as described in the Guidelines for Monitoring Public Drinking Water Supplies and notify the Department as soon as the Approval Holder(s) becomes aware.
- h. Standard operational procedures (SOPs) for the disinfection process shall be developed, implemented and communicated to all operations staff and documented in the operations manual required herein. The procedures and a log indicating the date and method of communication to staff shall be made available to the Department immediately upon request.
 - i. The standard operational procedures shall indicate the design ranges for achieving CT (e.g. minimum temperature and chlorine residual, maximum flow and pH) and/or IT (e.g. minimum UV intensity, minimum UV transmittance, and maximum water flow).
 - ii. When operational conditions are outside the design ranges for achieving CT/IT, the Approval Holder(s) shall notify the Department as soon as the Approval Holder(s) becomes aware, investigate the cause and take necessary corrective action. CT/IT shall be calculated during every such event.

Page 9 of 22

Secondary Disinfection and Residual Monitoring Requirements

- i. Secondary disinfection through the use of chlorine shall be used to maintain a chlorine residual in the water distribution system.
- j. The disinfection process shall be operated in such a manner as to ensure that the following minimum chlorine residual value is achieved throughout the water distribution system at all times:
 - i. 0.20 mg/L free chlorine residual.
- k. The disinfection process shall be operated in such a manner as to ensure that the maximum chlorine residual delivered to consumers does not exceed the following value:
 - i. 4.0 mg/L free chlorine residual.
- Continuous monitoring of chlorine residual is required for finished water at each location where water enters the distribution system from an individual well or combined wells, with measurements taken at no more than five minute intervals.
- m. Continuous monitoring of chlorine residual is required for the water leaving any water storage structure within the water distribution system, with measurements taken at no more than five minute intervals.
- n. Monitoring of the water distribution system for chlorine residual is required. Unless specified otherwise in this Approval, sampling and testing frequency is the same as for bacteriological sampling requirements as stated in the "Guidelines for Monitoring Public Drinking Water Supplies".

Turbidity Requirements

- The turbidity levels entering the water distribution system from each well or combination of wells shall not exceed 1.0 NTU:
 - i. In at least 95% of the measurements taken by grab sample for each calendar month; or
 - ii. In at least 95% of the time each calendar month if continuous monitoring is the method of turbidity measurement.
- p. If the Approval Holder(s) cannot meet the 1.0 NTU turbidity requirements described herein, the Approval Holder(s) may request that a less stringent value apply provided the Approval Holder(s) can demonstrate to the Department that the turbidity is not health-related and that the disinfection process is not compromised by the use of a less stringent value.
- q. A turbidity value of 5.0 NTU or less shall be achieved on water distribution system sampling.

Page 10 of 22

- r. Unless specified otherwise in this Approval, sampling and testing frequency is the same as for bacteriological sampling requirements as stated in the "Guidelines for Monitoring Public Drinking Water Supplies".
- s. Where turbidity values of greater than 5.0 NTU are observed in the water distribution system, the Approval Holder(s) shall investigate the cause and take corrective action as necessary and notify the Department immediately.

Turbidity Monitoring Requirements

- t. Daily grab or continuous monitoring, with measurements taken at no more than five minute intervals, is required for each wellhead or combined flow.
- u. Continuous or grab sample monitoring of the water distribution system is required. Unless specified otherwise in this Approval, sampling and testing frequency is the same as for bacteriological sampling requirements as stated in the "Guidelines for Monitoring Public Drinking Water Supplies".

9. Backup Water Systems

- a. Prior to the use of a backup water system, the Approval Holder(s) shall immediately notify the Department and identify the anticipated period of time that the backup system will be in service.
- b. For backup systems that do not meet the Nova Scotia Treatment Standards for Municipal Drinking Water Systems, the Approval Holder(s) shall immediately initiate a Boil Water Advisory as stated in the "Guidelines for Monitoring Public Drinking Water Supplies" prior to the use of a backup system. The Approval Holder(s) shall maintain the boil advisory until otherwise advised by the Department.
- c. For backup systems that meet the Nova Scotia Treatment Standards for Municipal Drinking Water Supplies, the backup water system may continue to operate until the main water system is put back into service or as otherwise directed by the Department.

10. Laboratory Reports and Water Quality Results

- a. The Approval Holder(s) shall submit copies of the laboratory certificate of analysis to the Department immediately upon request.
- b. The Approval Holder(s) will authorize and work with laboratories to electronically report water quality results to the Department upon implementation of an on-line drinking water quality surveillance program.
- c. Electronic reporting shall not replace the Approval Holder(s)'s responsibility to notify the Department immediately, by telephone, of the presence of bacteria or an exceedance of a maximum acceptable concentration for a health-related

Page 11 of 22

parameter listed in the "Guidelines for Canadian Drinking Water Quality".

11. Monitoring and Recording

- a. The Approval Holder(s) shall monitor and sample the Municipal Public Drinking Water Supply in accordance with a monitoring program deemed acceptable by the Department and which meets the minimum requirements of Schedule A, attached. In the case of a discrepancy between Schedule A and the accepted monitoring program, the accepted monitoring program shall apply.
- b. All required monitoring data must be collected and submitted in the units of measure indicated in the standard(s)
- c. Sampling shall be representative of the water distribution system.
- d. On or before October 1 of each year, the Approval Holder(s) shall recommend to the Department the monitoring program for the Municipal Public Drinking Water Supply for the following calendar year, highlighting any proposed changes and the reason for the changes. Any existing monitoring program shall remain in place until the recommended monitoring program is deemed acceptable by the Department.
- e. The monitoring program shall meet the minimum requirements of the Department's "A Guide to Assist Nova Scotia Municipal Water Works Prepare Annual Sampling Plans", as amended from time to time.
- f. The monitoring program shall be acceptable to the Department.
- g. The Approval Holder(s) is responsible for implementing, on an annual basis, the monitoring program and subsequent revisions as deemed acceptable by the Department.
- h. The Approval Holder(s) shall not move, relocate or otherwise alter the location of the sampling locations indicated in the approved monitoring program without written permission from the Department.
- i. Following a review of any of the analytical results required by this Approval, the Department may alter the frequencies, location, and parameters for analyses required for this Approval or require other remedial action.
- j. Any flow measuring devices and continuous water quality analyzers and indicators with alarm systems shall be installed, maintained and calibrated as specified by the instrument manufacturer's instructions. Calibration logs for each instrument shall be maintained at the site and be available for inspection immediately upon request by the Department.
- k. The Approval Holder(s) shall establish a QA/QC program to validate the measurements obtained from continuous monitoring equipment and for all

Page 12 of 22

analysis conducted at the Site or a non-certified laboratory.

- I. The Approval Holder(s) shall establish and conduct process control testing and sampling and record the results. Results are to be made available for inspection or review by departmental staff immediately upon request.
- m. The Approval Holder(s) shall establish and conduct source water protection testing and sampling and record the results. Results are to be made available for inspection or review by departmental staff immediately upon request.

12. Reporting

Reporting Upon Request

a. The Approval Holder(s) shall keep records continually updated in such a way, that weekly and/or monthly reporting of monitoring and sampling results can be immediately sent to the Department upon request.

Annual Reporting

- b. The Approval Holder(s) shall prepare and submit to the Department, an annual report for the Municipal Public Drinking Water Supply.
- c. The annual report shall be submitted on or before April 1 following the completion of the calendar year being reported upon.
- d. The annual report shall contain, but not be limited to, the following information:
 - a summary and discussion of the quantity of water supplied during the reporting period on a per month basis showing design values, maximum daily flow and average daily flow for each month and any other parameters or conditions specified in the Water Withdrawal Approval;
 - a summary and interpretation of analytical results obtained in accordance with the "Monitoring and Recording" section of this Approval, including an explanation for any exceedance of the maximum acceptable concentration (MAC) of health-related parameters listed in the "Guidelines for Canadian Drinking Water Quality", latest edition and the actions taken to address the exceedance;
 - iii. annual trend graphs for parameters that are continuously monitored;
 - date and description of any emergency or upset conditions which occurred during the period being reported upon and action taken to correct them;
 - any modifications to the contingency plan or emergency notification procedures including a description of how the information was communicated to staff;

Page 13 of 22



- vi. a list of the names of each laboratory utilized by the Approval Holder(s) and the parameters analyzed by each laboratory;
- an update on the status of the source water protection plan, including any modifications to the plan or implementation schedule, and a summary of activities taken to achieve the goals and objectives of the plan;
- viii. all incidents of free chlorine residual below 0.20 mg/L in the water distribution system shall be detailed with a description of any actions taken
- verification that the operational conditions remained within the design range for achieving CT/IT; if operational conditions went outside the design ranges, provide CT/IT calculations and a summary of corrective actions taken;
- mathematical verification that turbidity levels entering the water distribution system from each well or combination of wells shall not exceed 1.0 NTU 95% of the time each calendar month;
- a summary and interpretation of results obtained in accordance with the corrosion assessment/control program including, but not limited to, residential lead sampling results;
- xii. incidents of non-compliance with this Approval, the date it was reported to the Department, and corrective actions taken by the Approval Holder(s);
- xiii. any complaints received, the steps taken to determine the cause of the complaint and the corrective measures taken to alleviate the cause and prevent its recurrence;
- xiv. a review of the QA/QC program to validate the measurements obtained from continuous monitoring equipment and for all analysis conducted at the facility or a non-certified laboratory; and
- xv. a list of each certified operator and their level of certification.

Emergency Reporting on Operation

e. The Approval Holder(s) shall notify the Department immediately of an incident that may adversely affect the quality of the water within the Municipal Public Drinking Water Supply. Notification shall be made to a live person by phone or in person and followed by fax or email. These incidents shall include, but not be limited to: the presence of bacteria; inadequately disinfected water being directed to the water distribution system; sewage or other releases in the source Municipal Public Drinking Water Supply area; line breakage that may result in cross contamination; exceedance of turbidity values required by this Approval; if using membrane filtration, failure of direct integrity test, etc.

Page 14 of 22

- f. The Approval Holder(s) shall notify the Department immediately of any analytical results that exceed the maximum acceptable concentration (MAC) of health-related parameters listed in the "Guidelines for Canadian Drinking Water Quality", latest edition. Notification shall be made to a live person by phone or in person and followed by fax or email.
- g. When bacteria are detected in the Municipal Public Drinking Water Supply, the Approval Holder(s) shall notify the Department immediately of the presence of bacteria and take corrective action as outlined in the latest edition of the "Guidelines for Monitoring Public Drinking Water Supplies", as amended from time to time. Notification shall be made to a live person by phone or in person and followed by fax or email.
- h. If the chlorine residual in the water distribution system is less than 0.20 mg/L free chlorine, the Approval Holder(s) shall notify the Department immediately of the low chlorine residual and take corrective actions to obtain the required residual. Notification shall be made to a live person by phone or in person and followed by fax or email.

13. Contingency Plan

- a. The contingency plan is to meet the minimum requirements of the Department's "A Guide to Assist Nova Scotia Municipal Water Works Develop a Comprehensive Operations Manual" and "Contingency Planning Guidelines", as amended from time to time.
- b. The Approval Holder(s) shall ensure that the contingency plan for the Municipal Public Drinking Water Supply is reviewed and updated on a yearly basis. The Approval Holder(s) shall document in the annual report what modifications were made to the plan and how the plan was communicated to their staff.
- c. The Approval Holder(s) shall ensure that all employees are trained in accordance with the contingency plan and shall keep a record of training at the facility for a minimum period of five (5) years.
- d. A copy of the contingency plan is to be maintained on Site at all times and is to be available for review immediately upon request by the Department.

14. Records

- a. The Approval Holder(s) shall keep the following records and water quality analyses:
 - All incidents of suspected and/or confirmed disease outbreaks attributed to the water system shall be documented and kept for a minimum of ten (10) years;
 - ii. Bacteriological, chlorine residual and turbidity analyses shall be kept for

Page 15 of 22



two (2) years;

- iii. Chemical analysis shall be kept for ten (10) years;
- iv. Annual water withdrawal records shall be kept for ten (10) years.
- b. The Approval Holder(s) shall retain the following information for a period of five (5) years:
 - i. Calibration and maintenance records;
 - ii. Continuous monitoring data.
- c. A copy of project reports, construction documents and drawings, and inspection records shall be kept for the life of the Municipal Drinking Water Supply.

Page 16 of 22

	Schedule A		
Water Quality Parameters	Non-GUDI		
Turbidity	Sample Location	winimum Frequency	
Turbidity	At individual wellheads or the combined flow	Continuous at no more than 5 minute intervals or daily grab sample	
	Distribution system sample points	Weekly grab sample	
Primary Disinfection (Paramused)	neters to be monitored depend	on the disinfection method	
Free Chlorine			
Free Chlorine Residual	CT control point (water entering the distribution system)	Continuous at no more than 5 minute intervals – must meet CT design criteria	
Temperature	CT control point	Continuous at no more than 5 minute intervals or daily grab – must meet CT design criteria	
pH	CT control point	Continuous at no more than 5 minute intervals – must meet CT design criteria	
Secondary Disinfection (Par method used)	rameters to be monitored depe	end on the disinfection	
Free Chlorine			
Free Chlorine Residual	Storage structure outlet	Continuous at no more than 5 minute intervals	
	Distribution system sample points	Weekly grab sample	
Microbial Quality			
Total coliforms and <i>E. coli</i> (present/absent)	Distribution system sample points	Weekly grab sample	
Viruses	Raw water	As requested by the Department	
	Water distribution system	As requested by the Department	
Corrosion Monitoring Progra	am		
pHAlkalinity	Point of entry and representative locations	Quarterly grab sample for two consecutive years*	

Page 17 of 22

	Scheo				
Water Quality Parameters	Sample	ocation	Minimum Erequency		
Conductivity Temperature Dissolved oxygen Chloring or phloremine	within the dist system based population set	ribution on rved:	* An owner may submit a request to NSE for a		
 residual Corrosion inhibitor residual (if used) 	Population	# of distribution samples	of point-of- entry and distribution monitoring requirements from		
These peremeters will	<100	1	quarterly to annually		
assist the utility determine	101-500	2	between May and October		
the correctivity of the water	501-3 300	3	if the water is not corrosive		
and type of corrosion control the system should	3,301- 10,000	4	as evidenced by point-of- entry and distribution		
install, if needed.	10,001- 100,000	6	sample results for key parameters in conjunction		
	>100, 000	10	with residential lead levels		
			consecutive years). *If the water is corrosive as evidenced by point-of-entry and distribution sample results for key parameters in conjunction with residential lead levels (e.g. the 90 th percentile lead concentrations are above the lead action level in any given year), the utility shall implement a corrosion control program or optimize their existing program. The utility shall submit a corrosion control program to NSE for review and acceptance. Once accepted by NSE, the utility shall follow the corrosion control monitoring parameters, leading(a) and foreward.		

Page 18 of 22

	Schedule A			
Water Quality Parameters	Sample Locatio	n	Minimum Frequenc	v
Lead – flushed sample(s)	Representative locat within the distribution system based on population served – table above.	tions An n wa see *Ar rec col for dis sar dis the per yea not fitti con dis	nually – during the rmest month* n owner may submit juest to NSE to stop lecting flushed sam lead from the tribution system, if nples collected from tribution system dur warmest month for riod of two consecut ars show the utility of the tribution system to ngs or other mponents in the tribution system.	a ples ing a ive loes in
Lead – Stagnated Sampling (as per Health Canada's Guidance for Controlling Corrosion in Drinking Water Distribution Systems, as amended from time to time) Tier 1 Sampling • Minimum 6-hour stagnation period • Collect first draw 1 litre sample. May collect 4 1-litre samples in case Tier 2 sampling is required.	Where possible, site be selected to includ at least 50% of sites lead service lines (w present); 2/ locations contain copper pipes lead solders or lead and 3/ locations with containing brass fitting	s shall An le: 1/ Oc with con here rele s that s with If < pipes; per lead res ngs act sull sar (re If > per res act 2 s	October to assess corrosivity of water to lear release. If < 10% (defined as 90 th percentile) of initial sampl results are above the lear action limit for a period of two consecutive years, submit request to NSE to sample once per year (reduced annual). If > 10% (defined as 90 th percentile) of initial sampl results are above the lear action limit, proceed to Ti 2 sampling	
	Population	the following # of site (Routir annua	es # of sites (Reduced () annual)	20
	<100	5	5	
	101-500	10	5	
	501-3,300	20	10	

Page 19 of 22

	Schedule A			
	Non-GUDI	-		
Water Quality Parameters	Sample Location	Minimum Frequency		
	3,301- 10,000 10,001-	40 60	30	
	100,000	100	50	
	*An owner may submit a re in the number of residential percentile lead concentratic level for a period of two cor	quest to NS samples if ns are belo secutive ye	E for a reduction the 90th w the lead action ars.	
 Tier 2 Sampling Minimum 6-hour stagnation period Collect first draw 4* x 1 litre samples (or additional 3 x 1 litre samples from Tier 1) * More than 4 samples may be required to identify the source of lead, depending on several factors including the length and diameter of piping, etc. 	Sample at 10% of sites sampled in Tier 1 (sites with the highest lead concentration). For systems serving 500 or fewer people a minimum of two sites are required. Each 1 liter sample is analyzed to obtain a profile of lead contribution from the: -Faucet -Plumbing (leaded solder, brass and bronze fittings, brass water meter, etc.) -Lead service line	Only requ of Tier 1 s the lead a	lired when >10% samples exceed action limit.	
Process Control				
Water Volume	Each individual well	Continuo than 5 mi	us at no more nute intervals	
Fluoride – for facilities that add fluoride	Water entering the distribution system	Daily		
Disinfection By-products				
Total Trihalomethanes (THMs)	Select distribution system sample point(s) – representative of highest level. Areas in the distribution system with the	Quarterly running a (Iraa) bas of 4 quart	*- locational nnual average ed on a minimum erly samples.	

Page 20 of 22

	Schedule A	
Water Quality Parameters	Sample Location	Minimum Frequency
	longest disinfectant retention time.	* The Approval Holder may request a reduction in sample frequency to annual, if the Iraa based on a minimum of four quarterly samples collected from each location is < 0.010mg/L
Haloacetic Acids (HAAs)	Select distribution system sample point(s) – where historical data show the highest concentration. Where historical data is not available concentrations shall be monitored in the middle and extremities of the distribution system.	Quarterly* - locational running annual average (Iraa) based on a minimum of 4 quarterly samples. * The Approval Holder may request a reduction in sample frequency to annual, if the Iraa based on a minimum of four quarterly samples collected from each location is < 0.010mg/L
Chlorate – if storing sodium hypochlorite more than 3 months	Water entering distribution system	Quarterly
Bromate – if storing sodium hypochlorite more than 3 months	Water entering distribution system	Quarterly
Treatment Process Backwa If required, treatment proce- frequency in accordance wi program.	sh Wastewater ss backwash wastewater- para th this approval and the accep sical Quality	ameter(s), location(s), and ted annual monitoring
General chemical and Phys	Raw and treated water	Minimum even two upper
physical parameters listed in the Guidelines for Monitoring Pubic Drinking Water Supplies	Naw and treated water	www.mum.every.two-years
Manganese	 Raw water (prior to treatment) Entering the distribution system Distribution system. 	 Twice per year (spring and fall) Quarterly Quarterly The Approval Holder may request a reduction in sample frequency, if it is

Page 21 of 22

	Schedule A Non-GUDI	
Water Quality Parameters	Sample Location	Minimum Frequency
		manganese is not a parameter of concern for the water supply.
Guidelines for Canadian Dr	inking Water Quality	
All health-related parameters in the Guidelines for Canadian Drinking Water Quality	Raw and treated water	Every 5 years unless system assessment report or source water protection plan requires more frequent monitoring.
Source Water Protection		
Parameters as per the source water protection monitoring program	Locations and frequencies source water protection m	s in accordance with the conitoring program.

Page 22 of 22

APPENDIX H

Approval to Withdrawal





136 Exhibition Street Kentville, NS Canada B4N 4E5 902-679-6086 T 902-679-6186 F www.novascotia.ca

Our File Number: 95100-30-KEN-2009-068808

May 19, 2020

MUNICIPALITY OF THE COUNTY OF ANNAPOLIS James Jenner PO BOX 609, 271 Granville Street ANNAPOLIS ROYAL, NS B0S1C0

Attention: James Jenner

RE: Approval for Operation - Water Withdrawal. Approval No. 2009-068808-05 PID # 05141973, 05142039

Enclosed please find Approval 2009-068808-05 for Operation of the Water Withdrawal at 308 Church St.507 Church St. Bridgetown North, Annapolis County Nova Scotia.

Strict adherence to the attached terms and conditions is imperative in order to validate this approval.

Despite the issuance of this Approval, the Approval Holder is still responsible for obtaining any other authorization which may be required to carry out the activity, including those which may be necessary under provincial, federal or municipal law.

Should you have any questions, please contact Lanying X Zhao, Western Region, Kentville Office at 902-679-6086.

Yours truly,

yenny onergan

Jennifer Lonergan District Manager

cc: CBCL Limited





136 Exhibition Street Kentville NS Canada B4N 4E5 902-679-6086 P 902-679-6186 F www.novascotia.ca

APPROVAL

Province of Nova Scotia Environment Act, S.N.S. 1994-95, c.1 s.1

APPROVAL HOLDER: MUNICIPALITY OF THE COUNTY OF ANNAPOLIS

41973, 05142039	SITE PID:
4	SITE PID:

APPROVAL NO: 2009-068808-05

EXPIRY DATE: March 15, 2030

Pursuant to Part V of the *Environment Act*, S.N.S. 1994-95, c.1 s.1 as amended from time to time, approval is granted to the Approval Holder subject to the Terms and Conditions attached to and forming part of this Approval, for the following activity:

Water Approval - Water Withdrawal

Jennifer Jonergan

Administrator: Jennifer Lonergan

Effective Date: March 16, 2020

The Minister's powers and responsibilities under the Act with respect to this Approval have been delegated to the Administrator named above. Therefore, any information or notifications required to be provided to the Minister under this Approval can be provided to the Administrator unless otherwise advised in writing.

Page 1 of 9



TERMS AND CONDITIONS OF APPROVAL

Nova Scotia Environment

Approval Holder: MUNICIPALITY OF THE COUNTY OF ANNAPOLIS

Project: Bridgetown Water Treatment

S	it	ρ	•	
-		~	•	

PID	Civic #	Street Name	Street Type	Community	County
05141072	507	CHURCH	et.	BRIDGETOWN	ANNAPOLIS
05141975	507	CHURCH	51.	NORTH	COUNTY
05142039	308	CHURCH	ST.	BRIDGETOWN NORTH	ANNAPOLIS COUNTY

Approval No:	2009-068808-05			
File No:	95100-30-KEN-2009-068808			

Grid Reference: Easting - 318104, Northing - 4970229

Reference Documents

- Application submitted February 13, 2020 and attachments.

1. Definitions

a. Act means Environment Act, Chapter 1 of the Acts of 1994-95, and includes, unless the context otherwise requires, all regulations made pursuant to the Act.

 Department means the Department of Environment, and the contact for the Department for this approval is: Nova Scotia Environment Western Region, Kentville Office 136 Exhibition Street Kentville, Nova Scotia B4N 4E5

Phone: (902) 679-6086 Fax: (902) 679-6186

c. Minister means the Minister of Environment and includes any person appointed as a designate of the Minister.

Page 2 of 9



d. Site means a place where a designated activity and/or undertaking is occurring or may occur.

2. Scope

- a. This Approval (the "Approval") relates to the Approval Holder and their application and supporting documentation, as listed in the reference documents above, to withdraw groundwater from well(s) denoted as: PW2, PW3, and PW4 situated at or near 308 and 507 Church Street, Bridgetown North, Annapolis County (the "Site").
- b. The Approval Holder(s) shall ensure the designated activity is carried out in accordance with this Approval and reference documents, including the application and supporting documentation.
- c. This approval authorizes only the activities outlined in the Scope section. All other watercourse alterations require additional Approvals or Notifications.

3. General

- a. The Approval Holder(s) shall conduct the Designated Activity in accordance with the following provisions:
 - i. The Act, as amended from time to time;
 - ii. Any standard adopted by the Department, as amended from time to time.
- b. No authority is granted by this Approval to enable the Approval Holder(s) to commence or continue the designated activity on lands which are not in the control or ownership of the Approval Holder(s). It is the responsibility of the Approval Holder(s) to ensure that such a contravention does not occur. The Approval Holder(s) shall provide, to the Department, proof of such control or ownership upon expiry of any relevant lease or agreement. Failure to retain said authorization may result in this Approval being cancelled or suspended.
- c. If there is a discrepancy between the reference documents and the terms and conditions of this Approval, the terms and conditions of this Approval shall apply.
- d. Any request for renewal or extension of this Approval is to be made in writing, to the Department, at least ninety (90) days prior to the Approval expiry.
- e. Nothing in this Approval relieves the Approval Holder(s) of the responsibility for obtaining and paying for all licenses, permits, approvals or authorizations necessary for carrying out the work authorized to be performed by this Approval which may be required by municipal by-laws, provincial or federal legislation, or other organizations. The Minister does not warrant that such licenses, permits, approvals or other authorizations will be issued.

Page 3 of 9

- f. The Approval Holder(s) shall advise the Department in writing prior to any proposed extensions or modifications to the Activity and/or the Site. An amendment to this Approval may be required before implementing any extension or modification.
- g. The Approval Holder(s) shall immediately notify the Department of any incidents of non-compliance with this Approval.
- The Approval Holder(s) shall bear all expenses incurred in carrying out the environmental monitoring required under the terms and conditions of this Approval.
- i. Unless specified otherwise in this Approval, all samples required to be collected by this Approval shall be collected, preserved and analysed, by qualified personnel, in accordance with recognized industry standards and procedures.
- j. Unless written authorization is received otherwise from the Minister, all samples required by this Approval shall be analysed by a laboratory that meets the requirements of the Department's Policy on Acceptable Certification of Laboratories as amended from time to time.
- k. The Approval Holder(s) shall ensure that this Approval, or a copy, is kept on Site at all times and that personnel directly involved in the Facility operation are made fully aware of the terms and conditions which pertain to this Approval.
- I. Upon any changes to the Registry of Joint Stock Companies information, the Approval Holder(s) shall provide a copy to the Department within five business days.

4. Covenant Conditions

- a. The Approval does not authorize any activity that would:
 - i. prejudice any riparian rights of any owner or of any person lawfully in possession of or holding any lands abutting the watercourse;
 - ii. cause any damage or nuisance to adjacent or abutting land; or
 - iii. discharge water onto adjoining lands without the authorization of the affected landowner(s).
- b. By granting this Approval, the Department is not responsible for any damages as a result of the approved activities, including any water quality or quantity problems that may be encountered by the Approval Holder(s) or other parties.
- c. By issuing this approval, the department is not providing any assurance(s) as to sufficient water quantity and/or quality to meet any requirements of the Approval Holder(s).

Page 4 of 9

5. Fees

a. The Approval Holder(s) shall, upon receipt of an invoice from the Department stating the amount owing in accordance with the Fees Regulations, as amended from time to time, pay to the Minister of Finance the amount stipulated.

6. Site Specific Conditions

- a. Withdrawal Locations
 - i. This Approval applies to withdrawal water from the production wells denoted PW2, PW3, and PW4, situated at or near 308/507 Church St, Bridgetown North, Annapolis County, Nova Scotia (the "Site"). Available locations and construction details for the production wells, PW2, PW3, and PW4, and monitoring wells, are identified in Table 1, Well Construction Information in the Appendix.
- b. Water Withdrawal Limits for the Wellfield
 - The Maximum Pumping Rate (litres/day), Average (30-day) Pumping Rate, 30-day Withdrawal Volume (litres) and Annual Withdrawal Volume shall adhere to the limits shown in Table 2, Approved Withdrawals in the Appendix.
- c. Withdrawal Flow Monitoring
 - i. A flow meter shall be installed, maintained and monitored separately for each individual production well.
 - ii. The Approval Holder shall keep daily well production records for each well and the total for the wellfield including water withdrawal volumes. Data shall be tabulated within a spreadsheet and compared to approved limits.
- d. Water Level Monitoring
 - i. A level logger shall be installed and maintained in each production well and monitoring well. Water levels shall be monitored continuously via leveloggers and validated with manual measurements every year.
 - ii. Water level data shall be recorded in meter as a geodetic elevation and reference to meter above sea water level, and tabulated in a spreadsheet.
- e. Water Quality Sampling:
 - i. Raw water sample shall be collected for each production well (PW2, PW3, and PW4) and for mixed raw water for analyzing uranium on a monthly basis.
 - ii. Water quality analytical results including historical water chemistry results

Page 5 of 9

shall be tabulated in spreadsheet format and compared to applicable guidelines. Data shall be presented to easily identify changes/trends in water quality.

- f. Well Decommissioning
 - i. Any well located at the Site that is required to be decommissioned by the Minister or that is not being used or maintained for present or future use shall be decommissioned in accordance with the Well Construction Regulations and Water Well Decommissioning Guidelines. This condition survives the expiry or cancellation of this Approval.
- g. Well Interference Remedy
 - i. In the event that groundwater withdrawal causes interference (water quality and water quantity) with other water supplies, the Department shall be notified immediately, and the water withdrawal rate shall be reduced and/or the problem rectified by the Approval Holder in accordance with an action plan acceptable to the Department.
- h. Monitoring Records:
 - i. The Approval Holder shall maintain the following monitoring records, as a minimum:
 - (a) water withdrawal rates for each well and for the wellfield in comparison to approved limits, including:
 - (1) daily pumping rate (litre/day)
 - (2) average(30-day) pumping rate (litre/day)
 - (3) maximum daily withdrawal volume for each month (liter/day)
 - (4) 30-day withdrawal volume(litre) and
 - (5) annual withdrawal volume (litre).
 - (b) current and historical water chemistry results;
 - (c) current and historical uranium concentrations;
 - (d) current and historical water levels;
 - (e) potential hazards or changes to the water supply (e.g., nearby land development, new wells or pumps installed, wells abandoned, contaminant spills);
 - (f) complaints received regarding water withdrawal activities and the follow up actions taken;
 - (g) reported effects of the withdrawal on other groundwater users and/or the environment.

Page 6 of 9

- ii. Monitoring data referenced above including water chemistry shall be maintained in tabular (in a spreadsheet format) and in paper.
- iii. The monitoring records shall be maintained by the Approval Holder for the duration of the Approval.
- iv. All the monitoring data shall be available, in a format and timeframe acceptable to the Department, for review at any time upon request by the Department.
- i. Reporting
 - i. The Approval Holder shall prepare an annual report in a format acceptable to the Department, and submit the annual report to the Department by February 1st following the completion of the calendar year being reported.
 - ii. The annual report shall include at least a summary of the above monitoring records (6.h.i), a comparison of the monitoring results to the Approval requirements, an evaluation of whether the results are in compliance with Approval conditions, an overall assessment of the wellfield performance (water levels and water chemistry), and recommendations to improve the water monitoring program based on the wellfield operation.
 - iii. The Approval Holder may be requested by the Department to retain the services of a Professional Hydrogeologist licenced to practice in Nova Scotia to prepare, analyse, or comment on the well field report(s).

Page 7 of 9

Appendix to the Water Approval for Groundwater Withdrawal for Municipality of the County of Annapolis at Bridgetown site, Annapolis County

	Table 1 - Well Construction Information							
Civic Address: 308 Church Street; 507 Church Street, Community: Bridgetown North, Annapolis County, NS PID: 05142039, 05141973								
Production	NSE Well	Well UTM Coordinates		Well Total Casing	Diameter	Screen		
Well	Log Number	Easting	Northing	Depth (m)	Depth (m)	(mm)	Description ³	
PW1	071319	318864	4969098	103.6	97.5	254	bedrock: 10.7m; screen(4X5feet) 54.86-56.39m, 73.15-74.68m, 91.44-92.96m, 103.63-105.16m	
PW2	071326	318783	4969291	106.7	100.6	254	Bedrock:10.7m; screen(4X5feet) 51.82-53.34m, 76.2-77.72m, 88.39- 89.92m	
PW3	090945	318843	4969033	121.9	21.3	203	bedrock: 9.1m screen:21.34-121.9m	
PW4		318104	4970229	57.6	12.2	203	bedrock: 6m; screen12.2-57.6m	
Monitoring Well								
TW4		318826	4968955	122	12.2	152	bedrock:8m;openhole	
TW5		318130	4970238	60(91.5)	12.2	152	open borehole	
MW09-01	090982	318612	4969326	60.9	12.2	152	open borehole	
MW17-01S		318061	4970377	6.1	3.1	51		
MW17-01D		318065	4970378	12.2	9.2	51		

Notes: TW4: GPS coordinates are given based on google earth; TW5: initial depth of 91.5m and backfilled to 60m; and

PW1: use of PW1 was discontinued in 2018 and is designated a back-up well/monitoring well.

Page 8 of 9

T									
Production	Pumpin (litre/	g Rate day)	Withdrawal Volume (litre)						
Well	Average ¹ (over 30 days)	Maximum² (Over 3 days)	30 day ³	Annual ⁴					
PW1	0	0	0	0					
PW2	573,235	716,531	17,197,050	209,520,775					
PW3	583,708	728,760	17,511,240	213,343,420					
PW4	654,637	981,956	19,639,110	238,942,505					
Total Wellfield	1,000,000	1,300,000	30,000,000	365,000,000					

Notes:

1. Average allowable pumping rate is based on the demonstrated water needs of the facility and the

Average allowable pumping rate is based on the demonstrated which needs of the identity and the sustainable yield;
 Maximum allowable pumping rate is based on the maximum rate used in the pumping test. Pump rate shall at no time exceed the maximum based on actual rate averaged after 3 days;
 30-day withdrawal volume equals approved average pumping rate multiplied by 30 days;

Annual withdrawal volume equals approved average pumping rate multiplied by 365 days; and
 Use of PW1 was discontinued in 2018; PW1 is designated a back-up well/monitoring well.

Page 9 of 9



APPENDIX I

Schematic of the Treatment & Disinfection Process







APPENDIX J

Water Protection Zone Mapping in GIS Format for NSECC

To be provided separately.



APPENDIX K

Terms of Reference Checklist



Nova Scotia Environment & Climate Change System Assessment Report Terms of Reference Checklist





PART I Introduction

This checklist was prepared as a companion document to the Terms of Reference for System Assessment Reports for Municipal Drinking Water Systems, 2022. For detailed information on each of the submission requirements below, please consult the source document. For ease of reference, reports should follow the format and sequence of the checklist below. Where possible, section references should follow section and subsection numbering conventions used in the checklist.

Where data is required to be submitted for 'the most recent calendar year', Approval Holders may submit 12 consecutive months of data within a 2-year period from the date the system assessment report is due.

Nova Scotia System Assessment Report Terms of Reference Checklist / Part I



1

PART II Characterization of the Water Source

2.0 Source Water Characterization

Confirm all applicable information has been submitted to the Department. Indicate the section and page number where the information is documented.		Yes	N/A	Section	Page #				
2.1 Source Description and Schematic*									
i.	Describe the water source(s) used to meet water consumption demand.	V		2.1	3				
ij.	Describe any sources that are used as back-up supplies.		1						
iii.	Identify sources on a map.	1		App. C	-				
iv.	Document what precautions are required for back-up supplies.		V						
v.	If a back-up supply is intended to be used without precautions, verify that it meets the Nova Scotia Treatment Standards for Municipal Drinking Water Systems or if the back-up supply is connected to an adjoining municipality, document the name of the Municipal Public Drinking Water Supply to which it is connected.		7						
vi.	For Municipal Public Drinking Water Supplies that purchase water from an adjoining system, identify system connections on a map.		1						
vii.	Document the name of the municipal public drinking water supply(s) that water is purchased from and proceed to section 2.3.		1						

Nova Scotia System Assessment Report Terms of Reference Checklist / Part II

2

Confi Indica	rm all applicable information has been submitted to the Department. It the section and page number where the information is documented.	Yes	N/A	Section	Page #
2.2	Microbial Risks				
2.2.1	Surface Water Sources				
i.	Summarize microbial risks and water quality variability of the surface water source(s).		4		
ii.	Submit raw water quality data for total coliforms and E. coli, as well as Cryptosporidium and Giardia if available, for the most recent calendar year as an Appendix.		4		
2.2.2	Groundwater Sources				
i.	Verify that all individual wells have been classified in accordance with the Protocol for Determining Groundwater Under the Direct Influence of Surface Water.	1		2.2.2	6
ii.	Summarize the GUDI status by individual well and identify at which step in the GUDI. Protocol the well was categorized as GUDI or non-GUDI.	7		2.2.2	6
iii,	For wells that are no longer in use, identify if the well has been properly decommissioned or is being maintained as a back-up well or monitoring well.	1		2.2.2	6
iv.	For GUDI wells, complete Table A.1 and verify that the GUDI classification has not changed based on the results of microscopic particulate analysis (MPA) testing required every two years.		V		
v.	Verify that MPA samples were taken following a rainfall event in accordance with Step 3 of the GUDI Protocol (e.g., if there is a 15-day time-of-travel, then the well shall be sampled 15 days after a surface water event).		7		
vi.	Inspect the site(s) to verify that there are no changes to the surrounding area to warrant re-classification of the well(s).	1		2.2.2	6

Nova Scotia System Assessment Report Terms of Reference Checklist / Part II

3
Indic	ate the section and page number where the information is documented.	465	ara	30000	1 age #
vii.	 Recommend corrective action for wells: For which MPA test results indicate a change in GUDI classification. Where changes to the surrounding area have occurred to warrant reclassification of the well per the GUDI Protocol. Where any other concerns are identified. 		N		
viii.	Submit raw water quality data for total coliforms and E. coli bacteria for the most recent calendar year as an Appendix.		8		
ix.	For GUDI wells, submit any raw water quality data for Cryptosporidium or Giardia (if available) for the most recent calendar year as an Appendix.				

.4

Indic	ate the section and page number where the information is documented.	 		
2.3	Chemical Risks			
2.3.1	Disinfection By-Products			
a) T	rihalomethanes (THMs)			_
i.	Complete Table A.2 to summarize quarterly THM concentrations by sampling location.		App.A	
ij.	 For non-GUDI systems that have had quarterly sampling reduced to annual sampling: Note the acceptance date for this reduction in sampling frequency. Modify Table A.2 to summarize annual results, including sampling date. 			
iii.	If the locational running annual average for any sampling location exceeds the maximum acceptable concentration, recommend corrective actions.			
iv.	 Verify that sampling locations are appropriate as follows: Are samples collected at the point(s) in the distribution system with the highest potential THM concentrations? Are an adequate number of sites sampled to represent exposure levels system-wide? 		App.A	
v.	Identify THM sampling locations on a map of the distribution system.		App. C	
vi.	Recommend sampling location/frequency changes if necessary.	V		
b) H	aloacetic Acids (HAA5)	 -		

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
i.	Complete Table A.3 to summarize HAA5 concentrations by sampling location.	N		App. A	
ii.	 For non-GUDI systems that have had quarterly sampling reduced to annual sampling: Note the acceptance date for this reduction in sampling frequency. Modify Table A.3 to summarize annual results, including sampling date. 		V		
ш.	If the locational running annual average for any sampling location exceeds the maximum acceptable concentration, recommend corrective actions.		7		
iv.	 Verify that sampling locations are appropriate as follows: Are samples collected at the location(s) where historical data show the highest HAA5 concentrations? If historical data are not available, are HAA5 concentrations monitored in the middle and extremities of the distribution system to determine the highest concentrations? Are samples collected in areas where disinfectant residuals are significantly lower than the system average because of long residence time? In systems with booster chlorination stations and water tanks/reservoirs, are HAA5 concentrations monitored downstream of these components? Are an adequate number of sites sampled to represent system-wide exposure levels? 			Арр А	
v.	Identify HAA5 sampling locations on a map of the distribution system.	V		App C	
vi.	Recommend sampling location/frequency changes if necessary.		V	A	

Indic	arm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	rage 7
c) ()	ther Disinfection By-Products (DBPs)				
i.	Identify which other DBPs are required to be monitored and compare this to existing monitoring (see Table 1 in the Terms of Reference).				
ii.	Verify that sampling locations are appropriate.		1		
iii.	Identify sampling locations on a map of the distribution system.		7		
iv.	Recommend sampling location/frequency changes if necessary.		V		
v.	Summarize concentrations for the most recent calendar year as an Appendix.		7		
vi.	Recommend corrective actions if any maximum acceptable concentration is exceeded.				
.3.2	Lead and Corrosion Control		-		
a) La	ad and Copper				

Conf	rm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
î.	 Verify that sampling locations and frequencies for lead are appropriate as follows: Does the residential sampling program meet the minimum requirements as outlined in the Lead and Copper Management Requirements – Municipal Public Drinking Water Supplies or as otherwise accepted by the Department? Are residences suspected to be at the highest risk for lead targeted in the residential sampling program? 	N		2.3.2	8
ij.	Recommend sampling location/ frequency changes if necessary.	V		2.3.2	9
ш.	Summarize and append lead and copper concentrations by sampling location and sample protocol used for the most recent calendar year.	2		2.3.2	9
iv.	 Summarize corrective actions taken when residential sample results exceeded the maximum acceptable concentration, as outlined in the Lead and Copper Management Requirements – Municipal Public Drinking Water Supplies. Are the corrective actions taken in line with the minimum requirements outlined in the Lead and Copper Management Requirements – Municipal Public Drinking Water Supplies or as otherwise accepted by the Department? 	N		2.3.2	9
v.	Recommend program improvements, where applicable.	8		2.3.2	9
b) C	orrosion Control				
i,	Review the corrosion control program: • Does one exist?	8		2.3.2.2	10
	 Does it include the minimum monitoring requirements as outlined in the Guidelines for Monitoring Public Drinking Water Supplies – Part 1? 			2.3.2.2	10

Con Indi	firm all applicable information has been submitted to the Department. cate the section and page number where the information is documented.	Yes	N/A	Section	Page #
	• Does it include action limits for the corrosion monitoring parameters that trigger follow-up?	4		2.3.2.2	10
ii.	Summarize the water quality results of the corrosion control program for the most recent calendar year as an Appendix.		7		
iii.	Recommend corrective actions if concerns are identified from the review of the corrosion control program.	1		2.3.2.2	10
iv. P I I	If a corrosion control program does not exist, document why, including water quality results that demonstrate non-corrosivity of the water, or recommend the need for a more comprehensive corrosion control program. Note: The Langelier Index is no longer considered an adequate measure of corrosivity. The submission of water quality results based solely on a positive Langelier Index will not be accepted as justification for not having a corrosion control program. Note: The Engineer is not required to develop a corrosion control program as part of the	N		2.3.2.2	10
2.3.3 *Mu wate	system Assessment Report. 3 Guidelines for Canadian Drinking Water Quality* nicipalities that only distribute water purchased from another Municipal Public Drinking Water Supply t er quality results from the Approval Holder of the Municipal Public Drinking Water Supply t	ater Su hat trea	pply ma its the w	y obtain vater,	
	Verify that the full suite of health-related parameters (see Table A.4 in the Terms	2		2.3.3	
i.	water sources and treated water and document sampling dates.				

Cont	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
iii.	Discuss any trends for parameters with detectable concentrations.		7		
iv.	Include laboratory results from the last round of sampling as an Appendix.			App. E	
v .	Identify when the next round of sampling is scheduled to occur.			2.3.3	11
vi.	Recommend corrective actions if any MACs are exceeded.		7		
/ii.	Recommend any changes to the monitoring program (frequency/location) if sampling is inappropriate for cyanobacterial toxins, pesticides or other parameters with enhanced monitoring that was recommended for parameters with detectable concentrations.		V		
2.3.4	Guidelines for Monitoring Public Drinking Water Supplies				
i.	Verify that the parameters in the Guidelines for Monitoring Public Drinking Water Supplies (see Table A.5) have been analyzed as required in all raw water sources and treated water and document the sampling dates.			2.3.4	11
R.	 Review the data to: Verify that sampling locations and frequencies are appropriate. Identify if any maximum acceptable concentrations (MACs) have been exceeded. Identify any aesthetic parameters that may compromise disinfection or other critical processes. 	N		2.3.4	11
				1	

Con Indi	firm all applicable information has been submitted to the Department. cate the section and page number where the information is documented.	Yes	N/A	Section	Page #
iv.	Include laboratory results from the last round of sampling as an Appendix.	V		2.3.4	11
v.	Identify when the next round of sampling is scheduled to occur.	1		2.3.4	11
vi.	If any MACs are exceeded, recommend corrective actions.		4		
vii.	Recommend any changes to the monitoring program, sampling location/frequencies if necessary.		V		
2.3. *Thi Vate	5 Source Water Protection Plan Monitoring* s section is not applicable for municipalities that only distribute water purchased from and r Supply.	other M	unicipal	Public Dri	nking
i.					
	For Approval Holders monitoring any other chemical parameters for source water protection purposes, summarize the parameters, their sampling frequency, and their measured concentrations.			2.3.5	12
II.	For Approval Holders monitoring any other chemical parameters for source water protection purposes, summarize the parameters, their sampling frequency, and their measured concentrations. Recommend corrective actions if concentrations are detectable or increasing.			2.3.5 2.3.5	12

Con Indi	firm all applicable information has been submitted to the Department. cate the section and page number where the information is documented.	Yes	N/A	Section	Page #
2.3 . This	6 Cyanobacteria* section is only applicable to surface water sources.				
i.	Identify whether the source of supply has been impacted by cyanobacterial blooms.		4		
ii.	Summarize and append any results for cyanobacterial blooms through visual observation and/or confirmation from laboratory results including dates.		V		
iii.	Discuss any corrective actions taken when cyanobacteria have been detected in the source water.		7		
iv.	Discuss the treatment capability of the facility to remove microcystin toxins and identify any vulnerabilities.		7		
v.	Provide recommendations if necessary.		1		

Indic	firm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
2.4 *Not	Filter Backwash Water* applicable for municipalities that only distribute water purchased from another Municipal	l Public	Drinkin	g Water Su	pply
i.	Document the impact on the raw water source if water from the filter backwash treatment system is discharged upstream of the raw water intake.				
ii.	Provide recommendations if this discharge impacts the source.		1		
*Not	applicable for municipalities that only distribute water purchased from another Municipa	I Public	Drinkin	g Water Si	upply
*Not i.	Compile existing Water Withdrawal Approvals and include copies of these as an Appendix.	l Public	Drinkin	g Water Su 2.5	upply 13
*Not i. ii.	applicable for municipalities that only distribute water purchased from another Municipa Compile existing Water Withdrawal Approvals and include copies of these as an Appendix. Complete Table A.6.a and A.6.b to compare water withdrawals to approved limits.	l Public	Drinkin	g Water Su 2.5 App. A	upply 13
*Not i. ii. iii.	applicable for municipalities that only distribute water purchased from another Municipa Compile existing Water Withdrawal Approvals and include copies of these as an Appendix. Complete Table A.6.a and A.6.b to compare water withdrawals to approved limits. Recommend corrective actions, including water conservation measures, if water withdrawals are greater than approved limits.	l Public	Drinkin	g Water St 2.5 App. A 2.5	13 13

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
2.6 *Not	Source Water Protection Plan* applicable for municipalities that only distribute water purchased from another Municipa	1 Public	Drinking	g Water Su	ipply.
i.	Identify the source water protection zone(s) on a map.	1		2.6	14
ii.	Submit the source water protection zone(s) in GIS format to the Department. If zones are not available in GIS format, contact the Watershed Planner for your supply.				
iii,	Summarize the status of the source water protection plan and implementation schedule.	1		2.6	14
iv.	Document the dates of the last two SWPP meetings.		-	Î	
v.	Note the status of meeting actions and/or SWPP deliverables.	7		2.6	14
vi.	Make recommendations to address any concerns identified by the advisory committee or the source water protection planning process.	1		2.6	14
2.7	Conclusions and Recommendations				
i.	Refer to the Terms of Reference.	1		2.7	

PART III Treatment Processes, Facilities and Equipment

3.0 Evaluation of Treatment Processes, Facilities and Equipment

Conf Indic	rm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
3.1	Treatment Processes				
i.	Compile existing Approval(s) to Operate and include copies of these as an Appendix. For Approval Holders that only distribute water purchased from another Municipal Public Drinking Water Supply, document the name of the treatment facility, and proceed to section 3.2.	V		App. G	
3.1.	Treatment Process Schematic				
i,	Provide a schematic of the treatment process from the source to treated water entering the distribution system.	2		3.1	19
3.1.	2 Turbidity Levels and Associated Criteria				
a) S	irface Water				
i.	Verify that filtration technologies are meeting specified turbidity limits to receive the assigned log removal credits outlined in Table C2 of the Nova Scotia Treatment Standards for Municipal Drinking Water Systems by either Option 1 or Option 2.		1		
ii.	Submit individual filter effluent turbidity values for the most recent calendar year by month (Option 1) or by the time interval graphed (Option 2).		1		
iii.	Recommend corrective actions if the supply does not meet stipulated turbidity limits.		V		

Nova Scotia System Assessment Report Terms of Reference Checklist / Part III

Conf	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
iv.	For Municipal Public Drinking Water Supplies with cartridge filters assigned log reduction credits for protozoa, provide the highest recorded individual filter differential pressure reading for each month of the most recent calendar year.		V		
v.	Review the standard operating procedures (SOPs) for the filtration process:		1		
	 Have control limits been set to alarm and notify operators of issues related to the filtration process? 				
	 Have procedures been developed to remove a filter or membrane unit from service before turbidity or differential pressure (i.e., for cartridge filters assigned log reduction credits) exceeds stipulated values? 				
	 Have procedures been implemented and communicated to all operations staff? 				
	 Have procedures been documented in the operations manual? 				
vi.	Inspect the filtration process to verify that continuous on-line turbidity measurements are taken and recorded for each individual filter at a minimum of once every five minutes.		V		

Conf. Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
vii.	 Inspect the on-line turbidimeters: Do they have the required range and accuracy to measure turbidity levels? Are they in good working order? Do they have a maintenance and quality assurance/calibration program? 		V		
/iii.	Inspect the filtration process to verify that there are a minimum of two filters.		1		
ix. Not serv exp whi	Document if the maximum day flow can be met with the largest filter out of service. e: If the facility is unable to meet maximum day flows with the largest filter out of rice, improvements to meet the Treatment Standards may be deferred to a future ansion provided SOPs are in place to minimize filter rate changes and spikes in turbidity ch can result in filter breakthrough.				
x.	Make recommendations to address any concerns identified by the review of the filtration SOPs, inspection of on-line turbidimeters, and filter redundancy.				

b) G	iUDI Wells		
i.	Verify that natural filtration is achieving specified turbidity limits to receive the assigned log removal credits outlined in Table C2 of the Nova Scotia Treatment Standards for Municipal Drinking Water Systems by either Option 1 or Option 2.	V	
ii.	Submit individual GUDI well turbidity values for the most recent calendar year by month (Option 1) or by the time interval graphed (Option 2).	1	
iii.	For GUDI wells that do not meet stipulated turbidity limits, contact the Department to determine what requirements shall apply.	1	
iv.	Inspect the site(s) to verify that continuous on-line turbidity measurements are taken for each individual GUDI wellhead at a minimum of once every five minutes.	V	
v.	 Inspect the on-line turbidimeters: Do they have the required range and accuracy to measure turbidity levels? Are they in good working order? Do they have a maintenance and quality assurance/calibration program? 	N	
vi.	Make recommendations to address any concerns identified by the inspection of the on-line turbidimeters.	1	



Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
c) N	on-GUDI Wells				
i.	Summarize turbidity levels in non-GUDI wells by either Option 1 or Option 2.	1		3.1.2.3	21
ii.	Note if measurements are by daily grab samples or continuous on-line turbidimeters.			3.1.2.3	21
ili.	Submit non-GUDI system turbidity for individual wells or combined flow for the most recent calendar year by month (Option 1) or by the time interval graphed (Option 2).			3.1.2.3	21
iv.	For non-GUDI wells that do not meet stipulated turbidity limits, contact the Department to determine what requirements shall apply.		1		
v	 Where continuous measurements are taken, inspect the on-line turbidimeters: Do they have the required range and accuracy to measure turbidity levels? Are they in good working order? Do they have a maintenance and quality assurance/calibration program? 	V		3.1.2.4	22
vi.	Where grab samples are taken, inspect the monitoring equipment, SOPs, maintenance, and quality assurance/calibration program to ensure equipment is in good working order and measurements are appropriate.		1		
vii.	Make recommendations to address any concerns identified by the inspection of on-line turbidimeters or grab sample protocols.			3.1.2.4	22

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
3.1.	3 Membrane Filtration – Additional Requirements				
Ì.	Complete Table B.1 to verify that each individual membrane treatment unit that is used for pathogen reduction credits is free of any integrity breaches and determine its log removal value using pressure-based testing.		1		
ii.	Make recommendations to address any concerns identified.		1		
iii.	For Municipal Public Drinking Water Supplies with integrated membrane systems, summarize the process used to verify the rejection rate remains adequate for organics removal.				
iv.	Make recommendations to address any concerns identified.		1		
3.1.	4 Primary Disinfection				
i.	Document how many inactivation log credits are required by the disinfection process for each target microorganism (e.g., protozoa and/or viruses).			3.1.4	23
ii.	Discuss how disinfection is achieved (e.g., chemical disinfectants, UV or both).	1		3.1.4.1	23



i) C	hemical Disinfection (CT Concept)				
i.	Where chemical disinfectants are used, provide a schematic of the primary disinfection process including, but not limited to:			3.1.4.1	24
	• Tank(s) dimensions.				
	 Baffling configuration and assumed baffling factor. 				
	• Water level operating range, highlighting the low level.				
	 Disinfection type (e.g., free chlorine, chlorine dioxide, ozone). 				
	• Minimum disinfectant concentration at the CT control point.				
	Minimum water temperature.				
	 Maximum pH of the water for free chlorine or optimum pH for chlorine dioxide or ozone. 				
	 Maximum flow and minimum retention time - if the tank used to achieve CT is subject to water level fluctuations, verify if the inflow/outflow represents the maximum flow condition. 			1	
ii,	Calculate the design CT.	1		3.1.4.1	24
ii.	Verify that operational conditions remained within the design range for achieving CT at all times during the most recent calendar year.			3.1.4.1	24
v.	Where operational conditions went outside the design range, identify the cause, document the corrective actions taken and verify that CT was calculated during every such event.		1		
v.	Make recommendations to address any concerns identified.		1		

i.	Where UV disinfection is used, provide a schematic of the primary disinfection process including, but not limited to:			
	Unit manufacturer and model.			
	Validation standard.			
	Maximum flow.			
	• Minimum intensity at the end of lamp life.			
	• Minimum transmittance at the end of lamp life.			
	Correction for water temperature.			
	 Maximum concentrations for water quality parameters that promote fouling (e.g., iron, manganese, hardness). 			
	Sleeve cleaning method.			

Conf	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
ili.	Verify that the following conditions were met at all times during the most recent calendar year:		V		
	• Was the intensity above the minimum required?				
	• Was the flow below the maximum allowed?				
	• Was the transmittance above the minimum required?				
iv.	Where operational conditions went outside the design range, identify the cause, document the corrective actions taken and verify that IT was calculated during every such event.		V		
v.	Provide recommendations to address any concerns identified.		1		
c) R	edundancy, Continuous Monitoring and Alerting				
i.	Inspect the primary disinfection process to verify the following:	V		3.1.4.3	25
	• Are there a minimum of two primary disinfection units?	1.5			
	 Are the primary disinfection units sized to meet maximum day demand with one unit out of service? 				
	 Is on-line monitoring of the primary disinfection process in place with measurements taken and recorded at least once every five minutes? 				
	 Have control limits been set to alarm and notify operators that the primary disinfection process is not working properly? 				
	 Are protocols in place to prevent inadequately disinfected water from entering the distribution system? 				
ii.	Inspect the on-line instrumentation:	¥		3.1.4.3	25
	 Do they have the required range and accuracy to measure chlorine concentrations? 				

Conf ndic	rm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
	Are they in good working order?Do they have a maintenance and quality assurance/calibration program?				
iii.	Provide recommendations to address any concerns identified.		1		
d) S	andard Operating Procedures				
i.	Review the standard operating procedures for the disinfection process:		V		
	 Do they specify the design ranges for achieving CT (e.g., temperature, disinfectant residual, flow, pH) or Π (e.g., intensity, flow, transmittance)? 				
	 Do they include notification and response procedures when operational conditions are outside CT or Π design ranges? 				
	 Do they include procedures to ensure the disinfection process is working properly? 				
	 Do they include response procedures when the disinfection process is not working properly? 				
	• Have they been implemented and communicated to all operations staff?				
-	 Have they been documented in the operations manual? 	1 -			
ii.	Provide recommendations to address any concerns identified.			3.1.4.4	25
3.1.	5 Secondary Disinfection				
i.	Describe the secondary disinfection process.			3.1.5	25
ii.	Inspect the secondary disinfection process to verify the following:	V		3.1.5	25

	 Are on-line continuous chlorine residual monitors in place to measure chlorine residual entering the distribution system at least once every five minutes? 				
2	 Are the on-line chlorine residual monitors in good working order? Is there a maintenance and quality assurance/calibration program in place? 				
iii.	Where free chlorine is used for both primary and secondary disinfection, refer to Section 3.1.4 and note if the chlorine dose is controlled by CT (primary disinfection) or distribution system residual maintenance (secondary disinfection).	V		3.1.5	25
iv.	Where UV light is used for primary disinfection to receive protozoa inactivation credits, calculate the design CT for virus inactivation credits.				
v.	Where UV light is used for primary disinfection to receive protozoa inactivation credits, verify that operational conditions remained within the design range for achieving CT for virus inactivation at all times during the most recent calendar year.		5		

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
vi.	Where operational conditions went outside the design range, identify the cause, document the corrective actions taken and verify that CT was calculated during every such event.		2		_
vii.	Provide recommendations to address any concerns identified.		1		
3.1.	6 Other Critical Processes				
i.	Evaluate and inspect other critical processes against established standards and guidelines.		V		
ii.	Recommend corrective actions where necessary.		V		
3.1.	7 Waste Streams				
a) F	lter-to-Waste				
ì.	Describe the filter-to-waste process.		1		
ii.	For chemically assisted filtration, verify that turbidity is less than or equal to 0.2 NTU before returning a filter to service.		V		
iii.	Identify recommendations, if necessary, to meet the Nova Scotia Treatment Standards for Municipal Drinking Water Systems.		1		
b) F	lter Backwash Water – Discharge Into A Freshwater Watercourse	-			
i.	Summarize treatment of the filter backwash water, if applicable, and identify the watercourse it is discharging into.		1		
	Identify any discharge criteria specified in the Approval to Operate		1		-

ndic	ate the section and page number where the information is documented.		_	_
iii.	Complete Table B.2.		App A	
	 Does sampling meet the minimum requirements as outlined in the Nova Scotia Treatment Standards for Municipal Drinking Water Systems? 			
	 Does effluent quality meet the discharge criteria stipulated in the Approval to Operate? 			
v.	If the water quality does not meet the discharge criteria stipulated in the Approval to Operate or if there are no discharge criteria stipulated in the Approval to Operate, identify recommendations to meet the requirements specified in Part V – Management of Waste Streams of the Nova Scotia Treatment Standards for Municipal Drinking Water Systems.	1		
v.	Recommend corrective actions where necessary to address any concerns identified.	V		

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page
c) F	ilter Backwash Water – Discharge To Land Or Soil				
i.	Summarize treatment of the filter backwash water, if applicable, and identify the location of discharge.		1		
ü.	Identify whether the municipal public drinking water supply has a Discharge Management Plan in accordance with Part V – Management of Waste Streams of the Nova Scotia Treatment Standards for Municipal Drinking Water Systems, as amended from time to time.		ø		
iii.	ldentify the effluent discharge criteria specified in the Approval to Operate, or the Department accepted Discharge Management Plan.		1		
iv.	 Complete Table B.3. Does effluent quality meet the discharge criteria stipulated in the Approval to Operate, or the Department accepted Discharge Management Plan? 		1		
v.	If the water quality does not meet the discharge criteria stipulated in the Approval to Operate, or the Department accepted Discharge Management Plan, identify recommendations to meet the minimum requirements for a plan specified in Part V – Management of Waste Streams of the Nova Scotia Treatment Standards for Municipal Drinking Water Systems, as amended from time to time.		ø		
vi.	Identify operational, maintenance, and monitoring procedures in the Discharge Management Plan that do not meet the minimum requirements for a plan as specified in Part V – Management of Waste Streams of the Nova Scotia Treatment Standards for Municipal Drinking Water Systems, as amended from time to time.		V		
vii.	Recommend corrective actions where necessary to address any concerns identified.		1		

Conf	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
d) Fi	lter Backwash Water – Discharge To A Marine Or Brackish Environment				
L.	Summarize treatment of the filter backwash water, if applicable, and identify the watercourse it is discharging into.		1		
ii.	Identify any discharge criteria specified in the Approval to Operate.		5		
iii.	 Complete Table B.4. Does effluent quality meet the discharge criteria stipulated in the Approval to Operate? 		N		
iv.	Recommend corrective actions where necessary to address any concerns identified.		N		
e) ()	ther Waste Streams				
i.	Review other waste streams and verify that they are being managed appropriately.		1		
ïi.	Provide recommendations to address any concerns identified.		1		



Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
3.2	Distribution Water Quality				
3.2.	1 Chlorine Residual Levels				
i.	Review distribution system chlorine residuals for the most recent calendar year available.	2		3.2.1	26
ü.	Recommend corrective actions where residuals are routinely less than 0.20 mg/L or 0.40 mg/L (depending on the concentration specified in the Municipal Public Drinking Water Supply's Approval to Operate) where free chlorine is used (or less than 1.0 mg/L combined chlorine for chloraminated systems).	1		3.2.1	26
iii.	Inspect all distribution water storage tanks to verify that on-line continuous chlorine residual monitors are in place to measure chlorine residual at the storage tank outlet at least once every five minutes.	2		3.2.1	26
iv.	Inspect the on-line chlorine residual monitors to ensure that they are in good working order and that a maintenance and quality assurance/calibration program is in place.	V		3.2.1	26
v.	Recommend corrective actions where necessary.	1		3.2.1	26

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
3.2.	2 Microbiological Water Quality				
i.	Review total coliforms and E. coli results for the most recent calendar year available.	1		3.2.2	26
ii.	Discuss any presence of bacteria in the distribution system and identify recommendations where necessary.		1		
iii.	Verify that sampling locations and frequencies meet the requirements of the Guidelines for Monitoring Public Drinking Water Supplies Part I, including any re- sampling required after the presence of bacteria is detected.			3.2.2	26
iv.	Identify sampling locations on a map of the distribution system.	4		App C	
v.	Recommend sampling location/frequency changes if necessary.		4		

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
3.2.	3 Turbidity				
i.	Review distribution system turbidity results for the most recent calendar year available.	V		3.2.3	27
ii.	Verify that a protocol exists for investigating the cause of turbidity values above 5 NTU.			3.2.3	27
iii.	Discuss any values above 5 NTU and identify recommendations identified where necessary.	5		3.2.3	27

Conf ndic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Paget
3.2.4	4 Cross Connection Control Program				
i.	Review the cross connection control program.	1		3.2.4	27
	 Does it meet the minimum requirements as outlined in A Guide to Assist Nova Scotia Municipal Water Works Develop a Cross Connection Control Program, as amended from time to time. 				
	• Are implementation timelines being met in accordance with the accepted plan? Provide an update on the status of the Cross Connection Control Program, including any modifications to the plan or implementation schedule, and a summary of the activities taken to achieve the goals and objectives of the program.				
ii.	Provide recommend where necessary.		1		
3.2.	5 Other Distribution System Monitoring/Programs				
ì.	Review any other distribution system monitoring or programs that are in place to deal with threats to distribution system integrity, including but not limited to infrastructure age, watermain breaks, leak detection, pressure transients, etc.		V		
ü.	Provide recommendations where necessary.		4		

Confirm Indicate	all applicable information has been submitted to the Department. the section and page number where the information is documented.	Yes	N/A	Section	Page #
3.3 Si	te Inspection				
i. C fa T	onduct a site inspection to evaluate treatment processes, as well as other culities and equipment as per the requirements outlined in section 3.3 of the erms of Reference.	1		3.3	27
3.4 Co	onclusions and Recommendations				
i. R	efer to section 3.4 of the Terms of Reference.	V		3.4	

PART IV Operations, Monitoring and Management

4.0 Review of Operations, Maintenance, Monitoring and Management

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
4.1	Operations and Maintenance				
j.	Review the comprehensive operations manual: • Does one exist?	1		4.1	30
	• Is it current and up to date?				
	 Does it include SOPs, emergency notification procedures and contingency plans? 		-		
	• Is it available on site or an alternate location accepted by the Department?				
	• Are operations staff aware of its contents?				
ü.	Evaluate the procedures an operator follows to identify any problem(s) with the water treatment and distribution process, determine the changes needed to correct the problem(s) and how adjustments to the processes are approved and performed as needed.	5		4.1	30
iii.	Verify that a maintenance program exists and is adequate to ensure the long-term viability of the Municipal Public Drinking Water Supply, including distribution system components.			4.1	30
iv.	Identify recommendations where necessary.	V		4.1	30
4.2	Monitoring and Reporting				-

Nova Scotia System Assessment Report Terms of Reference Checklist / Part IV

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
î.	Review the annual monitoring program to:	4		4.2	31
	• Does one exist?				
	• Is it current and up to date?				
	 Does it meet the minimum requirements as outlined in the Nova Scotia Treatment Standards for Municipal Drinking Water Systems and A Guide to Assist Nova Scotia Municipal Water Works Prepare Annual Sampling Plans? Are operations staff aware of its contents? 				
ii.	Identify the laboratories being used for water quality analyses.	5		4.2	31
iii.	Verify that the Municipal Public Drinking Water Supply is operating in accordance with the Policy on Acceptable Certification of Laboratories.	V		4.2	31
iv.	Review reporting requirements and verify that the Approval Holder has complied with the immediate, annual and ad hoc reporting requirements outlined in the Nova Scotia Treatment Standards for Municipal Drinking Water Systems.	3		4.2	31
v.	Review the most recent annual report and identify any concerns in the System Assessment Report.	2		4.2	31
vi.	Identify recommendations where necessary.	V		4.2	31

Confi Indica	rm all applicable information has been submitted to the Department. Ite the section and page number where the information is documented.	Yes	N/A	Section	Page #
4.3	Management				
i.	Review the number of certified operators and back-up personnel to verify that the municipal public drinking water supply is operating in accordance with Part I of the Water and Wastewater Facilities and Public Drinking Water Supplies Regulations.			4.3	33
ä,	Complete Table C.1 to identify the operator(s) in overall direct responsible charge (ODRC) and summarize what protocols are in place during the absence of the operator(s) in ODRC.	N		App. A	
ili.	Review the water quality goals that the Municipal Public Drinking Water Supply has and evaluate their plan(s) to accomplish or maintain these goals.			4.3	33
iv.	Identify recommendations where necessary.	V		4.3	33
4.4	Conclusions and Recommendations				
i.	Refer to section 4.4. of the Terms of Reference.	1		4.4	

PART V REPORT SUBMISSION

5.0 Ability to Comply

Conf Indic	irm all applicable information has been submitted to the Department. ate the section and page number where the information is documented.	Yes	N/A	Section	Page #
5.1	Summary				
i.	Summarize conclusions and identify all recommendations necessary to meet the Nova Scotia Treatment Standards for Municipal Drinking Water Systems.	1		5.1	34
ii.	Include preliminary cost estimates and an implementation schedule to address the above requirements. Costs shall be presented and prioritized with respect to public health risks.	1		5.1.4	34
	Note: If the corrective action plan submitted to the Department varies from the risk-based approach documented in the System Assessment Report, written justification shall be included in the corrective action plan for varying the priority.				
iii.	Highlight any obvious problems associated with the Municipal Public Drinking Water Supply that jeopardize treated water quality to the point that it no longer meets the health protection standards adopted by the Department.		V		

Nova Scotia System Assessment Report Terms of Reference Checklist / Part V

ndic	ate the section and page number where the information is documented.	Yes	N/A	Section	Page t
5.2	Report Preparation				
i.	Submit three (3) copies of the System Assessment Report to the Department and include a copy of this completed checklist.	1			
ii.	Engineer's Declaration (refer to section 1.4 of the Terms of Reference)	V	Ц	5.2	38


Ach I C

KOHLER

Solutions today | Tomorrow 🕟 mind

