

SEWER SERVICE CONNECTION
FEES, NOTICE OF INSPECTION REQUIREMENTS AND
SPECIFICATION DETAILS

This application is for the approval of a sewer connection to the Municipal Sewer System. Not all existing lots have sewer service lateral pipes installed to them. The customer is advised to confirm the presence of a lateral pipe by contacting the Municipal Operations Office in Bridgetown at 902-665-4704.

The Municipality's Bylaws provide for the charging of fees for sewer connections. The Bylaws require that persons connecting to the sewer systems comply with technical specifications. The Bylaws require that the Municipality inspect sewer service pipe and fitting installations. The Bylaws require that the installer provide the Municipality sufficient notice to enable the Municipal Inspector to carry out the Municipal inspection.

THE MUNICIPALITY'S FEES, NOTICE OF INSPECTION REQUIREMENTS, AND SPECIFICATION DETAILS ARE OUTLINED IN THE FOLLOWING:

FEES:

The Municipality charges a fee of \$75.00 for the inspection of a sewer service connection.

The Property Owner is required to pay fees, unless the requirement is waived in writing by the Municipality. The Property Owner is required to supply and install all pipes and fittings for the sewer service connection.

NOTICE OF INSPECTION REQUIREMENTS:

The customer is required to have the Municipality inspect the work **before it is backfilled**. The Customer is to notify the Municipality and allow approximately two (2) working days' notice that an inspection is required. To book an inspection please call the Municipal Operations office in Bridgetown at 902-665-4704, between the hours of 8:30 am and 4:30 pm, Monday to Friday, excepting Public Holidays.

SPECIFICATION DETAILS:

- Sewer pipe shall be PVC, SRD 35, conforming to CAN/CSA B182.1;
- Buried sewer pipe shall be joined using rubber gasket joints (the use of glued joints for buried pipe shall not be permitted);
- Sewer pipe shall have a minimum diameter of 4 inches (100 mm);
- Sewer pipe shall be installed at a minimum gradient (slope) of 1% (1/8 inch per foot) and a maximum gradient of 15% (1 and 3/4 inches per foot);
- Sewer pipe shall be installed and backfilled in accordance with the Manufacturer's instructions.

I hereby agree to comply with the Sewer Bylaw for the Municipality of the County of Annapolis as well as the specifications for installation of sewer lateral(s) on private property.

Print Name

Signature

Date